

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月23日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.81	2.31	61.62	2.21	19.32	10.03	1.24	70504.10
1	4.56	1.57	51.55	2.83	18.36	11.09	1.28	68672.59
2	8.57	1.60	46.24	3.13	19.56	10.56	1.28	72694.43
3	4.85	3.33	55.69	3.81	16.00	11.64	1.28	65945.82
4	3.03	1.41	49.12	3.04	16.99	10.94	1.27	68647.49
5	6.08	3.96	42.71	3.77	15.68	10.94	1.26	64421.89
6	8.45	4.14	43.80	4.53	15.85	10.89	1.26	66568.77
7	8.03	2.17	51.46	3.60	17.08	10.79	1.26	67715.49
8	7.81	1.70	52.14	3.36	17.77	10.52	1.27	69008.88
9	7.64	2.86	45.97	3.58	16.57	10.74	1.25	67420.05
10	9.29	2.13	51.18	4.02	17.42	10.67	1.27	68212.62
11	4.13	2.42	51.43	3.41	15.77	11.42	1.28	63874.06
12	9.20	2.23	49.65	3.53	17.13	10.48	1.28	70078.06
13	7.44	3.76	52.87	3.24	16.63	11.14	1.31	66954.38
14	7.72	6.99	50.63	3.94	14.91	11.47	1.33	65470.84
15	8.36	5.81	48.89	4.00	15.56	11.22	1.33	65581.39
16	8.40	2.26	68.77	3.83	19.37	9.99	1.33	71885.83
17	9.74	2.48	39.13	4.13	17.24	10.35	1.32	68929.88
18	5.35	2.06	46.88	2.77	17.80	11.03	1.32	68932.44
19	7.73	1.78	70.12	2.56	19.56	10.60	1.33	71618.57
20	6.49	2.53	41.93	3.07	16.71	11.44	1.31	66273.46
21	8.84	2.87	63.33	2.93	17.52	11.12	1.30	70657.37
22	8.51	5.15	41.34	3.73	15.43	11.62	1.30	66411.72
23	7.55	2.80	51.42	3.50	16.30	11.61	1.33	67849.35
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.07	2.93	51.16	3.44	17.11	10.93	1.29	68097.06
最大值	9.74	6.99	70.12	4.53	19.56	11.64	1.33	72694.43
發生時間	17	14	19	6	2	3		2
最小值	1.81	1.41	39.13	2.21	14.91	9.99	1.23	63874.06
發生時間	0	4	17	0	14	16		11
零點偏移(率)	-0.03 %	-0.01 %	-0.02 %	-0.01 %		-0.02	0.00	0.00 %
全幅偏移(率)	0.02 %	0.03 %	-0.02 %	0.02 %		-0.04	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月23日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.12	1.87	40.91	1.72	19.54	9.96	1.42	84440.28
1	5.31	2.05	44.58	1.67	20.15	9.71	1.42	84685.91
2	7.34	1.81	47.71	2.36	18.51	9.79	1.44	83930.11
3	7.52	3.23	48.45	2.78	18.37	9.61	1.42	82393.87
4	8.59	4.77	44.66	2.59	19.23	9.50	1.45	84818.59
5	5.94	2.68	40.37	2.58	18.08	9.23	1.46	82123.69
6	9.56	2.00	42.35	3.85	17.35	9.53	1.45	84028.05
7	8.47	3.34	47.06	2.74	17.69	9.39	1.46	82135.35
8	7.18	0.99	51.79	2.49	17.03	9.97	1.46	83247.74
9	6.10	1.02	54.07	2.36	16.59	10.32	1.47	82030.48
10	9.27	1.11	55.42	2.31	17.52	10.10	1.48	82622.09
11	10.34	4.04	44.34	3.02	16.58	10.05	1.48	83152.81
12	10.55	1.44	57.98	2.53	17.34	9.97	1.46	82248.19
13	7.01	3.03	46.57	2.31	17.95	9.69	1.45	81871.28
14	5.49	3.74	53.99	1.91	18.95	9.21	1.43	85342.23
15	8.48	7.17	40.93	2.51	16.92	9.74	1.43	79911.06
16	6.63	13.35	55.32	2.24	19.18	9.57	1.45	79679.14
17	10.08	1.96	44.70	3.06	18.48	9.24	1.46	82450.79
18	8.32	1.90	52.00	2.27	17.98	9.48	1.46	81402.42
19	8.29	1.33	55.76	1.99	18.47	9.60	1.47	84107.86
20	6.54	3.02	60.83	1.56	20.10	9.38	1.48	83676.60
21	9.23	3.41	40.62	2.26	18.62	9.45	1.48	82985.39
22	8.92	1.91	49.45	2.16	18.47	9.81	1.46	81450.89
23	6.23	1.33	64.87	1.53	19.75	9.55	1.47	82688.39
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.77	3.02	49.36	2.37	18.29	9.66	1.45	82809.30
最大值	10.55	13.35	64.87	3.85	20.15	10.32	1.49	85342.23
發生時間	12	16	23	6	1	9		14
最小值	5.12	0.99	40.37	1.53	16.58	9.21	1.41	79679.14
發生時間	0	8	5	23	11	14		16
零點偏移(率)	-0.22 %	-0.01 %	-0.09 %	0.00 %		0.02	0.00	0.00 %
全幅偏移(率)	0.38 %	-0.51 %	0.15 %	0.15 %		-0.08	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月23日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.00	2.11	59.71	2.36	17.74	10.86	1.35	73148.61
1	6.21	5.94	47.07	2.45	20.42	9.74	1.37	81708.86
2	8.74	2.63	44.44	3.30	18.28	9.91	1.38	84118.51
3	6.86	1.62	53.92	2.89	15.86	11.04	1.38	73607.68
4	7.64	1.56	56.81	2.83	17.44	10.35	1.38	82103.64
5	6.75	1.31	61.41	2.93	16.45	10.89	1.38	78373.71
6	9.74	1.21	59.61	3.16	15.69	10.92	1.39	83055.45
7	1.59	5.77	66.01	2.27	15.27	11.40	1.39	69955.44
8	4.60	1.15	49.47	2.52	14.98	11.21	1.39	79768.75
9	6.56	1.39	49.18	2.38	15.63	11.11	1.39	81456.00
10	2.92	1.60	52.10	2.23	16.05	11.06	1.40	80578.50
11	5.20	1.48	47.00	2.44	15.12	11.00	1.42	81025.15
12	6.80	2.01	50.22	3.01	14.70	10.98	1.42	80831.68
13	5.06	1.61	50.42	2.44	16.35	10.85	1.41	80468.21
14	5.93	1.20	50.14	2.33	16.56	10.68	1.39	81376.22
15	8.46	1.24	62.61	2.35	16.90	10.79	1.39	80063.97
16	7.97	1.25	68.94	2.15	17.35	11.25	1.40	76897.19
17	9.24	3.13	44.27	2.05	17.43	10.59	1.42	81781.49
18	7.51	2.06	48.29	2.17	16.42	10.94	1.41	77798.78
19	4.19	1.66	48.49	1.98	17.68	10.51	1.42	82954.44
20	5.90	1.49	52.46	2.12	18.24	10.12	1.43	84878.47
21	8.29	1.17	46.19	2.44	16.94	10.29	1.42	83035.60
22	8.99	1.23	44.35	2.28	16.70	11.03	1.43	79196.18
23	8.41	1.40	46.43	2.20	17.65	10.62	1.43	84585.15
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.52	1.97	52.48	2.47	16.74	10.76	1.40	80115.32
最大值	9.74	5.94	68.94	3.30	20.42	11.40	1.45	84878.47
發生時間	6	1	16	2	1	7		20
最小值	1.59	1.15	44.27	1.98	14.70	9.74	1.33	69955.44
發生時間	7	8	17	19	12	1		7
零點偏移(率)	-0.01 %	-0.01 %	-0.24 %	0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	-0.68 %	-0.28 %	-0.17 %	0.02 %		-0.12	-0.03	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								