

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月03日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.77	3.48	53.94	3.13	15.18	12.18	1.51	72091.82
1	10.23	4.94	49.18	3.49	14.80	12.25	1.51	70821.90
2	10.05	3.55	45.57	3.18	16.23	11.86	1.51	73044.85
3	6.99	6.78	65.47	3.31	15.59	13.19	1.61	63406.69
4	9.65	3.86	45.16	2.50	16.98	11.72	1.51	74258.36
5	10.68	6.10	62.49	2.47	16.92	11.70	1.51	72770.45
6	11.24	3.33	53.02	2.81	16.46	11.72	1.50	74563.70
7	10.66	3.34	54.17	3.32	15.66	11.86	1.50	73943.60
8	5.33	3.49	61.25	3.04	15.50	12.46	1.47	69531.21
9	7.28	3.47	52.58	2.29	17.27	11.64	1.46	73860.09
10	9.69	3.67	55.67	2.98	15.88	12.11	1.46	70638.67
11	9.87	3.46	58.10	2.98	15.96	12.14	1.46	70488.70
12	5.47	3.62	49.80	2.82	15.69	12.15	1.49	70886.39
13	3.25	3.55	59.31	2.33	16.33	12.08	1.51	71025.13
14	1.04	3.67	52.92	2.43	15.97	12.06	1.51	71203.18
15	0.16	4.13	56.23	2.81	15.82	13.06	1.57	63624.84
16	0.82	1.22	53.23	2.36	16.35	12.04	1.49	71616.69
17	2.69	1.67	54.00	2.56	15.70	12.07	1.45	71204.39
18	1.95	3.65	57.52	2.65	15.38	12.14	1.44	70932.39
19	2.40	3.38	61.12	2.41	16.19	12.22	1.49	69954.12
20	1.68	3.39	60.42	2.05	17.12	11.87	1.50	71917.66
21	3.98	3.42	50.79	2.22	17.02	11.79	1.49	71779.11
22	4.39	3.21	62.75	2.01	17.43	11.81	1.50	71711.23
23	1.80	3.29	69.04	1.83	17.40	11.68	1.49	72450.85
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.88	3.65	55.99	2.67	16.20	12.08	1.50	71155.25
最大值	11.24	6.78	69.04	3.49	17.43	13.19	1.96	74563.70
發生時間	6	3	23	1	22	3		6
最小值	0.16	1.22	45.16	1.83	14.80	11.64	1.42	63406.69
發生時間	15	16	4	23	1	9		3
零點偏移(率)	-0.03 %	0.00 %	-0.02 %	-0.00 %		-0.02	0.00	0.00 %
全幅偏移(率)	4.04 %	0.54 %	-0.97 %	0.30 %		0.12	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月03日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.38	3.33	53.02	2.03	18.58	10.24	1.51	86233.72
1	10.39	3.41	57.54	2.19	18.29	10.33	1.52	84557.97
2	9.76	3.82	50.28	2.06	18.20	10.86	1.51	81500.90
3	10.38	3.67	59.45	2.24	18.23	10.66	1.51	80879.78
4	10.23	3.44	46.62	2.93	16.72	10.50	1.50	83835.83
5	10.47	3.60	52.95	3.09	16.11	10.69	1.50	82460.69
6	11.05	3.80	50.31	2.95	16.22	10.43	1.51	82214.30
7	9.34	4.76	49.43	2.58	17.09	10.38	1.51	82481.96
8	6.02	4.24	49.74	2.23	16.77	10.48	1.50	75675.08
9	1.10	3.85	58.21	1.29	17.77	11.04	1.53	76956.51
10	2.00	5.23	53.62	1.48	17.68	10.49	1.51	80936.76
11	8.95	3.50	50.97	2.28	16.95	10.46	1.52	80800.57
12	9.03	3.67	46.63	2.22	16.36	10.58	1.51	78779.82
13	7.63	6.58	47.26	2.42	15.74	11.13	1.49	79454.13
14	9.65	8.40	43.30	3.16	14.65	10.88	1.49	78267.90
15	6.75	4.84	46.39	2.35	16.45	10.40	1.50	78641.71
16	4.09	3.99	57.08	1.78	17.06	11.02	1.52	77695.63
17	9.10	4.38	52.27	2.25	17.47	10.57	1.51	82503.30
18	6.27	5.28	53.01	1.89	16.98	11.12	1.49	76480.25
19	6.21	4.86	50.71	1.76	18.00	10.74	1.50	81039.84
20	6.67	4.95	51.23	1.93	17.53	10.80	1.51	81151.50
21	6.76	5.43	53.13	2.06	16.54	11.01	1.51	79354.05
22	2.70	4.13	48.19	1.40	17.80	10.79	1.51	81653.38
23	6.46	6.56	53.34	1.31	18.84	10.23	1.54	86319.72
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.56	4.57	51.45	2.16	17.17	10.66	1.51	80828.14
最大值	11.05	8.40	59.45	3.16	18.84	11.13	1.56	86319.72
發生時間	6	14	3	14	23	13		23
最小值	1.10	3.33	43.30	1.29	14.65	10.23	1.48	75675.08
發生時間	9	0	14	9	14	23		8
零點偏移(率)	-0.16 %	-0.00 %	-0.19 %	0.00 %		-0.12	0.00	0.00 %
全幅偏移(率)	0.70 %	-0.03 %	-0.47 %	0.18 %		0.00	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月03日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.03	12.16	57.72	1.97	18.78	9.60	1.41	90994.86
1	8.94	3.24	50.84	1.81	17.36	10.11	1.42	85217.15
2	8.36	9.46	52.68	1.51	18.08	10.47	1.43	85080.04
3	9.67	8.07	57.63	2.00	17.35	10.62	1.43	88305.76
4	12.05	6.53	53.24	2.24	16.00	10.92	1.43	88645.31
5	8.67	4.68	67.44	2.22	15.87	10.88	1.43	85634.16
6	9.75	5.71	58.38	2.34	16.01	10.72	1.43	86867.76
7	10.47	7.25	57.48	1.98	17.34	10.13	1.43	88449.22
8	7.20	4.59	57.96	1.61	16.63	10.76	1.43	82719.09
9	5.80	6.34	62.10	1.53	17.52	10.31	1.43	83689.58
10	5.90	4.60	49.42	1.61	16.70	10.60	1.42	80382.28
11	4.56	4.17	47.06	1.58	16.33	10.28	1.42	83217.31
12	2.86	2.06	53.21	1.35	16.89	10.54	1.41	81431.07
13	2.58	3.47	55.61	1.34	16.77	10.47	1.43	82012.52
14	2.51	2.47	53.84	1.65	15.38	10.84	1.43	80064.09
15	2.61	2.31	61.13	1.62	15.97	10.96	1.41	79977.93
16	3.15	3.06	52.45	1.50	16.21	10.78	1.43	82482.37
17	3.63	2.63	55.85	1.67	16.00	10.70	1.41	81840.04
18	3.94	2.74	65.40	1.45	17.31	10.76	1.43	82444.71
19	2.45	3.54	50.13	1.26	17.59	10.45	1.43	85522.37
20	1.96	4.54	53.40	1.36	17.65	10.29	1.43	85040.30
21	6.15	4.60	53.27	1.71	17.37	10.40	1.43	83841.08
22	7.27	3.11	58.21	1.59	17.17	10.93	1.43	80153.55
23	1.90	2.78	62.85	1.35	17.79	10.98	1.43	80972.01
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.85	4.75	56.14	1.68	16.92	10.56	1.42	83957.69
最大值	12.05	12.16	67.44	2.34	18.78	10.98	1.44	90994.86
發生時間	4	0	5	6	0	23		0
最小值	1.90	2.06	47.06	1.26	15.38	9.60	1.39	79977.93
發生時間	23	12	11	19	14	0		15
零點偏移(率)	0.00 %	0.00 %	-0.00 %	-0.04 %		-0.03	0.00	0.00 %
全幅偏移(率)	0.82 %	0.03 %	-0.60 %	0.03 %		0.23	-0.03	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								