

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年10月16日

報表日期: 114年10月16日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.78	13.15	62.12	3.35	16.57	11.51	1.23	71502.36
1	7.39	13.15	69.86	2.51	18.46	10.95	1.25	73461.56
2	10.04	13.49	53.11	4.91	15.89	11.09	1.25	74254.31
3	9.90	15.55	47.64	3.37	14.47	11.66	1.25	69720.91
4	11.41	13.42	48.50	1.57	15.10	11.72	1.25	69764.45
5	3.45	12.84	58.24	3.01	15.87	11.69	1.21	69345.53
6	9.46	12.97	55.87	3.08	15.22	11.63	1.19	69923.81
7	8.50	13.21	47.76	1.77	15.71	11.53	1.19	69520.48
8	8.79	13.93	55.46	1.87	16.06	11.28	1.20	72097.32
9	12.66	12.72	55.20	2.74	15.52	10.89	1.18	73932.48
10	6.71	10.84	57.84	2.83	14.69	11.47	1.18	70256.45
11	9.06	11.08	48.91	3.43	14.67	11.69	1.18	70401.66
12	8.53	17.49	57.21	2.81	14.78	12.10	1.18	71610.16
13	10.43	13.19	50.65	2.98	13.92	12.22	1.18	72407.18
14	7.06	12.47	64.23	2.09	14.77	12.21	1.18	75133.93
15	9.35	18.24	47.07	3.25	13.68	12.29	1.18	74498.67
16	8.04	15.20	63.80	2.90	14.78	12.17	1.18	70337.86
17	10.64	12.70	56.02	3.27	16.43	11.09	1.18	74213.39
18	8.39	14.25	48.83	3.32	16.30	11.31	1.18	74010.24
19	8.31	15.18	55.20	2.31	17.37	11.36	1.18	73669.26
20	8.93	14.32	54.03	4.14	15.34	11.54	1.18	73198.66
21	8.72	14.08	56.64	2.74	16.93	11.28	1.18	73757.11
22	9.03	14.14	50.18	2.76	17.04	11.28	1.18	73865.95
23	9.13	15.12	52.84	2.60	16.54	11.68	1.18	71708.79
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.82	13.86	54.88	2.90	15.67	11.57	1.20	72191.35
最 大 值	12.66	18.24	69.86	4.91	18.46	12.29	1.25	75133.93
發生時間	9	15	1	2	1	15		14
最 小 值	3.45	10.84	47.07	1.57	13.68	10.89	1.18	69345.53
發生時間	5	10	15	4	15	9		5
零點偏移(率)	-0.01 %	0.01 %	-0.02 %	-0.01 %		0.02		0.20 %
全幅偏移(率)	-0.33 %	0.41 %	0.27 %	-0.19 %		0.38		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年10月16日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	6.71	13.42	51.78	1.72	15.78	9.29	1.31	75876.12
1	8.03	12.33	52.08	1.55	18.78	9.01	1.32	76930.73
2	8.33	12.33	48.84	1.55	17.91	8.75	1.36	79057.26
3	9.91	12.55	58.58	1.99	16.45	9.70	1.37	75696.55
4	8.66	12.26	58.07	1.96	16.41	9.72	1.36	76561.94
5	8.49	12.49	58.04	1.81	16.37	9.63	1.34	77090.49
6	7.98	13.85	56.30	2.63	14.72	10.07	1.32	72246.82
7	8.05	13.77	53.59	2.10	15.24	9.65	1.42	70560.78
8	9.89	11.22	53.17	2.13	16.02	9.43	1.40	77338.92
9	10.00	10.64	53.75	2.07	16.61	9.29	1.42	76776.25
10	7.90	11.68	51.25	1.80	16.18	9.31	1.37	74922.51
11	11.48	12.37	49.05	2.25	15.59	9.62	1.40	73353.61
12	10.22	12.39	51.05	2.49	14.90	9.84	1.41	73158.89
13	5.59	12.64	51.73	1.74	15.86	9.52	1.41	72706.21
14	9.04	11.73	57.53	1.98	16.31	9.82	1.41	77896.88
15	12.22	11.48	65.33	2.41	16.40	10.10	1.40	77998.41
16	8.44	11.55	57.43	1.99	15.90	10.12	1.37	79067.18
17	7.55	12.10	46.33	2.11	18.48	8.76	1.36	78291.40
18	6.85	10.54	52.43	1.43	18.31	9.15	1.41	76543.64
19	11.49	12.06	49.00	2.96	19.51	8.59	1.37	75549.64
20	8.57	11.77	50.42	1.82	17.98	9.94	1.36	67380.05
21	10.15	11.49	55.25	2.05	18.62	10.02	1.36	68138.34
22	7.65	12.53	65.35	1.91	18.44	10.84	1.36	69914.87
23	9.59	11.95	61.73	1.82	18.48	10.51	1.36	70313.76
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.87	12.13	54.50	2.01	16.89	9.61	1.37	74723.80
最 大 值	12.22	13.85	65.35	2.96	19.51	10.84	1.43	79067.18
發生時間	15	6	22	19	19	22		16
最 小 值	5.59	10.54	46.33	1.43	14.72	8.59	1.31	67380.05
發生時間	13	18	17	18	6	19		20
零點偏移(率)	-0.03 %	-0.06 %	-0.02 %	-0.01 %		0.00		0.10 %
全幅偏移(率)	-0.30 %	0.03 %	0.64 %	-0.63 %		0.40		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								