

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年03月04日

報表日期: 114年03月04日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	8.72	5.34	56.60	2.03	17.35	11.83	1.28	78683.47
1	4.80	4.91	54.43	2.22	17.02	11.98	1.29	77893.07
2	8.17	4.40	59.83	1.51	17.34	11.76	1.29	80167.42
3	7.11	3.02	60.06	1.50	17.39	11.81	1.29	79074.62
4	8.20	3.95	57.06	1.96	16.81	12.10	1.30	76919.20
5	1.50	3.04	58.24	0.97	17.34	12.34	1.27	73872.08
6	8.59	2.98	55.90	1.51	17.20	11.96	1.23	78090.23
7	8.84	2.96	61.59	0.96	17.65	12.04	1.23	76560.75
8	8.77	3.15	56.73	0.74	18.66	11.51	1.24	80205.58
9	7.48	3.22	52.71	1.02	18.67	11.33	1.26	81601.51
10	8.30	3.08	57.96	1.23	17.80	11.97	1.29	77243.63
11	8.74	3.04	57.61	1.51	17.12	12.08	1.29	76729.07
12	10.00	3.09	57.94	1.26	17.86	11.61	1.29	80203.41
13	8.80	2.96	55.09	1.91	16.71	11.89	1.30	78793.58
14	9.44	3.04	58.43	1.67	17.29	11.78	1.29	79157.86
15	9.24	4.97	55.58	1.21	18.85	11.07	1.29	83024.14
16	7.19	4.14	52.89	1.26	18.27	11.23	1.29	83112.27
17	7.35	2.84	56.02	0.80	19.02	11.10	1.28	83621.78
18	7.48	2.82	55.97	1.43	17.14	11.59	1.26	81064.46
19	6.46	3.32	53.82	1.49	17.50	11.57	1.29	80902.43
20	6.42	3.09	62.85	1.06	18.71	11.53	1.29	79922.06
21	8.18	3.24	61.56	0.73	19.77	11.02	1.28	83464.14
22	7.93	2.90	54.97	1.28	18.03	11.16	1.27	83557.67
23	8.19	4.52	65.06	1.89	16.65	12.08	1.27	76971.49
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.75	3.50	57.45	1.38	17.76	11.68	1.28	79618.16
最 大 值	10.00	5.34	65.06	2.22	19.77	12.34	1.31	83621.78
發生時間	12	0	23	1	21	5		17
最 小 值	1.50	2.82	52.71	0.73	16.65	11.02	1.23	73872.08
發生時間	5	18	9	21	23	21		5
零點偏移(率)	-0.48 %	-0.01 %	-0.22 %	-0.00 %		-0.12		0.30 %
全幅偏移(率)	0.00 %	-0.36 %	0.01 %	0.02 %		-0.34		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

報表日期: 114年03月04日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.02	4.26	53.67	2.36	16.49	11.52	1.06	77854.60
1	6.60	3.75	57.59	1.73	17.26	11.65	1.09	76272.04
2	9.36	6.09	52.11	1.83	17.03	10.66	1.09	83003.48
3	7.22	4.64	58.48	2.28	14.94	11.34	1.06	80217.99
4	10.05	3.66	55.74	1.97	15.36	11.55	1.06	73375.82
5	8.37	3.71	53.24	1.98	15.86	11.34	1.06	76901.68
6	7.09	2.70	56.01	2.30	14.80	11.42	1.06	77781.38
7	7.35	3.62	58.29	2.27	16.37	11.22	1.08	80297.74
8	7.71	2.32	53.82	1.95	16.65	11.00	1.09	82249.13
9	7.40	2.98	52.33	2.27	16.48	11.03	1.10	82340.13
10	5.96	6.35	52.22	2.78	14.16	11.65	1.10	78147.32
11	1.82	5.60	56.95	2.85	14.15	11.81	1.10	76448.65
12	3.57	7.28	55.25	2.43	16.21	11.17	1.10	81228.04
13	7.86	6.04	50.29	2.20	16.21	10.97	1.10	81509.62
14	7.93	4.90	54.30	2.10	16.17	11.22	1.08	79178.75
15	6.90	7.63	52.60	2.57	16.15	11.12	1.10	79965.07
16	8.04	2.65	63.10	1.78	17.50	10.73	1.09	84479.43
17	8.18	2.18	57.58	1.65	17.75	10.44	1.08	85785.07
18	8.14	1.89	69.20	2.30	15.77	11.04	1.07	82586.27
19	6.98	3.00	59.66	2.31	15.71	11.24	1.06	81184.43
20	9.23	3.59	62.35	1.40	18.38	10.52	1.09	85382.74
21	9.89	2.94	53.93	2.12	16.71	10.75	1.09	84462.12
22	8.75	2.99	57.47	1.57	17.08	11.01	1.07	82130.42
23	7.59	3.36	66.75	1.43	16.82	11.56	1.06	78056.60
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.42	4.09	56.79	2.10	16.25	11.16	1.08	80451.60
最 大 值	10.05	7.63	69.20	2.85	18.38	11.81	1.11	85785.07
發生時間	4	15	18	11	20	11		17
最 小 值	1.82	1.89	50.29	1.40	14.15	10.44	1.05	73375.82
發生時間	11	18	13	20	11	17		4
零點偏移(率)	-0.07 %	-0.00 %	-0.01 %	0.00 %		-0.13		-0.10 %
全幅偏移(率)	-0.06 %	0.07 %	0.77 %	0.37 %		-0.20		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年03月04日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	9.77	4.53	63.35	1.49	16.20	11.70	1.49	73472.56
1	9.12	4.75	57.88	1.04	18.54	10.91	1.52	77712.54
2	10.81	3.78	62.62	1.38	17.16	11.15	1.51	77198.29
3	10.50	4.06	60.72	1.65	17.36	10.90	1.50	79054.75
4	10.59	4.57	61.52	1.77	15.90	11.96	1.50	71292.95
5	10.62	5.21	53.60	1.24	16.75	11.42	1.51	74288.99
6	11.52	3.99	62.77	1.58	16.42	11.35	1.51	75519.11
7	6.43	5.70	51.96	0.62	17.05	10.89	1.52	75717.79
8	12.72	4.93	54.14	0.92	17.01	10.81	1.52	80065.78
9	14.03	9.64	54.71	1.10	18.29	10.57	1.52	77710.58
10	17.79	6.33	49.16	2.14	16.49	10.61	1.54	73520.78
11	15.21	2.38	53.31	2.63	15.12	11.44	1.54	70844.58
12	13.50	3.43	49.18	0.81	17.21	10.58	1.52	74484.56
13	13.35	7.73	52.11	1.67	17.59	10.54	1.53	75100.01
14	13.08	6.62	49.11	2.52	16.04	10.69	1.52	76443.20
15	9.83	5.51	49.36	2.23	15.72	11.09	1.52	74424.86
16	14.02	3.64	54.10	0.70	18.05	10.42	1.54	82886.90
17	10.10	7.22	56.93	0.94	17.56	10.44	1.52	83206.26
18	11.18	3.30	57.69	0.83	17.83	10.51	1.52	81555.13
19	9.59	4.08	59.94	0.67	18.07	10.61	1.52	80114.56
20	12.56	5.87	60.73	0.84	18.26	10.27	1.52	83288.25
21	12.01	9.26	57.75	0.95	18.45	10.14	1.52	83731.81
22	14.17	4.92	51.68	1.40	17.86	10.51	1.52	81426.12
23	9.98	3.26	58.14	0.37	18.21	10.68	1.52	79668.00
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	11.77	5.20	55.94	1.31	17.21	10.84	1.52	77613.68
最 大 值	17.79	9.64	63.35	2.63	18.54	11.96	1.56	83731.81
發生時間	10	9	0	11	1	4		21
最 小 值	6.43	2.38	49.11	0.37	15.12	10.14	1.48	70844.58
發生時間	7	11	14	23	11	21		11
零點偏移(率)	-0.09 %	-0.01 %	-0.05 %	-0.02 %		-0.12		0.20 %
全幅偏移(率)	0.02 %	-0.50 %	0.69 %	0.21 %		-0.37		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								