

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 115年07月15日

報表日期: 115年07月15日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.08	11.16	52.33	2.60	20.17	10.07	1.27	88491.18
1	6.93	11.33	64.76	2.71	19.28	10.82	1.26	83566.50
2	5.66	11.90	55.97	3.42	16.76	11.21	1.29	83235.66
3	9.51	11.40	66.66	2.93	18.35	11.07	1.29	82604.51
4	9.53	11.22	59.22	2.94	19.56	10.74	1.29	83790.69
5	13.67	11.12	45.22	3.36	19.31	10.43	1.29	86445.85
6	7.84	11.54	53.49	2.14	17.84	11.15	1.29	81739.80
7	10.23	12.41	62.92	1.93	18.38	11.87	1.29	75770.65
8	9.29	11.18	49.19	2.18	19.39	10.73	1.28	83922.22
9	8.67	11.39	51.71	2.03	19.25	10.95	1.29	82030.74
10	13.20	11.51	48.36	3.68	18.71	10.92	1.29	77594.30
11	3.67	13.48	58.09	3.32	16.75	11.59	1.29	79820.92
12	9.82	11.18	67.32	0.76	19.97	10.37	1.29	86081.84
13	9.80	10.54	61.38	0.99	19.10	10.16	1.29	88953.68
14	9.47	11.52	41.68	1.06	16.60	11.17	1.29	82874.84
15	8.40	11.24	50.53	0.97	16.80	11.08	1.29	83718.01
16	13.75	11.36	49.39	1.06	16.36	11.24	1.29	82929.13
17	9.30	11.27	49.42	1.09	17.40	10.96	1.29	84103.19
18	10.29	11.27	46.42	1.32	16.07	11.21	1.29	83331.56
19	8.85	11.93	50.38	1.46	16.63	11.36	1.29	81822.31
20	8.19	10.93	52.96	1.07	19.26	10.33	1.29	87720.62
21	10.34	10.94	46.22	1.35	18.86	10.20	1.29	88999.06
22	8.37	11.19	48.66	1.15	17.24	11.04	1.29	84079.80
23	7.97	11.11	51.96	1.11	18.25	10.80	1.29	84975.99
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.28	11.42	53.51	1.94	18.18	10.89	1.29	83691.79
最 大 值	13.75	13.48	67.32	3.68	20.17	11.87	1.31	88999.06
發生時間	16	11	12	10	0	7		21
最 小 值	3.67	10.54	41.68	0.76	16.07	10.07	1.25	75770.65
發生時間	11	13	14	12	18	0		7
零點偏移(率)	-0.08 %	-0.02 %	-0.06 %	0.00 %		-0.04	-0.01	-0.10 %
全幅偏移(率)	0.00 %	0.95 %	-0.06 %	0.00 %		0.10	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 115年07月15日

項目 單位	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
小時\限標	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.48	12.17	52.10	0.28	20.57	10.28	1.00	85973.53
1	0.57	12.24	41.15	0.81	19.64	10.60	1.01	84667.83
2	0.38	12.66	43.46	0.49	18.85	11.06	1.00	81654.39
3	0.35	12.44	45.41	0.89	19.27	10.69	1.00	84152.29
4	1.15	13.92	53.97	1.00	20.52	10.43	1.01	84868.38
5	1.00	12.27	53.26	1.09	19.20	10.42	0.99	86325.11
6	3.49	12.03	59.60	1.07	19.00	10.56	0.99	88188.06
7	2.23	12.34	45.82	0.81	18.86	10.82	0.99	83690.77
8	1.18	12.26	50.47	0.87	18.90	10.77	0.99	84147.77
9	5.72	12.64	58.33	1.07	18.19	11.11	0.99	81441.49
10	1.87	10.33	59.58	1.18	17.85	11.61	1.00	77702.07
11	1.87	10.22	52.91	1.89	16.28	11.63	1.00	78705.17
12	5.16	12.50	53.64	1.19	18.57	10.87	1.00	83054.31
13	6.26	12.80	53.40	1.06	19.74	10.13	1.00	87336.58
14	9.05	12.49	45.60	2.10	16.89	11.14	0.98	82676.48
15	6.07	13.37	49.66	2.30	16.20	11.08	0.99	83712.66
16	5.62	12.43	50.97	1.84	16.89	11.08	1.00	83449.43
17	6.80	11.99	47.24	0.71	18.87	10.49	1.01	86037.60
18	5.84	12.04	44.56	1.44	17.22	10.65	1.00	86593.97
19	3.45	12.06	47.95	1.10	18.98	10.18	0.99	87736.01
20	5.68	13.21	58.89	2.10	16.55	10.75	1.00	85954.32
21	6.91	12.49	51.31	1.93	16.78	11.07	0.99	83450.13
22	5.11	12.08	47.64	1.02	18.48	10.66	1.00	85343.71
23	3.72	12.12	50.03	1.00	18.27	10.73	1.00	84699.17
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	3.75	12.30	50.71	1.22	18.36	10.78	1.00	84231.72
最 大 值	9.05	13.92	59.60	2.30	20.57	11.63	1.03	88188.06
發生時間	14	4	6	15	0	11		6
最 小 值	0.35	10.22	41.15	0.28	16.20	10.13	0.97	77702.07
發生時間	3	11	1	0	15	13		10
零點偏移(率)	-0.08 %	-0.06 %	-0.10 %	-0.02 %		-0.07	-0.01	-0.10 %
全幅偏移(率)	0.14 %	0.14 %	0.14 %	0.14 %		0.09	-0.06	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年07月15日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	7.89	11.72	55.31	2.93	18.78	10.08	1.31	80273.50
1	7.08	11.51	54.32	2.72	20.51	9.71	1.31	81627.11
2	8.52	11.20	57.22	3.16	20.05	9.54	1.31	80699.34
3	5.59	11.34	52.34	2.83	18.20	9.90	1.30	78258.56
4	9.10	11.85	55.79	3.08	20.21	9.67	1.31	80188.06
5	7.01	11.46	57.42	3.05	19.72	9.85	1.31	79457.75
6	8.78	11.70	53.42	3.00	19.44	10.10	1.31	77669.23
7	4.94	11.74	60.44	1.46	18.53	10.29	1.32	77855.51
8	9.30	11.81	61.05	1.53	18.82	10.13	1.29	75285.86
9	6.21	11.90	58.85	1.41	19.18	10.33	1.33	75913.40
10	7.13	12.24	65.09	2.23	19.21	10.67	1.29	73794.34
11	1.99	12.64	53.24	2.85	17.46	10.70	1.27	78650.26
12	2.44	11.84	50.67	0.96	17.83	10.46	1.32	81461.05
13	3.96	12.03	55.63	0.98	17.60	10.66	1.33	80085.54
14	9.39	12.07	55.28	1.02	17.94	10.65	1.31	79884.57
15	6.93	11.94	54.63	1.01	17.48	10.61	1.29	80476.46
16	7.50	12.67	51.17	1.08	16.23	10.81	1.27	79305.72
17	8.35	12.94	56.20	1.10	16.38	11.45	1.31	73259.57
18	9.05	11.81	44.57	1.02	16.82	10.40	1.28	79208.90
19	9.85	11.93	45.44	1.02	16.62	10.52	1.29	78891.48
20	7.92	13.24	41.74	1.42	16.42	10.42	1.31	77705.59
21	8.61	12.25	45.40	1.01	15.90	10.82	1.31	75128.88
22	10.76	12.38	44.14	1.11	16.17	10.49	1.31	75442.75
23	7.03	12.41	45.94	1.00	16.42	10.71	1.30	74434.60
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.31	12.03	53.14	1.79	18.00	10.37	1.30	78123.25
最 大 值	10.76	13.24	65.09	3.16	20.51	11.45	1.35	81627.11
發生時間	22	20	10	2	1	17		1
最 小 值	1.99	11.20	41.74	0.96	15.90	9.54	1.27	73259.57
發生時間	11	2	20	12	21	2		17
零點偏移(率)	-0.08 %	-0.09 %	-0.02 %	-0.01 %		-0.09	-0.01	0.10 %
全幅偏移(率)	0.02 %	0.02 %	-0.42 %	0.02 %		0.02	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								