

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月08日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.45	13.14	70.03	0.42	19.30	11.54	1.10	77784.88
1	7.13	14.13	53.38	0.89	19.24	11.02	1.07	82174.40
2	7.04	14.29	61.04	1.67	16.88	11.74	1.07	78238.77
3	1.66	13.69	54.54	1.35	16.89	11.72	1.07	78061.34
4	2.70	9.62	55.84	1.01	17.65	11.69	1.07	77625.98
5	2.60	10.56	60.75	0.78	18.13	11.31	1.07	86500.68
6	4.78	10.92	57.34	0.78	17.50	12.12	1.08	73718.56
7	4.83	9.93	63.32	0.52	19.73	11.41	1.07	78189.63
8	9.01	11.06	48.99	1.42	16.38	12.06	1.09	75103.92
9	9.61	6.41	57.10	0.90	18.90	11.33	1.10	79436.65
10	5.93	4.74	49.84	1.20	17.02	11.91	1.10	75931.21
11	6.48	4.99	51.88	1.51	16.76	11.74	1.07	76823.92
12	4.92	5.89	48.10	1.64	16.46	11.81	1.07	76444.95
13	8.66	6.65	51.08	1.74	16.51	12.05	1.07	75270.76
14	9.09	6.75	51.31	2.04	16.79	11.85	1.07	76202.84
15	9.49	6.17	53.82	1.36	18.05	11.41	1.08	78589.73
16	4.75	8.78	53.62	1.10	17.51	11.90	1.10	74311.80
17	2.79	8.25	57.76	0.38	18.91	11.52	1.09	78099.16
18	4.86	8.12	59.26	0.77	17.97	11.77	1.09	76660.30
19	7.94	8.97	59.50	1.44	18.54	11.52	1.07	77774.82
20	9.72	15.35	40.55	2.95	15.62	11.91	1.06	74686.91
21	9.71	13.50	45.90	2.71	15.24	11.89	1.07	73163.26
22	9.58	9.03	47.37	2.21	16.59	11.55	1.08	74927.77
23	8.47	12.19	60.90	1.02	18.33	11.49	1.10	75914.24
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.38	9.71	54.72	1.33	17.54	11.68	1.08	77151.52
最大值	9.72	15.35	70.03	2.95	19.73	12.12	1.11	86500.68
發生時間	20	20	0	20	7	6		5
最小值	1.45	4.74	40.55	0.38	15.24	11.02	1.05	73163.26
發生時間	0	10	20	17	21	1		21
零點偏移(率)	-0.04 %	-0.03 %	-0.01 %	0.00 %		-0.05		0.00 %
全幅偏移(率)	0.02 %	0.80 %	-0.42 %	0.59 %		-0.21		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月08日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.62	8.73	47.09	0.46	21.59	9.38	1.10	85299.57
1	2.91	7.19	42.04	1.38	20.43	9.62	1.10	83940.46
2	1.79	6.19	50.18	1.95	17.84	10.10	1.10	82695.76
3	0.75	6.27	49.33	1.68	18.19	10.02	1.10	84614.91
4	3.74	9.58	54.77	1.52	18.18	10.32	1.09	82379.79
5	0.74	8.41	45.11	1.56	18.58	9.81	1.07	86123.18
6	0.58	10.28	57.53	1.05	20.08	9.45	1.10	87880.57
7	8.72	4.54	58.36	1.34	18.71	9.93	1.10	84932.88
8	7.81	3.21	50.69	1.45	18.44	10.13	1.10	82999.95
9	6.12	3.06	52.10	1.79	17.30	10.52	1.10	80067.58
10	6.09	4.10	60.13	1.24	18.07	10.57	1.10	79470.14
11	5.24	5.41	53.19	1.69	18.47	10.14	1.10	83156.00
12	7.54	4.92	50.02	2.58	15.92	10.86	1.11	79963.25
13	10.65	3.33	53.66	2.71	18.05	10.26	1.15	83245.11
14	7.75	3.08	50.09	2.39	16.90	10.65	1.11	81503.19
15	9.74	6.53	47.94	2.10	16.83	10.46	1.13	82821.30
16	9.12	3.97	50.12	1.92	17.04	10.41	1.11	81067.51
17	9.64	2.88	50.63	1.67	17.76	10.12	1.10	83107.05
18	9.86	3.36	54.88	1.42	18.54	10.01	1.11	84448.33
19	8.01	5.32	59.57	1.41	18.39	10.28	1.11	81799.35
20	10.99	5.97	49.05	1.75	18.62	9.92	1.10	85050.02
21	8.78	3.92	56.52	1.87	17.26	10.37	1.10	83684.38
22	9.09	6.43	51.70	1.16	18.83	9.98	1.10	84718.85
23	8.82	8.97	55.03	1.06	19.06	9.88	1.10	85094.97
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.50	5.65	52.07	1.63	18.29	10.13	1.10	83336.00
最大值	10.99	10.28	60.13	2.71	21.59	10.86	1.18	87880.57
發生時間	20	6	10	13	0	12		6
最小值	0.58	2.88	42.04	0.46	15.92	9.38	1.07	79470.14
發生時間	6	17	1	0	12	0		10
零點偏移(率)	-0.02 %	-0.04 %	-0.02 %	-0.01 %		-0.39		0.00 %
全幅偏移(率)	0.02 %	0.07 %	-0.24 %	0.78 %		-0.30		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月08日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.10	10.36	53.63	0.44	17.96	10.96	1.05	81840.73
1	1.09	14.26	52.33	0.70	18.01	10.76	1.07	82797.37
2	1.06	5.28	55.94	0.57	17.16	10.66	1.07	82470.02
3	1.06	11.03	47.29	1.05	15.92	10.83	1.08	80927.22
4	1.41	6.89	54.04	1.47	15.32	11.01	1.10	77931.30
5	1.35	7.68	49.93	0.72	17.25	10.52	1.11	83336.73
6	0.85	9.74	52.80	1.20	15.72	11.01	1.10	79588.36
7	0.50	11.79	50.32	1.45	14.69	11.27	1.11	71597.39
8	3.37	6.21	50.41	1.07	16.68	10.66	1.10	79692.48
9	5.48	6.30	50.78	1.14	15.97	11.10	1.07	77887.02
10	1.07	14.42	52.81	1.15	15.07	11.15	1.09	76254.04
11	5.31	3.75	56.58	1.34	15.20	11.43	1.11	72074.58
12	0.36	4.32	50.32	0.58	16.69	10.67	1.11	76868.74
13	2.68	10.58	50.06	2.60	16.14	10.89	1.10	76326.61
14	12.81	10.62	43.50	7.31	16.55	10.60	1.09	77612.54
15	5.87	6.85	46.42	1.59	16.12	10.67	1.06	75688.44
16	7.44	12.23	50.21	2.28	13.54	11.30	1.07	75739.20
17	11.13	4.29	56.39	1.92	14.59	11.38	1.07	79614.86
18	12.73	4.06	60.96	1.40	16.06	10.95	1.08	81314.82
19	13.55	12.71	52.37	4.02	15.77	11.08	1.11	79961.36
20	9.79	8.56	49.95	2.18	16.33	10.78	1.11	81364.96
21	7.66	5.86	57.58	1.49	16.05	10.98	1.08	80034.55
22	1.23	5.33	52.28	0.68	16.38	11.02	1.07	80060.46
23	0.07	10.01	56.72	1.14	15.18	11.33	1.06	76809.53
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.54	8.46	52.23	1.65	16.01	10.96	1.09	78658.05
最大值	13.55	14.42	60.96	7.31	18.01	11.43	1.13	83336.73
發生時間	19	10	18	14	1	11		5
最小值	0.07	3.75	43.50	0.44	13.54	10.52	1.05	71597.39
發生時間	23	11	14	0	16	5		7
零點偏移(率)	-0.07 %	0.00 %	-0.23 %	-0.07 %		-0.05		0.00 %
全幅偏移(率)	0.00 %	0.06 %	0.24 %	0.45 %		0.12		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								