

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月12日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.83	7.04	64.60	0.69	17.71	12.14	1.10	72612.75
1	0.14	8.26	52.40	0.87	19.97	11.87	1.09	73344.40
2	5.17	6.84	34.04	1.19	19.82	11.01	1.05	80203.60
3	9.25	10.64	45.41	2.05	17.03	11.64	1.05	78064.76
4	8.02	4.98	53.15	1.77	17.07	11.75	1.05	76853.20
5	7.16	5.72	58.76	1.34	18.34	11.63	1.03	76787.66
6	3.20	3.04	62.56	0.63	18.87	12.02	1.04	73237.64
7	2.74	6.08	49.21	0.78	19.33	11.39	1.05	77809.79
8	1.18	14.38	56.87	0.70	19.29	11.63	1.07	75682.17
9	2.48	12.79	45.93	1.07	18.47	11.29	1.04	78158.23
10	6.03	13.88	49.06	0.92	19.36	10.95	1.06	78491.02
11	8.67	10.77	41.77	1.45	18.14	11.16	1.04	78090.24
12	7.27	7.24	55.78	1.27	17.73	11.88	1.05	72714.27
13	4.41	6.72	50.86	0.93	18.45	11.22	1.06	76849.97
14	7.72	10.84	36.98	2.33	16.97	11.16	1.06	76018.96
15	10.36	11.23	23.99	5.09	16.06	11.21	1.03	71226.31
16	10.94	5.94	23.86	3.74	16.91	10.91	1.02	73846.89
17	11.71	4.66	24.08	3.87	17.71	11.05	1.05	77698.40
18	4.60	6.13	57.89	0.94	19.03	11.44	1.06	76587.38
19	6.39	7.47	66.80	0.51	19.01	11.34	1.07	78034.10
20	1.35	9.15	50.89	0.50	20.02	11.29	1.06	78177.25
21	7.88	8.18	55.49	0.57	19.87	10.98	1.04	80508.48
22	8.79	9.86	48.48	0.90	19.10	11.28	1.02	78825.01
23	8.60	10.48	54.60	0.67	20.51	10.83	1.02	81309.61
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.04	8.43	48.48	1.45	18.53	11.38	1.05	76713.84
最大值	11.71	14.38	66.80	5.09	20.51	12.14	1.16	81309.61
發生時間	17	8	19	15	23	0		23
最小值	0.14	3.04	23.86	0.50	16.06	10.83	1.02	71226.31
發生時間	1	6	16	20	15	23		15
零點偏移(率)	-0.01 %	-0.01 %	-0.01 %	-0.06 %		-0.01		0.00 %
全幅偏移(率)	0.02 %	0.65 %	0.14 %	0.30 %		-0.11		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月12日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.05	6.34	58.26	0.88	18.90	11.74	1.01	73247.94
1	0.02	5.45	30.80	1.63	20.53	9.73	0.99	87187.68
2	0.10	3.00	42.59	2.72	18.65	10.09	0.99	86535.66
3	0.11	4.62	43.16	1.92	19.90	10.07	0.99	85533.03
4	0.10	4.50	43.89	2.12	18.77	10.34	0.99	84663.35
5	0.10	3.10	48.81	2.09	19.07	10.48	0.99	82802.60
6	0.09	4.93	41.28	2.49	18.61	10.11	0.99	84320.08
7	0.09	4.18	37.47	2.06	19.89	9.61	1.00	88761.65
8	0.08	4.22	41.56	1.27	20.65	9.84	1.02	86115.94
9	4.42	6.43	47.03	1.29	20.74	9.53	1.02	88606.72
10	5.19	4.42	45.04	1.83	18.90	10.06	1.01	86168.02
11	6.42	4.65	48.30	1.93	18.46	10.00	1.01	87127.81
12	7.97	6.53	48.88	2.59	16.03	10.14	1.02	84472.70
13	9.71	5.43	59.23	2.59	15.25	10.43	1.02	84342.98
14	11.85	9.08	51.55	5.42	14.33	10.47	1.01	82036.14
15	9.62	7.53	55.42	4.23	13.83	10.62	1.02	81304.28
16	9.39	2.25	46.55	3.53	15.32	10.81	1.01	82957.48
17	7.17	3.77	56.39	2.00	18.15	10.46	0.99	84162.08
18	1.36	4.93	50.64	1.30	18.66	10.49	0.99	83366.81
19	1.17	3.99	60.64	0.98	19.83	10.29	0.99	84241.92
20	2.95	5.23	46.58	1.43	19.38	9.79	0.99	88805.44
21	1.95	5.46	65.70	1.23	18.10	10.41	0.99	85246.81
22	0.39	9.66	43.43	1.80	17.79	10.61	0.99	83874.16
23	0.42	4.19	55.38	0.87	18.82	10.62	0.99	82568.42
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.36	5.16	48.69	2.09	18.27	10.28	1.00	84518.74
最大值	11.85	9.66	65.70	5.42	20.74	11.74	1.03	88805.44
發生時間	14	22	21	14	9	0		20
最小值	0.02	2.25	30.80	0.87	13.83	9.53	0.99	73247.94
發生時間	1	16	1	23	15	9		0
零點偏移(率)	-0.01 %	-0.01 %	-0.03 %	-0.02 %		0.00		-0.10 %
全幅偏移(率)	-0.40 %	-0.30 %	-0.18 %	-0.09 %		-0.25		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月12日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.27	5.04	58.54	1.00	16.72	11.09	1.02	72770.89
1	0.19	5.69	47.43	1.09	18.13	11.49	1.02	75439.79
2	2.97	7.15	29.76	1.14	16.68	11.46	0.99	80189.77
3	6.87	9.08	44.19	2.49	13.56	11.75	0.99	76670.00
4	5.74	2.26	52.61	1.91	14.91	11.50	1.00	79213.67
5	3.49	2.37	56.45	1.42	15.47	11.58	1.02	78474.91
6	3.48	2.29	53.58	1.25	15.95	11.19	1.02	83208.04
7	3.07	6.49	55.86	1.05	17.12	11.06	1.02	79286.11
8	3.20	5.30	48.01	1.13	16.83	10.73	1.01	81882.41
9	2.79	6.86	46.38	0.84	16.80	10.80	1.03	80602.40
10	5.58	10.56	43.72	1.82	14.90	10.92	1.03	77269.78
11	11.60	7.96	52.20	1.93	15.20	11.16	1.01	74412.12
12	7.22	7.12	48.03	1.55	15.19	11.24	1.04	75495.12
13	6.20	11.03	44.44	2.16	13.96	11.11	1.03	75427.33
14	6.91	11.78	42.98	3.72	12.88	10.95	1.01	71106.93
15	12.60	8.25	42.81	4.83	12.89	11.09	1.04	73548.57
16	13.65	7.19	37.56	4.26	14.16	10.70	1.03	73394.01
17	8.48	5.69	38.53	1.89	16.41	10.19	0.99	76131.85
18	6.36	5.26	55.45	0.96	17.78	10.11	0.99	78652.86
19	5.31	7.45	45.63	1.53	15.09	10.93	1.03	75634.92
20	6.26	9.56	45.86	1.25	15.74	10.98	1.01	79079.29
21	4.77	5.89	51.29	1.02	16.71	10.64	0.99	79441.65
22	6.23	6.02	55.26	1.60	15.68	10.80	0.99	78668.98
23	4.85	5.81	52.18	1.18	16.43	10.77	0.99	79705.69
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.96	6.75	47.86	1.79	15.63	11.01	1.01	77321.13
最大值	13.65	11.78	58.54	4.83	18.13	11.75	1.05	83208.04
發生時間	16	14	0	15	1	3		6
最小值	0.19	2.26	29.76	0.84	12.88	10.11	0.97	71106.93
發生時間	1	4	2	9	14	18		14
零點偏移(率)	-0.04 %	-0.06 %	-0.02 %	-0.05 %		-0.01		0.00 %
全幅偏移(率)	0.04 %	-0.01 %	-0.59 %	0.00 %		0.33		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								