

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年07月03日

報表日期: 114年07月03日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.61	10.85	64.00	2.65	16.33	12.66	1.29	73369.27
1	5.73	9.26	62.55	2.40	17.21	11.97	1.30	78103.67
2	1.90	9.37	61.57	1.57	16.26	12.03	1.31	76303.31
3	3.49	11.89	53.54	2.51	15.31	11.91	1.31	78698.39
4	5.69	10.01	57.20	2.85	15.48	12.17	1.30	77891.38
5	5.04	8.35	52.41	1.51	15.98	12.10	1.29	75993.05
6	8.39	9.27	56.03	3.25	14.99	12.00	1.34	77709.22
7	7.41	9.37	57.87	3.36	15.92	12.06	1.30	76001.24
8	1.83	10.72	58.59	2.61	15.64	11.79	1.29	77779.33
9	13.65	10.25	47.30	3.99	15.67	11.72	1.29	77383.95
10	10.39	9.68	56.39	3.75	15.71	12.16	1.29	78096.59
11	3.14	9.79	58.93	3.90	14.31	12.01	1.29	77121.31
12	9.31	11.25	47.90	2.51	14.16	12.06	1.29	78278.45
13	7.89	9.68	55.72	1.25	14.94	12.33	1.29	74971.78
14	3.46	9.37	62.98	1.07	14.40	12.41	1.29	73663.22
15	4.80	9.73	63.15	1.14	14.93	12.06	1.29	78334.69
16	9.67	9.14	53.48	1.19	16.07	11.48	1.29	82887.62
17	1.55	8.73	66.08	0.82	16.06	11.75	1.29	80721.11
18	5.25	8.52	52.22	2.24	16.36	11.57	1.29	81754.48
19	3.11	8.85	56.28	1.69	16.32	11.79	1.28	80173.04
20	8.68	8.57	50.56	2.22	16.82	11.02	1.29	86261.73
21	7.60	8.75	57.55	2.56	17.07	11.56	1.29	80838.08
22	4.97	9.33	58.91	1.98	17.88	11.26	1.29	83135.95
23	5.88	8.41	59.95	2.00	17.08	11.85	1.29	78414.74
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.31	9.55	57.13	2.29	15.87	11.90	1.29	78495.23
最 大 值	13.65	11.89	66.08	3.99	17.88	12.66	1.44	86261.73
發生時間	9	3	17	9	22	0		20
最 小 值	1.55	8.35	47.30	0.82	14.16	11.02	1.28	73369.27
發生時間	17	5	9	17	12	20		0
零點偏移(率)	-0.10 %	0.00 %	-0.01 %	-0.00 %		-0.09		0.20 %
全幅偏移(率)	0.69 %	0.26 %	-0.44 %	0.63 %		-0.05		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年07月03日

項目 單位	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
小時\限標	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
0	10.66	8.72	60.96	1.84	16.73	10.87	0.97	78156.34
1	6.75	8.85	58.56	1.69	19.39	10.61	0.97	80452.91
2	9.65	8.73	57.37	2.65	16.65	10.63	0.97	79815.63
3	7.96	10.68	56.91	2.35	16.72	10.66	0.97	79715.42
4	8.45	8.41	63.71	1.85	17.64	10.64	0.97	80787.91
5	8.24	8.45	59.72	2.15	16.75	10.61	0.98	81269.38
6	9.46	8.80	54.40	2.22	16.19	10.78	0.98	77977.68
7	6.68	8.28	56.48	2.07	16.79	10.65	0.97	79676.06
8	4.37	6.15	59.23	2.02	16.72	11.24	0.96	78744.39
9	4.79	7.56	56.43	2.84	16.04	11.35	0.95	79876.09
10	6.11	6.20	58.34	3.14	15.36	11.57	0.94	77690.18
11	5.17	9.93	56.28	3.66	15.17	11.64	0.94	75144.25
12	0.65	11.80	57.71	2.46	15.08	12.03	0.94	73590.80
13	2.55	9.36	54.73	2.21	16.46	11.32	0.94	75690.13
14	6.90	8.72	50.36	2.40	16.28	11.14	0.94	73168.56
15	8.86	9.09	56.68	3.22	15.80	11.17	0.94	76643.16
16	10.68	7.94	54.96	2.73	17.24	10.51	0.95	85660.62
17	10.55	9.59	49.53	2.87	15.62	10.90	0.94	81693.69
18	5.57	8.22	54.12	1.69	18.28	10.14	0.94	82016.97
19	9.96	9.61	55.67	1.84	18.40	9.87	0.94	81355.84
20	7.27	7.70	57.97	1.50	17.57	10.52	0.94	78908.34
21	9.65	7.78	56.56	1.64	18.24	10.13	0.94	82484.33
22	8.15	11.56	65.27	1.43	17.95	10.81	0.96	79441.58
23	4.91	8.28	61.50	1.39	17.18	12.01	0.97	73828.17
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均値	7.25	8.77	57.23	2.24	16.84	10.91	0.95	78907.85
最大値	10.68	11.80	65.27	3.66	19.39	12.03	0.99	85660.62
發生時間	16	12	22	11	1	12		16
最小値	0.65	6.15	49.53	1.39	15.08	9.87	0.94	73168.56
發生時間	12	8	17	23	12	19		14
零點偏移(率)	-0.05 %	-0.07 %	-0.01 %	-0.04 %		-0.08		-0.10 %
全幅偏移(率)	0.13 %	0.91 %	0.06 %	0.08 %		-0.10		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

