

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月12日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.57	1.92	53.24	3.52	16.75	11.38	1.33	70102.20
1	9.17	1.82	59.06	2.91	20.01	10.63	1.33	73164.86
2	9.76	1.75	55.76	3.34	17.23	11.08	1.32	72283.78
3	10.03	1.95	58.38	3.46	16.54	11.45	1.31	71003.70
4	10.83	3.30	42.39	4.43	15.80	10.62	1.30	72245.38
5	10.43	1.74	61.05	3.80	16.40	11.02	1.29	65237.13
6	9.30	1.87	52.68	3.49	16.31	11.51	1.30	69930.53
7	11.03	3.47	44.99	3.76	16.86	10.61	1.29	73259.16
8	5.98	2.17	52.81	3.53	15.23	11.52	1.32	70473.72
9	9.18	2.46	49.88	4.16	14.75	11.69	1.32	68303.86
10	8.54	2.66	56.64	3.27	16.04	11.54	1.33	69648.47
11	6.84	3.22	39.28	3.27	15.45	11.58	1.33	70682.92
12	5.80	2.01	61.88	3.02	16.50	11.54	1.33	69739.76
13	8.95	12.00	44.09	3.56	16.29	10.88	1.32	72200.39
14	6.48	3.63	55.34	2.91	17.74	11.24	1.29	69664.58
15	9.75	5.47	53.47	4.14	17.06	10.93	1.29	73033.75
16	8.29	3.70	47.16	3.25	16.99	11.25	1.32	71569.57
17	7.48	3.38	59.74	2.69	17.73	11.09	1.33	72576.66
18	6.62	4.01	49.53	2.83	17.32	11.42	1.33	70560.92
19	8.05	3.64	60.70	2.64	17.91	10.95	1.33	73440.97
20	7.83	4.26	41.70	2.61	17.98	10.62	1.31	76318.44
21	7.12	3.67	53.36	2.61	17.53	10.95	1.33	73913.61
22	6.73	3.66	42.07	2.60	18.36	10.81	1.33	73204.07
23	8.47	3.80	46.29	2.81	17.62	11.01	1.33	72873.44
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.47	3.40	51.73	3.28	16.93	11.14	1.32	71476.33
最大值	11.03	12.00	61.88	4.43	20.01	11.69	1.34	76318.44
發生時間	7	13	12	4	1	9		20
最小值	5.80	1.74	39.28	2.60	14.75	10.61	1.28	65237.13
發生時間	12	5	11	22	9	7		5
零點偏移(率)	-0.04 %	-0.02 %	-0.01 %	0.00 %		0.05	0.00	0.00 %
全幅偏移(率)	-0.66 %	0.00 %	0.00 %	0.00 %		-0.11	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月12日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.33	1.64	54.48	1.62	19.72	9.57	1.47	84181.23
1	9.78	2.28	47.25	2.36	19.58	9.38	1.47	80048.71
2	5.98	1.66	63.45	1.56	18.86	10.01	1.47	78763.09
3	8.43	1.54	54.44	1.76	18.88	9.70	1.47	84127.41
4	9.52	1.70	64.34	1.90	18.27	9.56	1.48	85003.89
5	9.47	4.17	53.89	2.56	17.01	9.61	1.47	79737.80
6	10.62	2.05	44.72	1.98	19.06	9.40	1.44	76897.76
7	9.22	2.18	52.44	2.14	18.29	9.64	1.44	80669.10
8	9.08	5.57	48.37	3.12	16.01	9.84	1.43	78684.40
9	6.42	3.65	59.80	2.89	17.44	9.65	1.43	79334.42
10	5.05	3.30	49.06	1.45	19.00	9.11	1.44	83561.71
11	3.19	2.15	56.22	1.56	17.37	9.98	1.43	80039.51
12	6.48	3.14	40.06	1.97	17.63	9.61	1.45	79159.66
13	9.11	3.16	56.67	1.52	18.80	9.48	1.46	82620.36
14	9.17	2.43	48.20	2.05	17.02	10.02	1.45	80288.40
15	0.99	1.60	55.69	1.11	17.95	9.83	1.44	80468.41
16	0.25	1.95	45.66	1.03	18.40	9.77	1.45	81626.16
17	0.17	3.29	48.76	0.79	19.47	9.34	1.44	83129.53
18	0.08	1.91	53.74	0.70	19.58	9.53	1.43	83020.41
19	0.08	1.96	38.75	0.89	19.19	9.68	1.43	80738.56
20	0.16	2.15	63.39	0.77	19.61	9.68	1.44	84869.65
21	0.78	1.95	57.92	0.93	19.36	9.45	1.41	86107.30
22	1.50	3.09	47.92	0.98	19.64	9.36	1.39	85592.44
23	2.38	2.72	55.91	1.01	19.60	9.71	1.38	82676.69
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.30	2.55	52.55	1.61	18.57	9.62	1.44	81722.77
最大值	10.62	5.57	64.34	3.12	19.72	10.02	1.49	86107.30
發生時間	6	8	4	8	0	14		21
最小值	0.08	1.54	38.75	0.70	16.01	9.11	1.38	76897.76
發生時間	18	3	19	18	8	10		6
零點偏移(率)	-0.13 %	-0.03 %	-0.01 %	-0.01 %		0.00	0.00	0.00 %
全幅偏移(率)	1.36 %	0.20 %	0.06 %	0.15 %		-0.03	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月12日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.63	3.31	51.85	3.20	15.67	10.49	1.28	80287.09
1	8.48	1.72	66.12	3.41	17.87	10.42	1.26	81233.17
2	11.50	2.29	56.66	4.91	14.52	10.80	1.25	79045.15
3	9.31	1.88	67.60	3.39	16.11	10.57	1.26	81918.44
4	10.16	2.40	51.52	3.87	14.32	10.90	1.25	77971.41
5	9.09	2.73	65.57	3.42	14.88	10.57	1.27	78397.09
6	11.13	4.71	50.87	4.10	14.16	10.89	1.28	79033.25
7	9.09	2.23	53.06	3.01	16.98	10.05	1.28	83002.53
8	10.08	3.61	44.32	4.18	14.21	10.23	1.26	79467.26
9	3.57	7.57	54.27	3.45	12.62	11.13	1.25	71015.54
10	3.90	2.14	62.95	2.14	16.45	10.27	1.29	77439.25
11	5.26	2.40	53.91	2.73	14.70	10.79	1.29	77360.27
12	4.32	1.99	59.06	2.25	15.39	10.82	1.30	76917.34
13	1.51	2.76	53.32	2.37	14.81	10.89	1.29	74881.56
14	1.94	1.76	59.86	2.62	14.55	10.61	1.28	75682.53
15	1.96	1.55	58.70	2.01	16.27	10.65	1.29	78218.84
16	1.88	2.72	55.98	2.08	16.00	10.69	1.30	80365.53
17	1.42	1.86	63.94	1.87	16.48	10.68	1.30	80333.06
18	0.46	2.03	64.49	2.33	15.43	11.60	1.30	73142.07
19	0.38	1.90	63.86	1.81	17.12	11.11	1.29	79097.19
20	0.67	3.85	52.46	1.86	16.87	10.70	1.30	84494.28
21	2.64	4.27	45.14	1.94	17.27	9.94	1.30	89479.59
22	2.99	3.14	47.21	2.15	16.01	10.47	1.29	81826.16
23	4.49	2.85	56.65	2.18	16.36	10.64	1.29	81092.79
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.24	2.82	56.64	2.80	15.63	10.66	1.28	79237.56
最大值	11.50	7.57	67.60	4.91	17.87	11.60	1.33	89479.59
發生時間	2	9	3	2	1	18		21
最小值	0.38	1.55	44.32	1.81	12.62	9.94	1.24	71015.54
發生時間	19	15	8	19	9	21		9
零點偏移(率)	-0.01 %	-0.00 %	-0.01 %	-0.07 %		0.00	0.00	0.00 %
全幅偏移(率)	0.41 %	0.37 %	-0.62 %	0.62 %		0.29	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								