

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月28日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.12	12.64	52.68	2.29	18.14	11.95	1.26	75610.01
1	7.45	12.10	56.97	2.80	19.51	11.36	1.25	79553.86
2	7.41	11.88	55.92	3.65	18.82	10.76	1.25	84951.67
3	7.30	11.96	56.00	2.42	17.48	11.40	1.26	80244.43
4	7.93	11.86	63.69	2.99	19.47	10.84	1.26	84227.04
5	8.37	13.99	47.91	3.89	16.40	11.40	1.29	82873.16
6	8.77	12.72	53.02	3.52	17.87	10.92	1.29	84626.53
7	9.16	13.27	53.43	3.51	15.21	11.89	1.29	78302.55
8	9.04	12.71	45.49	3.25	18.14	10.96	1.29	84484.11
9	8.94	12.64	43.38	2.74	17.03	11.21	1.29	81962.75
10	9.41	12.68	49.98	2.91	17.38	11.20	1.31	79983.75
11	9.22	12.61	48.14	2.99	16.50	11.06	1.34	80982.68
12	9.79	13.40	50.79	2.50	16.94	11.68	1.34	77657.04
13	9.34	12.54	53.67	3.04	16.84	11.12	1.34	82455.82
14	10.03	12.93	59.28	3.49	15.78	11.57	1.34	79056.96
15	9.79	13.17	58.25	2.69	16.79	11.56	1.34	78864.47
16	9.07	12.27	64.01	2.70	18.54	10.66	1.34	85429.01
17	8.47	13.01	41.54	2.52	17.69	11.03	1.34	83387.76
18	8.87	13.07	44.23	1.87	18.32	11.19	1.34	81367.39
19	10.34	12.87	40.68	2.69	17.48	11.22	1.34	81987.80
20	8.36	13.23	53.59	1.42	17.81	11.58	1.34	78813.95
21	8.22	13.09	59.06	1.25	19.04	11.32	1.34	79950.87
22	8.74	13.34	39.83	1.29	19.69	10.90	1.34	82412.23
23	4.45	12.93	48.05	2.41	20.26	10.90	1.34	81594.86
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.61	12.79	51.65	2.70	17.80	11.24	1.31	81282.53
最大值	10.34	13.99	64.01	3.89	20.26	11.95	1.35	85429.01
發生時間	19	5	16	5	23	0		16
最小值	4.45	11.86	39.83	1.25	15.21	10.66	1.25	75610.01
發生時間	23	4	22	21	7	16		0
零點偏移(率)	0.00 %	-0.01 %	-0.02 %	-0.01 %		-0.07	-0.01	0.30 %
全幅偏移(率)	-0.22 %	-0.32 %	1.75 %	1.53 %		-0.16	0.10	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月28日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.33	12.13	48.43	1.22	18.81	10.52	0.98	79295.10
1	9.08	12.37	50.79	2.15	17.70	10.89	0.98	79570.72
2	8.86	11.88	59.55	1.51	18.44	10.38	0.98	79842.56
3	9.64	11.70	55.64	1.64	18.69	10.13	0.97	78613.41
4	9.69	12.87	61.78	2.20	18.93	10.05	0.97	81285.05
5	9.31	11.86	61.99	1.54	17.86	10.50	0.99	78962.45
6	1.88	11.39	44.93	1.13	17.01	10.39	1.00	79369.57
7	7.74	12.24	60.92	1.30	17.14	11.00	1.01	79620.45
8	8.65	11.92	48.83	1.56	16.72	10.77	1.01	80229.83
9	10.71	11.84	41.36	1.33	17.55	10.34	1.00	77357.94
10	13.81	11.38	40.05	2.14	15.96	10.32	1.01	75207.58
11	5.98	11.91	50.78	1.41	16.79	10.27	1.02	73965.82
12	8.25	11.78	58.73	1.88	17.08	10.49	1.02	76720.81
13	12.11	11.79	46.64	1.95	16.87	9.99	1.02	78218.75
14	9.19	11.83	55.36	2.07	15.81	10.37	1.02	74740.41
15	6.28	11.41	53.22	1.82	17.59	10.08	1.02	76038.86
16	9.70	11.20	48.26	1.25	18.62	9.54	1.02	78278.60
17	8.54	11.33	54.56	1.35	17.39	10.06	1.02	78096.91
18	6.08	12.53	55.76	1.98	17.39	10.36	1.02	75657.28
19	7.01	12.65	53.06	2.42	17.50	10.07	1.02	80484.34
20	4.53	11.92	46.58	1.43	18.34	9.74	1.02	77272.52
21	4.70	11.66	48.05	1.84	17.91	9.82	1.02	77416.86
22	9.12	11.37	46.18	1.87	18.26	9.49	1.02	77480.72
23	8.98	12.02	46.68	1.37	20.01	9.27	1.02	77648.13
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.30	11.87	51.59	1.68	17.68	10.20	1.01	77973.94
最大值	13.81	12.87	61.99	2.42	20.01	11.00	1.03	81285.05
發生時間	10	4	5	19	23	7		4
最小值	1.88	11.20	40.05	1.13	15.81	9.27	0.97	73965.82
發生時間	6	16	10	6	14	23		11
零點偏移(率)	-0.08 %	-0.10 %	-0.05 %	-0.01 %		-0.10	-0.01	0.00 %
全幅偏移(率)	0.37 %	1.40 %	-0.01 %	0.22 %		-0.17	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月28日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.98	11.61	58.49	1.87	18.30	10.17	1.41	76041.31
1	8.95	11.75	59.97	2.09	18.67	10.15	1.41	78550.68
2	8.27	11.82	69.46	2.07	18.06	10.42	1.41	76784.02
3	7.59	12.33	56.63	2.01	16.93	10.48	1.40	73209.91
4	8.58	11.87	44.85	2.17	19.40	9.19	1.40	77535.32
5	3.55	11.19	65.88	1.44	17.58	9.76	1.39	72856.89
6	6.05	10.99	45.32	1.73	19.77	9.43	1.41	76169.55
7	6.11	12.23	46.86	2.19	16.08	10.58	1.43	74646.24
8	5.31	11.86	42.83	2.10	17.39	10.20	1.44	75156.29
9	8.56	11.39	42.10	2.18	17.99	9.59	1.44	75810.39
10	6.10	11.07	40.98	1.78	18.02	9.54	1.44	74051.15
11	4.92	11.46	45.99	1.86	15.85	10.19	1.45	70205.99
12	9.70	11.58	45.79	2.48	16.70	9.93	1.43	72735.24
13	7.98	11.19	41.15	2.07	18.02	9.61	1.43	74505.69
14	6.60	11.60	57.09	1.79	16.46	10.30	1.43	71191.98
15	7.38	11.38	65.00	1.88	17.44	9.77	1.43	73344.60
16	9.41	11.35	68.27	2.14	17.80	9.92	1.43	76669.10
17	8.67	12.47	53.54	2.43	15.72	10.60	1.43	72518.35
18	7.40	11.40	51.23	1.78	18.07	9.98	1.43	75833.43
19	4.29	11.54	52.65	1.59	17.41	10.25	1.43	74535.21
20	5.88	11.50	55.94	1.90	16.87	10.36	1.43	76408.16
21	6.64	11.60	58.57	1.86	17.46	10.35	1.43	75428.15
22	9.91	11.30	56.71	2.09	18.47	9.99	1.45	77674.56
23	7.28	11.77	62.03	1.90	18.29	10.23	1.46	77290.88
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.25	11.59	53.64	1.97	17.61	10.04	1.43	74964.71
最大值	9.91	12.47	69.46	2.48	19.77	10.60	1.47	78550.68
發生時間	22	17	2	12	6	17		1
最小值	3.55	10.99	40.98	1.44	15.72	9.19	1.39	70205.99
發生時間	5	6	10	5	17	4		11
零點偏移(率)	-0.04 %	0.01 %	-0.03 %	-0.01 %		-0.32	-0.01	-0.10 %
全幅偏移(率)	0.39 %	0.52 %	0.83 %	1.11 %		-0.04	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								