

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 115年08月01日

報表日期: 115年08月01日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.20	11.55	53.80	3.35	17.17	11.46	1.25	80328.29
1	7.57	11.34	48.94	3.05	17.68	11.11	1.25	82600.17
2	12.48	11.11	54.69	3.56	19.12	10.83	1.25	83951.26
3	7.31	11.56	52.42	2.98	17.72	11.41	1.25	81040.01
4	10.36	11.66	52.87	3.52	16.95	11.57	1.25	80442.96
5	5.04	13.46	44.74	1.88	15.44	11.93	1.26	80512.95
6	13.09	13.86	41.13	2.79	14.77	11.71	1.25	80710.06
7	11.55	14.34	41.56	2.78	14.36	12.11	1.27	77260.46
8	7.27	13.76	44.62	2.34	15.30	12.03	1.27	77758.22
9	9.56	13.52	42.57	2.74	15.11	11.83	1.26	79381.05
10	9.34	12.99	44.98	2.29	15.77	11.59	1.26	80809.93
11	9.98	13.19	45.02	2.79	16.48	11.37	1.27	81634.61
12	12.63	12.53	47.79	3.00	17.90	11.00	1.26	83630.37
13	3.97	12.79	45.38	1.26	17.62	11.28	1.26	81708.22
14	10.14	12.83	42.87	1.56	16.53	11.37	1.25	81977.83
15	8.84	13.22	44.08	1.84	16.32	11.67	1.25	79550.08
16	7.55	13.60	55.59	1.24	17.29	11.84	1.25	77678.01
17	10.27	12.66	44.41	2.15	17.32	11.17	1.25	82713.43
18	8.22	12.48	60.44	2.66	18.82	10.86	1.25	84116.57
19	8.96	13.24	64.37	2.62	20.84	10.24	1.25	86493.79
20	9.18	13.34	46.90	2.47	21.11	9.86	1.25	88930.35
21	6.09	12.64	55.38	1.48	17.89	11.04	1.26	83065.31
22	9.89	11.95	58.71	1.99	19.19	10.34	1.25	87073.35
23	8.57	12.67	61.47	1.52	19.57	10.72	1.25	83991.56
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.17	12.76	49.78	2.41	17.34	11.26	1.25	81973.29
最 大 值	13.09	14.34	64.37	3.56	21.11	12.11	1.28	88930.35
發生時間	6	7	19	2	20	7		20
最 小 值	3.97	11.11	41.13	1.24	14.36	9.86	1.24	77260.46
發生時間	13	2	6	16	7	20		7
零點偏移(率)	0.00 %	0.01 %	-0.01 %	-0.01 %		-0.01	-0.01	0.10 %
全幅偏移(率)	-1.48 %	-0.17 %	0.50 %	-0.10 %		0.14	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 115年08月01日

[illegible]

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年08月01日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.62	11.81	47.40	2.99	19.14	10.20	1.29	81566.51
1	7.90	11.45	34.64	2.85	19.82	9.83	1.30	80176.33
2	3.50	11.68	61.01	2.47	19.98	10.02	1.33	77268.95
3	4.68	11.56	57.38	2.56	18.18	10.16	1.31	76567.37
4	2.31	11.91	62.95	2.33	17.85	10.53	1.31	73994.94
5	2.71	11.97	57.82	2.27	17.26	10.66	1.29	73330.73
6	1.81	11.94	63.43	2.26	17.20	10.65	1.29	74015.77
7	2.79	13.13	53.72	2.70	17.85	10.32	1.31	77701.41
8	2.40	12.41	59.94	2.66	17.41	10.40	1.31	74314.45
9	5.73	11.56	56.18	2.59	18.31	10.02	1.29	75472.06
10	3.31	12.38	56.22	2.55	18.12	9.96	1.32	76394.76
11	2.76	4.60	56.49	2.81	16.66	10.40	1.27	74360.92
12	6.24	11.79	61.15	1.94	16.73	10.40	1.31	75997.19
13	2.58	11.51	59.05	0.43	16.90	10.51	1.30	76771.69
14	5.14	11.27	60.89	0.49	17.55	10.20	1.31	76813.60
15	3.02	11.28	61.64	0.44	17.23	10.26	1.31	75635.64
16	4.60	11.50	59.86	0.48	18.22	10.34	1.29	77080.26
17	5.25	11.48	60.05	1.48	18.27	10.24	1.27	78302.37
18	8.81	11.33	59.07	2.75	18.65	10.01	1.29	79379.18
19	4.29	11.37	60.23	2.50	18.93	10.01	1.31	78019.71
20	8.96	11.09	60.79	2.84	20.60	9.50	1.31	80592.07
21	5.96	11.01	56.65	2.65	19.86	9.50	1.31	81650.90
22	3.64	10.97	50.38	2.28	19.68	9.42	1.27	79919.92
23	8.90	10.64	50.71	2.89	20.35	8.97	1.28	79965.55
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.87	11.32	56.99	2.18	18.36	10.10	1.30	77303.85
最 大 值	9.62	13.13	63.43	2.99	20.60	10.66	1.34	81650.90
發生時間	0	7	6	0	20	5		21
最 小 值	1.81	4.60	34.64	0.43	16.66	8.97	1.27	73330.73
發生時間	6	11	1	13	11	23		5
零點偏移(率)	-0.02 %	0.01 %	-0.01 %	0.00 %		-0.03	-0.01	0.20 %
全幅偏移(率)	0.78 %	-0.46 %	1.30 %	-0.08 %		0.41	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								