

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月07日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.17	2.94	50.74	1.65	17.08	12.14	1.05	73640.12
1	2.77	2.22	55.15	1.88	18.13	11.56	1.05	77910.88
2	5.86	3.99	51.82	2.35	17.92	11.38	1.05	79543.31
3	8.46	5.31	53.61	2.62	16.97	11.65	1.05	78483.23
4	7.33	5.30	51.77	2.78	15.68	11.83	1.05	77711.52
5	7.88	6.15	54.61	2.66	15.78	12.10	1.05	71955.31
6	7.67	5.30	54.61	1.63	18.44	11.30	1.05	79824.09
7	5.99	5.65	56.86	1.34	18.45	11.68	1.05	76963.70
8	2.65	6.23	61.85	0.99	18.94	12.06	1.04	73528.82
9	1.56	8.61	59.32	0.90	19.84	11.22	1.05	79142.57
10	5.24	11.77	49.48	2.28	16.79	10.77	1.06	78617.82
11	4.14	7.54	52.81	2.06	16.42	11.80	1.05	75412.75
12	5.36	7.71	60.14	1.52	17.28	11.77	1.05	75836.13
13	3.94	9.41	48.43	2.56	15.05	11.91	1.03	73107.39
14	2.05	7.37	65.93	1.49	17.56	11.75	1.02	76799.65
15	3.93	8.93	51.67	2.29	15.88	11.91	1.02	77052.26
16	6.65	10.64	61.38	1.57	18.53	11.27	1.03	79240.71
17	9.01	7.18	48.39	1.88	17.48	11.42	1.05	78062.70
18	6.54	8.81	58.86	1.58	17.11	11.71	1.05	77184.78
19	3.55	9.73	63.97	1.04	17.96	11.23	1.05	80728.83
20	4.04	10.75	61.31	1.55	17.28	11.59	1.05	78308.45
21	4.33	9.85	51.62	1.69	16.93	11.62	1.05	78585.45
22	3.50	9.96	64.81	1.22	17.93	12.10	1.06	73147.74
23	1.42	12.17	55.04	1.21	17.96	12.03	1.06	73835.90
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.88	7.65	56.01	1.78	17.39	11.66	1.05	76859.34
最大值	9.01	12.17	65.93	2.78	19.84	12.14	1.07	80728.83
發生時間	17	23	14	4	9	0		19
最小值	1.42	2.22	48.39	0.90	15.05	10.77	1.02	71955.31
發生時間	23	1	17	9	13	10		5
零點偏移(率)	-0.02 %	0.00 %	-0.15 %	-0.01 %		0.00		0.00 %
全幅偏移(率)	0.04 %	0.74 %	-0.21 %	0.28 %		0.10		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月07日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.17	3.33	51.84	1.32	17.63	10.19	0.96	86073.40
1	0.38	4.19	48.94	1.45	18.29	10.20	0.97	86005.68
2	0.42	7.09	46.74	1.81	18.07	10.56	0.97	83313.54
3	2.48	3.60	56.40	1.48	18.97	9.22	0.97	89631.32
4	7.51	1.95	55.51	1.97	17.47	9.85	0.99	84116.71
5	1.76	4.17	55.65	0.92	17.89	9.89	0.99	85075.35
6	0.33	10.44	63.39	1.13	20.44	10.04	0.99	84673.58
7	1.15	6.70	41.61	1.22	19.96	9.44	0.99	88650.27
8	4.34	8.58	51.21	1.49	19.07	10.14	0.99	85283.92
9	9.23	2.49	48.10	1.77	18.85	9.94	0.99	87689.25
10	10.34	2.69	45.22	1.90	18.66	9.76	0.99	88801.63
11	14.35	3.59	58.25	2.51	16.44	10.68	1.00	84365.46
12	7.88	2.73	61.33	1.73	17.15	10.58	0.99	84279.79
13	9.10	3.79	58.04	1.39	18.18	10.40	0.99	84610.03
14	8.82	3.88	56.76	1.60	18.18	10.32	0.99	85509.41
15	9.90	3.14	44.75	1.63	18.51	10.13	0.99	87013.69
16	8.31	3.11	49.37	1.73	17.62	10.53	0.99	84399.87
17	8.54	6.27	53.67	1.79	18.32	10.43	0.99	84979.06
18	6.26	6.27	57.37	1.44	18.15	10.68	0.99	82348.66
19	3.16	8.77	61.66	1.28	17.99	10.94	1.00	81357.59
20	5.41	9.91	52.52	1.36	18.58	10.35	0.99	85094.14
21	3.42	6.06	60.09	0.89	19.12	10.49	0.99	83273.84
22	4.90	8.05	55.44	1.11	19.03	10.73	0.99	81280.13
23	0.90	9.58	58.19	0.95	18.23	11.78	0.99	73824.19
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.38	5.43	53.84	1.49	18.37	10.30	0.99	84652.10
最大值	14.35	10.44	63.39	2.51	20.44	11.78	1.05	89631.32
發生時間	11	6	6	11	6	23		3
最小值	0.17	1.95	41.61	0.89	16.44	9.22	0.94	73824.19
發生時間	0	4	7	21	11	3		23
零點偏移(率)	-0.07 %	-0.05 %	-0.01 %	0.00 %		0.00		-0.10 %
全幅偏移(率)	0.04 %	-0.57 %	-0.57 %	-0.03 %		-0.20		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月07日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.92	4.21	53.19	2.33	14.47	11.01	0.99	73032.08
1	1.58	1.86	54.95	1.37	16.97	10.81	0.99	76898.61
2	4.06	5.17	69.11	1.84	17.46	10.43	0.99	80943.28
3	6.88	9.67	60.31	2.18	16.47	10.13	0.98	78504.55
4	5.96	5.41	51.49	1.84	16.85	9.60	0.97	82346.87
5	6.62	13.99	47.06	1.76	16.83	9.63	0.98	78128.76
6	4.31	5.98	57.25	1.76	16.33	9.87	0.99	74988.87
7	1.31	10.36	60.03	1.29	16.73	10.24	0.99	76947.76
8	2.11	8.18	60.76	1.61	15.82	10.36	0.99	77085.68
9	4.60	3.55	66.98	1.68	16.23	10.53	1.00	79197.50
10	5.94	3.44	64.13	1.73	16.48	10.46	1.02	78135.58
11	7.27	3.65	62.91	2.01	15.78	10.60	1.02	78752.67
12	7.75	7.74	49.19	2.42	14.30	11.10	1.00	75297.68
13	8.12	4.10	51.50	1.69	16.03	10.59	0.99	77455.28
14	5.55	3.57	55.89	1.61	15.43	11.21	0.99	73465.90
15	6.16	3.37	56.51	1.59	16.20	10.85	0.99	78831.34
16	6.97	3.57	54.49	1.54	15.87	11.07	1.00	79556.60
17	6.79	7.83	54.69	1.76	15.96	10.81	1.01	79196.11
18	7.62	6.31	58.71	1.79	15.78	10.83	1.00	81405.88
19	4.19	6.03	56.50	1.29	16.05	11.11	0.99	77446.49
20	3.74	10.71	50.48	1.33	15.95	11.25	1.00	78876.00
21	2.61	6.30	53.73	1.83	15.16	11.07	0.99	77865.59
22	1.87	9.38	64.51	1.32	16.76	10.86	1.02	79567.10
23	4.03	9.76	48.38	1.28	16.80	10.64	1.02	82139.35
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.04	6.42	56.78	1.70	16.11	10.63	1.00	78169.40
最大值	8.12	13.99	69.11	2.42	17.46	11.25	1.04	82346.87
發生時間	13	5	2	12	2	20		4
最小值	1.31	1.86	47.06	1.28	14.30	9.60	0.97	73032.08
發生時間	7	1	5	23	12	4		0
零點偏移(率)	-0.01 %	-0.01 %	-0.05 %	-0.06 %		0.00		0.00 %
全幅偏移(率)	0.04 %	-0.77 %	-0.37 %	0.00 %		0.19		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								