

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月18日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.10	11.43	57.19	2.75	17.57	11.16	1.25	82026.26
1	9.72	11.66	59.29	3.03	17.61	11.34	1.25	80700.35
2	10.85	11.51	55.88	2.79	16.82	11.18	1.25	83476.64
3	10.69	11.76	58.77	2.26	16.23	11.48	1.25	81431.24
4	9.54	11.68	57.22	1.95	16.16	11.54	1.25	80743.49
5	11.37	11.37	54.21	2.43	16.67	11.21	1.25	79840.57
6	10.64	11.29	56.85	3.09	17.21	11.11	1.25	83470.67
7	10.11	11.53	58.61	2.56	16.92	11.36	1.25	81320.59
8	10.18	12.74	58.04	3.06	16.60	11.49	1.26	80683.52
9	7.38	12.99	60.65	2.21	17.90	11.18	1.25	82059.55
10	11.44	12.77	61.63	1.94	17.76	11.16	1.25	82154.26
11	8.70	13.16	55.68	2.21	16.16	11.63	1.25	79759.97
12	7.56	13.68	63.32	1.89	16.32	11.97	1.25	76675.86
13	9.84	12.85	47.53	1.48	18.00	11.19	1.25	81723.11
14	6.71	13.23	54.62	1.30	17.78	11.35	1.25	80543.69
15	8.10	13.29	51.04	1.82	15.53	11.78	1.24	79257.46
16	6.98	13.10	53.03	2.09	15.33	11.71	1.25	79990.84
17	7.35	12.87	53.19	1.93	16.05	11.50	1.25	80744.19
18	11.22	12.94	58.66	1.78	17.69	11.36	1.25	80745.34
19	8.15	12.37	61.41	2.31	19.54	10.64	1.25	84619.04
20	11.98	12.19	58.86	3.31	18.08	10.64	1.25	86001.30
21	6.75	12.55	62.27	1.50	17.78	11.03	1.26	82921.96
22	11.36	12.83	57.08	1.77	17.41	11.08	1.26	82463.71
23	6.95	12.85	60.87	1.16	19.15	11.09	1.25	81505.91
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.32	12.44	57.33	2.19	17.18	11.30	1.25	81452.48
最大值	11.98	13.68	63.32	3.31	19.54	11.97	1.27	86001.30
發生時間	20	12	12	20	19	12		20
最小值	6.71	11.29	47.53	1.16	15.33	10.64	1.23	76675.86
發生時間	14	6	13	23	16	19		12
零點偏移(率)	-0.01 %	-0.02 %	-0.03 %	-0.00 %		0.00	-0.01	0.10 %
全幅偏移(率)	-0.95 %	-0.80 %	-0.19 %	-0.36 %		0.09	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月18日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	14.04	12.11	50.89	1.16	19.07	10.45	0.94	85573.93
1	5.59	12.37	48.39	1.90	17.97	10.94	0.94	83229.61
2	11.82	12.39	50.93	2.27	17.33	11.07	0.94	82524.85
3	12.15	12.23	45.31	1.52	18.29	10.79	0.94	84155.26
4	7.69	12.35	45.32	1.74	17.26	11.03	0.94	83113.94
5	9.43	12.08	48.21	2.05	18.13	10.73	0.94	84448.88
6	5.39	12.26	38.58	1.02	17.86	10.89	0.94	86379.57
7	11.53	12.10	42.70	1.74	18.54	10.59	0.94	85167.52
8	6.17	12.04	48.60	1.10	19.18	10.54	0.95	84209.87
9	8.87	12.40	51.29	1.38	18.50	10.94	0.97	82508.27
10	8.40	12.75	44.36	1.72	16.69	11.15	0.96	82028.88
11	10.19	14.13	56.09	1.27	17.57	12.15	0.95	73377.71
12	8.81	14.37	53.81	1.79	18.82	11.12	0.94	80315.09
13	6.41	12.56	52.86	0.86	17.79	11.12	0.94	81123.09
14	1.85	12.70	47.48	1.00	17.48	11.21	0.94	80738.86
15	9.80	12.58	59.81	0.86	17.73	11.15	0.94	80712.16
16	10.16	12.22	48.06	1.77	16.98	10.93	0.94	83301.46
17	3.18	12.56	53.73	1.30	17.53	11.04	0.94	81990.40
18	8.03	12.45	54.63	0.39	19.87	10.82	0.94	81467.71
19	6.50	12.10	44.28	0.67	19.97	10.44	0.94	84434.77
20	10.06	12.30	40.88	0.59	20.63	10.18	0.94	86499.35
21	13.50	11.75	57.63	0.57	20.58	9.86	0.94	90137.24
22	13.92	12.47	47.88	1.34	20.03	10.72	0.94	83078.56
23	4.89	12.68	56.81	0.22	21.76	10.72	0.94	81561.24
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.68	12.50	49.52	1.26	18.57	10.86	0.94	83003.26
最大值	14.04	14.37	59.81	2.27	21.76	12.15	0.97	90137.24
發生時間	0	12	15	2	23	11		21
最小值	1.85	11.75	38.58	0.22	16.69	9.86	0.94	73377.71
發生時間	14	21	6	23	10	21		11
零點偏移(率)	-0.11 %	-0.00 %	-0.07 %	-0.00 %		0.00	-0.01	-0.20 %
全幅偏移(率)	-0.27 %	-2.87 %	1.17 %	0.20 %		0.16	0.00	-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月18日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.50	10.74	56.19	1.76	19.72	9.13	1.31	77078.44
1	9.40	10.90	57.61	1.89	20.28	9.31	1.31	75926.46
2	8.79	10.71	48.72	2.06	18.13	9.19	1.31	73518.54
3	8.63	10.56	48.98	2.33	17.70	9.20	1.27	72559.58
4	8.35	10.50	46.06	2.46	17.17	9.18	1.27	72500.03
5	10.87	10.50	42.12	2.64	17.02	8.86	1.27	74140.75
6	8.40	11.78	40.43	3.09	18.19	8.89	1.27	73976.94
7	5.23	10.83	45.35	1.54	18.00	9.17	1.32	74546.51
8	5.54	10.89	51.14	2.72	19.07	9.05	1.29	74987.95
9	9.67	10.95	52.21	3.38	18.28	9.18	1.31	73528.61
10	6.58	11.37	50.80	2.99	18.85	9.10	1.29	74242.37
11	10.96	11.39	53.26	3.09	19.39	9.07	1.32	74506.39
12	4.14	11.41	52.44	2.72	19.07	9.31	1.31	73420.63
13	3.26	11.28	55.45	2.69	19.35	9.17	1.31	73987.31
14	3.06	11.24	55.67	2.72	19.41	8.91	1.31	75527.89
15	3.79	11.48	52.72	2.63	18.22	9.27	1.27	73578.89
16	2.97	11.81	47.01	2.48	18.39	8.92	1.27	73900.91
17	4.25	10.75	50.10	2.67	17.59	9.18	1.30	73337.15
18	9.66	10.85	48.78	3.47	18.19	8.81	1.30	73973.95
19	6.85	11.14	44.74	2.72	18.55	8.99	1.27	72679.59
20	4.33	11.89	39.63	2.61	21.27	8.37	1.28	75870.72
21	4.70	10.66	54.65	2.87	19.92	8.97	1.30	77659.01
22	3.62	11.06	58.44	2.76	18.34	9.75	1.31	71765.00
23	3.64	12.52	54.68	2.68	18.89	9.12	1.31	76355.67
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.38	11.13	50.30	2.62	18.71	9.09	1.29	74315.39
最大值	10.96	12.52	58.44	3.47	21.27	9.75	1.34	77659.01
發生時間	11	23	22	18	20	22		21
最小值	2.97	10.50	39.63	1.54	17.02	8.37	1.23	71765.00
發生時間	16	4	20	7	5	20		22
零點偏移(率)	-0.07 %	-0.07 %	-0.04 %	0.00 %		-0.02	-0.01	-0.10 %
全幅偏移(率)	-2.25 %	-0.07 %	0.77 %	-0.03 %		0.32	0.04	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								