

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月06日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.15	2.45	56.89	3.40	14.93	12.13	1.44	71168.01
1	8.66	2.71	62.33	3.16	15.42	12.20	1.41	70578.12
2	11.44	5.28	58.16	4.04	14.99	12.11	1.38	71697.24
3	11.16	2.69	54.06	4.40	13.72	12.48	1.38	69612.37
4	9.54	4.22	56.30	4.58	13.35	12.59	1.38	69212.11
5	9.99	4.11	69.47	3.91	14.28	12.74	1.40	66490.12
6	10.19	2.24	59.48	3.81	14.02	12.15	1.41	71339.21
7	10.40	5.82	38.45	4.64	13.05	12.63	1.42	67765.90
8	10.06	1.43	65.37	3.76	14.22	12.63	1.43	67678.35
9	10.90	1.24	59.16	4.26	13.66	12.50	1.45	67692.74
10	10.63	2.52	47.65	4.65	12.72	12.81	1.46	67327.99
11	6.63	1.54	70.10	3.61	13.90	12.94	1.46	66043.19
12	6.48	1.31	63.92	3.40	13.88	12.66	1.47	68460.80
13	9.82	7.08	49.03	4.06	13.38	12.74	1.43	67424.75
14	7.42	1.85	58.46	3.89	13.62	12.80	1.41	66534.77
15	6.79	1.40	61.98	3.53	14.13	12.72	1.42	66785.68
16	4.95	0.98	63.82	2.51	15.48	12.20	1.46	70059.79
17	2.18	1.01	65.89	2.24	15.84	12.20	1.47	70255.59
18	4.18	1.08	56.00	2.38	15.69	12.02	1.47	71076.67
19	6.35	2.12	62.92	2.94	14.41	12.32	1.46	70020.74
20	10.56	2.77	57.48	3.53	14.00	12.48	1.45	69072.79
21	6.13	1.30	63.95	2.93	14.80	12.51	1.42	68179.54
22	6.94	1.03	59.75	2.29	16.15	11.95	1.41	71644.23
23	7.75	1.79	58.00	2.41	15.86	12.15	1.41	70193.63
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.30	2.50	59.11	3.51	14.40	12.44	1.43	69013.10
最大值	11.44	7.08	70.10	4.65	16.15	12.94	1.49	71697.24
發生時間	2	13	11	10	22	11		2
最小值	2.18	0.98	38.45	2.24	12.72	11.95	1.37	66043.19
發生時間	17	16	7	17	10	22		11
零點偏移(率)	-0.04 %	0.00 %	-0.14 %	-0.00 %		-0.03	0.00	0.00 %
全幅偏移(率)	2.11 %	0.28 %	-0.13 %	0.10 %		0.09	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月06日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.71	2.03	55.78	1.91	17.11	10.49	1.43	64399.61
1	9.40	0.41	62.52	1.22	19.85	10.10	1.45	65024.68
2	10.46	1.40	60.47	1.94	17.93	10.40	1.44	65585.41
3	10.87	3.45	58.24	1.96	17.08	10.40	1.43	64852.28
4	10.65	9.91	56.01	2.26	16.79	10.59	1.45	63953.24
5	10.21	8.13	56.13	2.24	16.04	10.55	1.45	61646.73
6	15.82	1.20	68.52	2.60	16.68	10.46	1.45	68925.85
7	9.97	1.24	56.59	1.90	16.96	10.29	1.45	63025.50
8	10.06	1.02	53.83	1.70	17.27	10.41	1.45	63883.04
9	9.55	0.60	66.98	1.66	17.21	10.38	1.44	64140.41
10	10.49	0.79	57.41	1.95	16.39	10.79	1.41	62368.56
11	6.77	0.65	63.19	1.28	17.97	10.60	1.38	61885.95
12	9.76	1.05	57.81	1.68	16.81	10.53	1.38	63344.84
13	9.86	1.07	58.18	1.52	17.16	10.68	1.39	62702.48
14	8.27	1.42	58.83	1.67	17.37	10.64	1.41	61882.73
15	8.92	1.13	64.05	1.82	16.55	10.85	1.43	61487.71
16	8.75	0.87	58.45	1.59	17.43	10.67	1.43	62810.94
17	1.38	2.52	74.22	0.77	19.51	10.27	1.41	60609.24
18	4.38	4.73	39.57	0.92	19.95	9.05	1.38	65080.30
19	8.66	6.10	46.84	1.43	17.46	10.13	1.41	62754.10
20	10.31	1.01	47.47	1.43	18.23	9.84	1.43	62691.99
21	10.05	1.42	49.56	1.27	18.81	9.77	1.41	62749.65
22	6.51	1.76	70.97	0.83	19.35	10.31	1.40	62820.62
23	0.93	3.26	65.87	1.21	18.23	11.41	1.42	58713.62
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.82	2.38	58.65	1.62	17.67	10.40	1.42	63222.48
最大值	15.82	9.91	74.22	2.60	19.95	11.41	1.50	68925.85
發生時間	6	4	17	6	18	23		6
最小值	0.93	0.41	39.57	0.77	16.04	9.05	1.38	58713.62
發生時間	23	1	18	17	5	18		23
零點偏移(率)	-0.10 %	-0.06 %	-0.03 %	-0.01 %		-0.10	0.00	0.00 %
全幅偏移(率)	1.42 %	0.48 %	-0.13 %	0.23 %		0.03	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月06日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.50	10.03	53.51	4.24	16.41	10.66	1.76	84362.57
1	11.08	7.54	58.11	2.41	16.71	10.47	1.78	86099.10
2	10.07	2.74	56.87	2.16	16.20	10.80	1.80	83059.18
3	10.60	4.98	57.22	3.14	16.24	10.63	1.80	83368.87
4	10.26	10.06	51.44	3.24	14.96	11.08	1.80	82680.59
5	12.21	6.21	54.80	3.17	15.33	10.85	1.80	84397.87
6	12.72	1.62	63.05	2.64	15.12	11.03	1.80	83117.07
7	9.70	1.74	58.83	1.67	17.04	10.62	1.80	81952.13
8	10.79	2.81	55.73	2.21	15.53	10.90	1.80	82773.30
9	11.20	3.64	61.60	2.48	14.68	10.99	1.78	81816.37
10	7.83	7.88	71.27	2.16	15.01	11.47	1.78	75850.02
11	5.09	10.71	47.57	1.38	15.85	11.31	1.80	76214.68
12	5.82	16.17	50.80	1.71	15.75	11.69	1.80	69984.29
13	8.80	16.71	43.74	1.68	16.28	11.32	1.80	72342.26
14	9.25	16.48	46.97	1.74	16.76	11.28	1.80	72144.66
15	9.73	14.47	39.95	1.93	16.32	11.29	1.80	71581.34
16	6.22	10.16	46.34	1.43	16.79	11.24	1.81	74437.65
17	2.73	13.73	40.59	1.08	17.18	11.04	1.83	74150.48
18	1.61	9.69	62.63	1.22	17.81	10.99	1.83	77623.33
19	1.79	2.98	51.88	1.11	17.65	10.56	1.81	88296.77
20	3.43	1.79	61.55	1.32	17.62	10.53	1.80	86184.89
21	5.66	1.32	67.77	1.34	17.94	10.95	1.80	84295.19
22	0.77	2.02	66.58	1.44	16.89	12.27	1.82	76141.34
23	1.17	7.34	54.32	1.13	18.83	10.55	1.80	88578.79
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.46	7.62	55.13	2.00	16.45	11.02	1.80	80060.53
最大值	12.72	16.71	71.27	4.24	18.83	12.27	1.87	88578.79
發生時間	6	13	10	0	23	22		23
最小值	0.77	1.32	39.95	1.08	14.68	10.47	1.75	69984.29
發生時間	22	21	15	17	9	1		12
零點偏移(率)	-0.04 %	0.00 %	-0.07 %	-0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	0.20 %	0.32 %	-0.20 %	0.14 %		0.05	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								