

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年11月01日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.17	11.91	51.14	1.73	17.18	11.30	1.25	73936.48
1	12.49	12.94	57.90	1.89	18.24	11.32	1.25	73567.20
2	11.62	11.82	69.65	1.98	17.31	11.20	1.25	75280.23
3	12.48	11.91	47.98	2.37	15.85	11.49	1.25	74448.60
4	11.07	12.51	69.32	2.06	16.26	11.97	1.25	69927.80
5	12.55	11.98	52.56	2.72	16.74	11.41	1.19	73655.65
6	10.90	12.61	64.98	1.82	16.49	12.00	1.18	69448.90
7	12.76	12.13	45.24	1.76	16.55	11.64	1.18	72467.14
8	12.13	11.80	55.57	2.24	16.25	11.35	1.18	74676.38
9	12.49	12.31	70.33	2.25	15.94	11.85	1.18	72037.57
10	13.20	11.97	62.30	2.02	17.13	11.41	1.18	74207.31
11	11.58	14.25	54.07	2.93	14.83	11.59	1.19	73650.03
12	10.25	11.55	66.48	2.37	14.62	12.39	1.18	68639.31
13	12.52	10.86	62.69	1.89	16.14	11.73	1.18	71933.96
14	12.07	10.95	58.12	1.99	16.69	11.73	1.18	71855.10
15	12.93	10.75	45.82	1.94	16.76	11.49	1.18	73827.74
16	13.55	13.80	51.10	3.47	15.68	11.74	1.18	72336.56
17	12.19	13.00	43.74	2.81	16.53	11.41	1.18	73744.53
18	12.21	12.34	48.18	2.47	16.49	11.32	1.18	75681.61
19	11.63	12.92	61.20	1.91	17.49	11.35	1.18	74711.11
20	12.45	13.89	49.00	2.45	17.62	10.98	1.18	77490.80
21	11.69	11.99	53.38	2.63	16.59	11.46	1.18	74235.43
22	12.60	12.41	58.80	2.44	17.42	11.22	1.18	76321.58
23	11.40	12.10	55.94	3.03	15.39	11.56	1.18	75166.53
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	12.08	12.28	56.48	2.30	16.51	11.54	1.20	73468.65
最 大 值	13.55	14.25	70.33	3.47	18.24	12.39	1.25	77490.80
發生時間	16	11	9	16	1	12		20
最 小 值	10.25	10.75	43.74	1.73	14.62	10.98	1.17	68639.31
發生時間	12	15	17	0	12	20		12
零點偏移(率)	-0.01 %	0.00 %	-0.00 %	-0.00 %		0.00	-0.01	0.20 %
全幅偏移(率)	0.38 %	0.56 %	0.00 %	0.02 %		-0.08	0.04	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年11月01日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.26	11.38	60.01	3.42	19.13	9.59	1.44	85447.00
1	12.98	11.42	54.75	3.47	19.32	9.57	1.44	85094.46
2	9.68	11.77	57.42	3.24	18.22	9.76	1.43	82707.63
3	13.04	11.05	50.19	3.70	18.67	9.24	1.43	84492.71
4	13.10	14.53	56.25	3.78	18.89	9.24	1.43	83832.03
5	10.55	11.26	65.48	3.10	20.23	8.97	1.43	85621.24
6	13.07	11.13	54.02	3.29	18.33	9.64	1.43	82845.61
7	9.01	13.83	61.23	3.08	17.65	9.42	1.43	87662.19
8	10.23	15.08	68.70	3.45	16.39	10.63	1.44	77380.03
9	14.76	14.14	47.06	3.34	18.41	10.01	1.44	79279.33
10	15.92	14.69	40.88	3.48	18.48	9.40	1.43	81615.14
11	11.36	14.86	39.85	3.46	15.20	9.76	1.43	75316.58
12	10.03	12.24	54.01	3.10	16.60	9.69	1.42	75462.71
13	13.15	13.02	51.88	3.67	16.97	9.68	1.43	78601.17
14	11.37	12.66	50.99	3.28	17.94	9.67	1.43	77666.38
15	15.08	13.29	49.63	3.88	19.02	8.98	1.44	82580.32
16	10.68	12.58	67.19	2.19	18.36	10.66	1.45	74008.75
17	12.92	12.50	46.00	2.33	20.56	9.04	1.45	79912.42
18	11.12	12.56	45.21	2.13	18.99	8.48	1.44	79543.54
19	11.33	11.15	54.07	2.07	18.37	8.83	1.44	78679.30
20	12.83	13.53	50.58	2.53	18.96	8.50	1.43	80576.31
21	12.38	12.29	58.39	2.27	18.57	9.32	1.46	85383.41
22	12.41	12.75	47.79	2.17	18.29	9.21	1.45	82483.81
23	11.66	12.13	52.11	3.04	18.72	9.15	1.43	83697.15
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	12.12	12.74	53.49	3.06	18.34	9.44	1.44	81245.38
最 大 值	15.92	15.08	68.70	3.88	20.56	10.66	1.47	87662.19
發生時間	10	8	8	15	17	16		7
最 小 值	9.01	11.05	39.85	2.07	15.20	8.48	1.41	74008.75
發生時間	7	3	11	19	11	18		16
零點偏移(率)	-0.07 %	-0.04 %	-0.01 %	-0.00 %		-0.03	-0.01	0.00 %
全幅偏移(率)	-0.87 %	-0.63 %	0.05 %	0.00 %		0.24	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								