

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月16日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.35	6.81	47.55	3.66	13.02	12.56	1.38	70730.38
1	10.82	6.12	52.31	3.69	13.04	12.63	1.38	70148.82
2	8.59	5.65	50.73	4.15	11.99	12.75	1.38	70304.52
3	7.63	3.02	58.13	3.38	13.40	12.55	1.38	71309.79
4	5.25	6.89	63.69	3.04	13.91	12.73	1.39	68516.71
5	8.65	4.32	54.59	2.74	14.58	12.33	1.43	73650.21
6	8.34	4.24	48.07	3.65	13.19	12.64	1.43	70390.76
7	9.88	7.88	57.19	3.45	13.72	12.58	1.43	70666.35
8	10.80	7.77	54.24	3.62	13.43	12.51	1.46	71248.00
9	8.14	2.52	53.35	3.61	13.42	12.67	1.49	70175.06
10	3.21	2.81	56.75	3.32	12.95	12.60	1.46	70517.68
11	6.45	6.21	48.10	3.83	12.83	12.68	1.43	69870.51
12	7.26	2.69	68.07	3.20	14.14	12.62	1.46	69209.91
13	6.95	2.51	50.80	3.03	13.69	12.45	1.49	70824.15
14	4.51	6.04	43.47	3.57	12.72	12.53	1.49	70545.15
15	9.24	7.47	55.88	4.57	12.16	12.99	1.49	66769.00
16	9.27	4.15	55.83	4.16	12.67	12.77	1.49	68964.36
17	7.08	3.10	52.06	3.71	12.99	12.75	1.49	68904.26
18	6.10	2.53	59.83	3.27	13.63	12.57	1.46	70055.90
19	8.07	4.18	53.84	3.93	12.65	12.80	1.43	68678.88
20	9.66	3.41	60.01	3.62	13.37	12.70	1.42	69046.63
21	8.68	5.70	53.21	3.21	13.76	12.42	1.43	71438.85
22	9.04	6.69	51.17	3.62	13.01	12.64	1.44	69983.56
23	8.77	7.09	56.87	3.57	13.23	12.63	1.46	69241.81
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.03	4.99	54.41	3.57	13.23	12.63	1.44	70049.64
最大值	10.82	7.88	68.07	4.57	14.58	12.99	1.50	73650.21
發生時間	1	7	12	15	5	15		5
最小值	3.21	2.51	43.47	2.74	11.99	12.33	1.37	66769.00
發生時間	10	13	14	5	2	5		15
零點偏移(率)	-0.02 %	-0.02 %	-0.02 %	-0.00 %		0.01	0.00	0.00 %
全幅偏移(率)	-1.41 %	0.03 %	-0.15 %	0.03 %		0.35	-0.03	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月16日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.95	10.70	57.65	2.10	15.90	10.33	1.41	81883.51
1	10.58	6.69	44.48	2.46	17.67	9.51	1.42	82854.09
2	9.63	1.35	51.88	2.28	15.60	9.80	1.42	80664.50
3	11.21	2.20	48.22	2.44	15.54	9.87	1.41	77468.65
4	9.62	3.55	41.20	2.41	15.22	9.79	1.41	81429.28
5	10.82	5.20	47.38	2.21	15.05	10.10	1.42	82356.22
6	11.86	4.95	55.93	1.99	16.84	9.60	1.42	79109.47
7	9.97	7.02	37.31	2.19	15.51	9.74	1.42	79676.87
8	9.02	4.06	44.27	1.97	15.70	10.21	1.45	80881.29
9	9.68	5.09	58.66	2.59	14.86	11.12	1.42	84469.69
10	7.80	6.24	51.77	2.54	15.07	11.17	1.37	82057.60
11	9.39	4.51	44.13	2.41	15.24	10.81	1.36	87727.72
12	9.07	4.73	42.37	2.28	15.87	10.79	1.38	87294.87
13	8.13	2.72	48.61	2.38	15.80	11.02	1.38	85454.36
14	6.64	2.63	56.07	2.19	15.55	11.18	1.38	85271.37
15	7.35	5.09	51.44	2.21	16.00	11.06	1.39	84971.85
16	7.69	1.42	58.02	2.26	16.18	11.32	1.39	84064.00
17	6.12	1.38	51.62	1.98	16.43	10.75	1.40	86398.40
18	9.77	1.98	61.75	1.74	17.56	10.30	1.38	88650.63
19	10.55	3.04	58.37	1.92	16.85	10.44	1.38	85575.93
20	10.36	4.54	62.19	2.33	15.53	10.98	1.38	82739.98
21	10.42	4.46	54.09	2.26	15.32	10.87	1.38	83894.82
22	9.65	3.25	63.87	1.73	16.59	10.65	1.39	84652.21
23	6.02	4.73	55.00	1.28	18.23	10.36	1.42	83862.10
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.22	4.23	51.93	2.17	16.00	10.49	1.40	83475.39
最大值	11.86	10.70	63.87	2.59	18.23	11.32	1.46	88650.63
發生時間	6	0	22	9	23	16		18
最小值	6.02	1.35	37.31	1.28	14.86	9.51	1.35	77468.65
發生時間	23	2	7	23	9	1		3
零點偏移(率)	-0.11 %	-0.00 %	-0.12 %	0.00 %		-0.01	0.00	0.00 %
全幅偏移(率)	1.24 %	0.28 %	-0.42 %	0.09 %		0.41	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月16日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.94	7.11	56.15	1.90	14.85	11.09	1.73	84503.06
1	9.21	7.12	48.15	3.31	15.28	10.62	1.72	83532.01
2	9.15	1.37	61.25	1.96	14.94	10.71	1.72	81601.11
3	7.03	1.53	48.69	1.59	14.80	10.83	1.72	79987.37
4	5.88	2.13	65.77	2.09	14.20	11.40	1.72	76687.74
5	11.62	3.25	59.06	2.39	14.15	11.44	1.72	83036.56
6	6.15	4.15	63.10	1.81	14.44	11.96	1.72	77366.74
7	10.55	5.97	62.04	2.07	14.92	11.13	1.72	77706.23
8	9.11	3.00	55.87	1.75	15.60	11.02	1.74	83047.03
9	7.30	3.07	58.66	1.59	15.49	10.95	1.75	83685.76
10	10.14	3.19	57.19	1.89	14.66	11.01	1.72	82573.16
11	6.20	2.99	62.72	1.60	15.72	11.07	1.75	81964.39
12	4.95	2.90	62.41	1.28	16.48	10.83	1.76	84627.20
13	8.91	3.14	58.38	1.84	15.00	11.03	1.76	84097.05
14	11.32	3.19	65.05	2.48	14.70	11.22	1.75	82300.89
15	6.11	5.33	59.67	2.16	14.13	11.33	1.72	82438.38
16	5.11	3.06	66.70	1.70	15.36	11.22	1.73	82757.53
17	3.93	3.00	70.32	1.52	15.64	11.49	1.76	80646.63
18	6.44	3.05	65.06	1.54	16.08	10.93	1.78	85195.04
19	7.95	4.68	61.94	1.92	14.90	11.22	1.75	83203.07
20	10.22	4.58	59.01	2.21	14.26	11.23	1.75	82102.27
21	8.98	3.71	61.05	1.87	15.00	11.04	1.75	83660.40
22	6.46	3.57	58.83	1.70	14.91	11.20	1.77	82675.25
23	6.03	6.51	60.88	1.38	16.24	10.75	1.78	82545.82
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.86	3.82	60.33	1.90	15.07	11.11	1.74	82164.20
最大值	11.62	7.12	70.32	3.31	16.48	11.96	1.80	85195.04
發生時間	5	1	17	1	12	6		18
最小值	3.93	1.37	48.15	1.28	14.13	10.62	1.70	76687.74
發生時間	17	2	1	12	15	1		4
零點偏移(率)	-0.12 %	-0.01 %	-0.02 %	0.00 %		0.04	0.00	0.00 %
全幅偏移(率)	1.50 %	0.19 %	-0.64 %	0.09 %		0.42	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								