

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年06月17日

報表日期: 113年06月17日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.09	5.06	52.31	1.39	19.28	10.97	0.94	84725.44
1	6.14	5.66	61.06	1.29	18.31	11.99	0.96	76368.49
2	8.63	5.24	48.76	0.97	20.25	10.71	0.97	85467.98
3	7.01	5.58	50.75	0.79	20.80	10.44	0.97	87353.78
4	10.57	5.36	49.93	0.95	20.81	10.09	0.96	90020.21
5	9.52	12.08	55.08	0.67	22.14	無效	0.93	86006.09
6	10.41	2.97	42.08	0.60	20.27	10.24	0.92	88098.41
7	9.33	1.60	40.78	0.63	20.17	10.71	0.93	85528.63
8	10.37	2.81	36.52	0.51	20.99	10.29	0.92	88454.30
9	8.83	1.69	52.16	0.72	19.70	11.32	0.95	81229.33
10	14.38	3.73	43.64	0.86	19.13	10.86	0.97	85371.20
11	6.80	6.38	51.85	2.02	16.37	11.81	0.96	79678.51
12	8.01	6.08	59.62	3.79	15.78	11.74	0.93	81115.97
13	4.73	8.31	59.80	4.13	14.61	12.16	0.96	76989.62
14	7.95	5.11	69.53	2.40	17.44	11.65	0.97	80518.51
15	8.22	5.64	60.85	2.39	16.59	11.86	0.97	78736.80
16	8.17	4.94	64.26	2.27	16.52	11.55	0.97	81000.36
17	8.01	4.75	64.75	1.96	18.03	11.39	0.95	81970.58
18	10.78	5.84	50.27	2.70	17.72	10.70	0.94	88402.21
19	12.27	2.51	50.36	3.71	17.12	11.05	0.96	86308.31
20	15.59	6.99	48.24	1.94	16.23	11.40	0.97	84414.80
21	9.93	4.94	54.11	1.90	17.50	11.06	0.97	85731.67
22	9.43	5.20	47.95	1.78	16.80	11.26	0.97	84391.13
23	9.91	4.89	61.72	1.72	17.33	11.35	0.97	83099.83
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	23	24	24
平 均 值	9.34	5.14	53.18	1.75	18.33	11.16	0.95	83790.92
最 大 值	15.59	12.08	69.53	4.13	22.14	12.16	0.97	90020.21
發生時間	20	5	14	13	5	13		4
最 小 值	4.73	1.60	36.52	0.51	14.61	10.09	0.90	76368.49
發生時間	13	7	8	8	13	4		1
零點偏移(率)	-0.09 %	-0.06 %	-0.08 %	-0.00 %		-0.07		0.00 %
全幅偏移(率)	-0.05 %	-0.08 %	0.01 %	-6.35 %		-0.01		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	95.83 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年06月17日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	3.56	3.45	59.75	0.61	20.39	10.00	0.94	82441.92
1	3.54	8.23	42.83	1.37	22.11	9.21	0.93	85903.34
2	10.93	2.84	50.90	1.43	17.50	9.78	0.92	81689.37
3	3.05	1.63	60.94	0.76	18.09	11.51	0.94	72654.87
4	9.01	5.33	36.82	1.61	19.78	8.68	0.92	90582.53
5	8.58	3.20	51.18	4.75	16.58	10.43	0.91	77556.32
6	8.72	1.25	50.69	1.55	16.88	10.64	0.90	75645.65
7	18.02	6.28	41.59	1.78	19.25	9.58	0.92	76169.45
8	8.14	2.37	52.58	1.02	19.29	10.02	0.94	81431.60
9	13.36	1.75	60.31	0.99	19.31	10.82	0.99	79002.32
10	9.25	3.57	34.45	1.77	18.93	10.75	0.95	82044.78
11	8.66	2.54	43.44	1.40	16.99	11.12	0.96	81191.58
12	4.70	1.60	44.42	0.75	17.22	10.63	0.96	77863.01
13	1.12	1.99	35.96	0.66	16.30	10.70	0.93	72734.65
14	1.28	1.68	40.58	0.60	17.08	10.52	0.95	73854.19
15	13.37	7.56	38.38	2.58	17.00	10.39	0.94	72774.61
16	8.17	1.33	37.24	1.43	18.92	9.99	0.93	77408.18
17	7.29	2.60	36.30	1.58	19.32	9.38	0.94	80860.02
18	10.04	5.73	40.97	1.00	18.95	9.90	0.98	80814.17
19	10.54	5.46	39.91	0.89	19.45	9.53	0.99	83235.76
20	10.65	3.73	51.51	1.72	17.91	10.42	0.99	77246.37
21	6.08	3.14	55.29	1.21	19.73	9.90	0.99	84023.77
22	7.96	1.72	54.27	1.13	17.87	10.57	0.99	80812.31
23	11.65	2.97	63.26	1.04	18.24	10.66	0.97	79034.37
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.24	3.41	46.82	1.40	18.46	10.21	0.95	79457.30
最 大 值	18.02	8.23	63.26	4.75	22.11	11.51	0.99	90582.53
發生時間	7	1	23	5	1	3		4
最 小 值	1.12	1.25	34.45	0.60	16.30	8.68	0.88	72654.87
發生時間	13	6	10	14	13	4		3
零點偏移(率)	-0.11 %	-0.01 %	-0.19 %	-0.06 %		-0.11		0.30 %
全幅偏移(率)	0.02 %	0.18 %	0.42 %	0.14 %		0.28		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								