

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月06日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.47	12.31	35.87	1.79	16.51	11.15	1.25	83118.41
1	9.19	13.35	43.18	1.61	17.54	11.79	1.25	76917.35
2	9.39	12.82	36.47	2.61	15.58	11.64	1.22	80055.38
3	8.68	13.44	45.21	2.03	15.46	12.13	1.21	76596.65
4	10.73	12.55	37.82	2.26	15.62	11.32	1.24	83117.66
5	6.89	12.87	47.71	2.01	16.56	11.45	1.29	81978.28
6	11.91	13.48	46.37	2.58	15.54	11.72	1.29	79520.22
7	10.07	12.62	51.99	1.34	17.54	10.76	1.27	85622.56
8	10.08	12.87	43.38	1.40	15.10	11.47	1.28	81559.60
9	9.28	12.90	40.30	1.19	16.17	11.50	1.29	80742.92
10	10.04	12.93	37.58	1.29	15.40	11.69	1.29	79401.66
11	9.38	13.16	36.33	1.58	14.86	11.89	1.29	78618.93
12	9.33	13.94	40.47	1.28	15.95	11.68	1.29	79289.09
13	12.93	12.75	51.54	1.89	14.62	11.51	1.29	82025.49
14	9.21	13.78	50.86	1.22	15.43	12.25	1.29	74757.81
15	9.49	12.63	54.56	0.93	16.48	11.32	1.29	82049.83
16	9.27	12.57	48.49	0.83	16.38	11.14	1.29	83520.39
17	9.23	12.66	51.92	1.15	14.56	11.54	1.29	81728.55
18	10.70	13.27	40.44	1.21	15.19	11.73	1.28	79706.07
19	9.70	13.15	49.91	1.03	15.75	11.65	1.29	79615.64
20	16.54	12.19	42.86	2.04	16.50	10.77	1.28	86237.48
21	8.90	13.10	64.34	2.44	15.36	11.75	1.27	78999.66
22	10.83	12.98	43.15	2.79	14.41	11.73	1.25	81225.46
23	9.51	13.33	51.71	1.53	15.82	11.88	1.25	78059.28
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.07	12.99	45.52	1.67	15.76	11.56	1.27	80602.68
最大值	16.54	13.94	64.34	2.79	17.54	12.25	1.30	86237.48
發生時間	20	12	21	22	1	14		20
最小值	6.89	12.19	35.87	0.83	14.41	10.76	1.20	74757.81
發生時間	5	20	0	16	22	7		14
零點偏移(率)	-0.03 %	-0.02 %	-0.03 %	0.00 %		-0.28	-0.01	0.20 %
全幅偏移(率)	-2.09 %	-0.04 %	0.65 %	0.22 %		0.02	0.10	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月06日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.58	11.69	47.04	3.25	16.34	10.59	1.02	76131.45
1	10.66	11.87	49.84	3.04	18.55	10.49	1.02	77211.80
2	10.37	11.83	48.88	3.15	16.96	10.65	1.02	77986.00
3	10.42	12.42	55.53	3.62	16.69	10.85	1.01	80209.75
4	10.85	12.70	61.37	3.69	15.80	11.52	1.02	80506.82
5	10.84	12.80	56.95	3.76	15.53	11.61	1.02	79069.18
6	1.19	11.71	51.68	2.12	16.12	11.11	1.04	79831.14
7	4.00	12.34	56.20	2.17	16.05	11.14	1.04	78260.74
8	8.00	11.85	45.49	1.93	16.02	10.81	1.04	77596.32
9	8.01	11.86	48.58	1.62	16.43	10.80	1.06	78241.97
10	7.55	12.24	56.00	4.05	16.86	10.23	1.05	78308.34
11	7.36	12.30	56.95	1.84	14.70	10.84	1.03	74850.55
12	7.20	11.32	33.70	1.43	16.13	10.24	1.02	76481.76
13	7.39	12.02	43.15	2.32	14.55	10.92	1.04	75653.64
14	7.73	12.33	45.12	1.90	15.33	11.15	1.04	75433.43
15	7.82	12.10	45.82	2.00	15.14	10.99	1.04	74889.42
16	8.18	11.68	49.91	2.01	16.51	10.61	1.05	78110.70
17	7.94	11.78	44.54	2.42	15.71	10.78	1.04	76847.13
18	8.47	11.78	44.74	1.37	16.39	10.59	1.03	76280.53
19	10.49	12.05	49.14	2.38	14.85	10.74	1.03	77705.26
20	8.24	12.42	57.51	2.45	15.89	11.12	1.03	77305.17
21	2.75	12.60	60.70	2.36	15.85	11.14	1.03	80677.51
22	2.33	12.25	53.72	1.80	15.69	11.16	1.03	77121.44
23	1.29	12.30	55.37	1.95	15.33	11.28	1.03	75913.04
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.49	12.09	50.75	2.44	15.98	10.89	1.03	77525.96
最大值	10.85	12.80	61.37	4.05	18.55	11.61	1.06	80677.51
發生時間	4	5	4	10	1	5		21
最小值	1.19	11.32	33.70	1.37	14.55	10.23	1.00	74850.55
發生時間	6	12	12	18	13	10		11
零點偏移(率)	-0.05 %	-0.02 %	-0.03 %	-0.01 %		-0.10	-0.01	0.00 %
全幅偏移(率)	0.60 %	0.82 %	0.29 %	-0.32 %		-0.22	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月06日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.65	11.20	49.86	1.97	16.19	10.18	1.43	72000.13
1	9.61	11.54	55.72	2.09	17.22	10.39	1.43	70550.24
2	9.65	11.07	49.32	2.41	16.70	10.01	1.43	71354.20
3	9.63	11.16	52.00	2.31	16.65	10.08	1.43	71323.44
4	9.51	11.16	51.82	2.37	16.53	10.01	1.43	72178.57
5	9.51	11.26	56.14	2.44	16.32	10.22	1.43	73652.69
6	9.46	11.46	58.33	2.23	16.31	10.45	1.43	73713.71
7	5.80	11.38	49.57	1.81	16.80	10.29	1.45	75426.60
8	9.80	11.01	49.78	2.02	17.41	9.83	1.43	73357.33
9	9.30	11.02	48.56	2.09	16.90	9.79	1.45	73279.68
10	8.56	11.89	42.30	2.65	17.24	9.55	1.45	72559.69
11	10.05	11.57	38.72	2.19	17.43	9.31	1.43	72248.23
12	8.81	10.85	38.63	1.87	17.25	9.33	1.43	71182.77
13	10.68	11.24	40.72	2.91	18.09	9.05	1.43	74478.40
14	9.74	12.61	29.94	1.79	17.52	8.67	1.43	71254.81
15	16.44	5.51	35.90	1.66	16.59	9.07	1.43	71979.11
16	10.30	13.06	31.56	1.59	18.70	8.47	1.43	74386.17
17	10.27	11.03	31.63	0.76	16.56	9.33	1.43	73821.97
18	8.86	10.83	45.65	0.82	16.61	9.55	1.43	73713.05
19	10.33	11.17	51.18	0.99	15.57	9.81	1.43	71826.41
20	8.99	11.03	52.51	1.27	16.65	9.54	1.43	73501.02
21	8.83	11.15	57.65	1.83	15.96	9.89	1.44	73462.14
22	10.22	10.91	45.66	1.88	17.33	9.58	1.45	74931.82
23	9.13	11.00	46.93	1.78	17.52	9.72	1.44	74629.03
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.67	11.09	46.25	1.91	16.92	9.67	1.43	72950.47
最大值	16.44	13.06	58.33	2.91	18.70	10.45	1.48	75426.60
發生時間	15	16	6	13	16	6		7
最小值	5.80	5.51	29.94	0.76	15.57	8.47	1.42	70550.24
發生時間	7	15	14	17	19	16		1
零點偏移(率)	-0.14 %	-0.01 %	-0.03 %	-0.01 %		-0.08	-0.01	0.00 %
全幅偏移(率)	1.80 %	-0.73 %	0.41 %	0.18 %		0.00	0.04	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								