

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月04日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.79	8.40	54.98	3.61	13.24	12.57	1.40	69594.86
1	11.83	5.76	56.49	3.25	14.28	12.38	1.39	70060.94
2	9.66	5.61	53.81	3.68	13.61	12.54	1.40	69350.86
3	10.21	6.65	59.28	3.86	13.33	12.51	1.38	70044.76
4	9.65	4.70	66.63	3.14	14.70	12.18	1.35	71626.55
5	1.83	8.53	46.29	2.76	14.48	12.33	1.33	73605.74
6	9.06	6.84	44.60	3.68	13.52	12.48	1.35	69766.62
7	7.59	11.31	48.82	4.23	12.26	12.83	1.37	67852.26
8	8.18	6.72	56.63	4.04	12.42	12.74	1.39	68259.76
9	4.94	3.53	61.29	2.96	13.91	12.35	1.40	70778.46
10	6.33	7.40	48.28	4.65	12.51	12.73	1.40	68722.00
11	10.32	12.55	37.45	8.63	11.72	12.73	1.35	68727.83
12	5.55	2.91	58.92	3.89	13.08	12.68	1.35	68519.85
13	8.86	4.37	61.24	3.51	13.62	12.55	1.39	68925.81
14	6.15	1.85	44.63	3.19	13.75	12.24	1.41	71436.28
15	8.54	3.62	53.53	3.96	12.70	12.86	1.41	67512.63
16	6.32	2.00	57.23	3.46	13.05	12.61	1.40	69319.16
17	13.83	1.82	59.34	3.39	13.79	12.38	1.38	70830.22
18	7.29	1.80	61.91	3.20	13.56	12.60	1.34	69025.00
19	6.72	1.55	51.21	2.60	14.44	12.09	1.36	72504.09
20	6.40	2.16	52.97	3.25	13.36	12.42	1.39	70419.00
21	4.53	1.52	57.00	2.60	14.31	12.21	1.40	71220.55
22	4.57	1.62	55.33	2.89	14.03	12.44	1.38	70021.58
23	3.29	1.65	62.18	2.94	14.04	12.72	1.37	67977.02
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.56	4.79	54.59	3.64	13.49	12.51	1.38	69837.58
最大值	13.83	12.55	66.63	8.63	14.70	12.86	1.42	73605.74
發生時間	17	11	4	11	4	15		5
最小值	1.83	1.52	37.45	2.60	11.72	12.09	1.33	67512.63
發生時間	5	21	11	19	11	19		15
零點偏移(率)	0.00 %	0.00 %	-0.03 %	0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	0.12 %	0.06 %	-0.22 %	0.05 %		0.35	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月04日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.24	1.25	53.77	1.87	17.10	10.38	1.38	82242.37
1	9.44	1.39	57.03	1.87	18.45	10.58	1.38	83191.44
2	10.43	2.45	57.77	2.62	17.07	10.59	1.38	85828.68
3	10.14	4.51	51.72	2.06	18.31	10.19	1.38	86506.90
4	9.88	3.85	49.83	2.17	17.43	10.48	1.38	85074.47
5	10.83	5.25	51.45	2.48	15.85	10.81	1.38	83519.40
6	10.46	5.90	56.48	2.18	16.30	10.61	1.38	88568.92
7	10.31	3.77	46.61	2.27	15.80	10.74	1.38	81294.11
8	9.26	3.36	50.16	2.24	16.31	10.56	1.38	82444.49
9	9.82	4.20	46.75	2.43	16.99	10.21	1.37	82560.61
10	10.88	7.05	42.49	6.69	15.38	10.25	1.34	81075.78
11	9.47	2.67	50.00	3.61	16.70	10.41	1.33	80201.47
12	11.22	2.10	52.46	2.35	16.86	10.41	1.35	82125.35
13	9.61	2.85	51.45	2.73	15.12	10.53	1.38	79853.16
14	8.20	3.78	51.50	2.49	14.78	10.63	1.37	79783.55
15	7.09	2.83	56.32	2.11	16.02	10.88	1.36	81894.23
16	8.42	2.47	45.82	1.84	17.51	10.08	1.37	83003.36
17	5.57	2.73	46.46	1.89	16.50	10.24	1.36	80509.04
18	2.20	2.12	55.61	1.28	18.18	10.23	1.34	82459.47
19	4.18	4.56	42.72	1.67	18.07	9.85	1.33	86276.49
20	7.92	5.08	52.52	2.06	17.39	10.35	1.33	84309.88
21	10.02	2.37	47.38	1.97	18.06	9.86	1.36	87235.08
22	6.49	2.07	47.57	1.67	17.43	10.22	1.38	81365.98
23	8.03	3.74	53.25	1.37	18.94	10.14	1.38	85556.49
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.71	3.43	50.71	2.33	16.94	10.38	1.37	83203.36
最大值	11.22	7.05	57.77	6.69	18.94	10.88	1.38	88568.92
發生時間	12	10	2	10	23	15		6
最小值	2.20	1.25	42.49	1.28	14.78	9.85	1.32	79783.55
發生時間	18	0	10	18	14	19		14
零點偏移(率)	-0.02 %	0.00 %	-0.02 %	0.00 %		-0.02	0.00	0.00 %
全幅偏移(率)	0.16 %	0.20 %	-0.87 %	0.00 %		0.31	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月04日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.99	2.44	56.45	1.48	15.45	11.12	1.78	82574.02
1	6.92	2.09	56.45	1.52	16.28	10.79	1.77	81742.29
2	6.56	2.86	60.85	2.18	14.91	11.31	1.77	75522.12
3	9.63	3.80	54.43	2.36	15.05	11.15	1.80	80840.23
4	11.69	6.57	56.02	2.41	16.65	10.69	1.80	84500.14
5	9.78	5.71	53.19	2.21	15.34	10.82	1.80	83245.32
6	13.58	9.77	58.57	3.04	14.15	11.22	1.80	81831.63
7	8.01	5.03	53.92	2.04	15.51	10.75	1.77	85242.36
8	5.52	3.46	62.25	1.65	15.45	11.00	1.76	82269.93
9	4.96	7.77	50.90	2.14	14.35	11.22	1.75	78432.02
10	9.31	4.35	60.97	6.90	14.89	11.43	1.76	80330.11
11	9.03	4.64	54.64	3.79	14.96	11.27	1.74	81634.55
12	9.09	4.64	62.03	2.69	13.85	11.55	1.76	78651.97
13	12.08	10.77	57.67	3.23	12.68	11.68	1.75	79553.44
14	8.12	12.97	54.20	4.09	12.02	11.55	1.75	76852.72
15	7.93	6.01	59.70	2.96	13.30	11.40	1.74	76949.42
16	7.37	2.69	55.30	1.78	15.53	11.02	1.75	81940.70
17	5.51	1.90	52.86	1.67	15.17	10.87	1.74	82445.50
18	3.74	1.11	58.43	1.38	15.92	10.93	1.74	83930.97
19	2.67	2.05	56.57	1.02	16.97	10.49	1.73	86654.42
20	7.39	4.27	58.79	1.68	15.41	10.93	1.77	85351.42
21	6.27	3.90	58.60	1.47	16.15	10.77	1.77	86155.67
22	6.60	4.75	57.95	1.38	16.20	10.83	1.77	83776.86
23	3.55	3.63	58.42	1.04	16.96	10.64	1.75	84177.35
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.60	4.88	57.05	2.34	15.13	11.06	1.76	81858.55
最大值	13.58	12.97	62.25	6.90	16.97	11.68	1.80	86654.42
發生時間	6	14	8	10	19	13		19
最小值	2.67	1.11	50.90	1.02	12.02	10.49	1.71	75522.12
發生時間	19	18	9	19	14	19		2
零點偏移(率)	-0.18 %	0.00 %	-0.00 %	-0.01 %		0.03	0.00	0.00 %
全幅偏移(率)	0.43 %	0.26 %	-0.28 %	0.13 %		0.29	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								