

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 115年01月09日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.22	13.24	56.78	1.36	16.20	12.18	1.39	77405.23
1	8.71	12.24	56.31	1.37	16.97	11.52	1.39	82466.83
2	8.97	11.95	57.95	2.26	14.62	11.75	1.39	82531.79
3	9.72	12.84	60.47	2.11	14.16	12.47	1.38	76758.22
4	9.26	12.26	50.13	1.95	14.47	12.05	1.37	80057.91
5	6.46	13.90	53.57	2.34	14.37	11.96	1.34	79703.50
6	6.82	13.03	57.89	2.12	14.34	12.56	1.34	75885.60
7	6.37	12.43	51.02	1.58	15.27	12.01	1.34	79451.28
8	6.89	13.30	54.04	2.59	13.91	12.74	1.36	74149.32
9	6.83	13.46	55.67	1.92	14.55	12.82	1.35	73278.79
10	6.07	12.02	50.84	1.72	14.93	11.83	1.33	81397.29
11	6.19	12.08	48.51	2.33	14.62	11.91	1.36	80906.65
12	6.45	12.67	59.86	1.77	14.68	12.35	1.35	76771.92
13	6.39	12.46	58.34	2.44	13.91	12.22	1.33	78372.50
14	6.32	12.12	62.41	1.97	15.44	11.75	1.34	81262.14
15	7.21	12.13	52.72	2.42	14.92	11.71	1.34	82281.96
16	9.07	12.16	56.04	3.17	14.22	11.95	1.33	80193.57
17	7.39	12.03	52.83	2.99	14.19	11.93	1.35	80173.10
18	3.04	12.71	53.02	2.45	14.84	11.73	1.37	81874.89
19	2.67	12.05	49.14	1.82	15.14	11.77	1.35	81087.74
20	2.84	12.30	48.78	2.31	14.24	11.99	1.34	80376.10
21	4.58	13.12	55.23	2.59	14.57	12.05	1.34	79672.01
22	5.87	12.28	51.30	2.81	14.37	11.82	1.33	81888.70
23	5.25	13.19	56.20	2.62	14.30	11.92	1.31	80885.52
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.61	12.58	54.54	2.21	14.72	12.04	1.35	79534.69
最 大 值	9.72	13.90	62.41	3.17	16.97	12.82	1.40	82531.79
發生時間	3	5	14	16	1	9		2
最 小 值	2.67	11.95	48.51	1.36	13.91	11.52	1.30	73278.79
發生時間	19	2	11	0	8	1		9
零點偏移(率)	-0.12 %	-0.02 %	-0.01 %	-0.01 %		-0.08	-0.01	0.40 %
全幅偏移(率)	1.33 %	0.57 %	-0.91 %	-1.14 %		0.15	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

報表日期: 115年01月09日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.14	11.90	45.26	1.03	18.75	10.16	1.10	81752.56
1	7.32	12.12	52.86	1.83	16.99	10.69	1.10	81701.89
2	7.17	12.19	52.38	1.81	15.89	10.91	1.10	80048.61
3	8.30	12.32	48.45	2.09	15.51	11.03	1.10	79314.85
4	7.88	12.01	56.23	2.00	15.49	10.79	1.09	79127.39
5	9.02	11.85	59.54	1.25	17.46	10.46	1.09	81538.31
6	8.17	12.05	43.17	1.48	17.27	10.40	1.07	80143.92
7	6.82	12.46	55.25	1.56	16.94	10.72	1.07	79126.45
8	5.70	13.31	60.45	1.61	16.64	11.66	1.08	71441.60
9	6.24	14.56	49.94	1.14	16.18	11.08	1.04	80267.91
10	6.31	13.61	50.20	2.40	14.11	11.51	1.06	82889.53
11	6.01	9.65	57.61	2.47	14.56	11.82	1.06	81494.51
12	6.31	9.06	62.49	2.15	14.53	11.74	1.06	79792.50
13	6.99	11.09	50.63	1.43	16.71	10.85	1.03	82172.71
14	6.73	11.21	48.39	1.67	16.77	10.96	1.02	80596.25
15	6.40	11.20	47.75	1.74	17.29	10.75	1.03	83383.98
16	8.39	11.40	45.75	2.28	15.64	11.18	1.03	80745.23
17	9.34	13.08	49.00	2.74	14.26	11.52	1.05	78993.88
18	9.25	12.17	47.72	2.91	15.20	10.96	1.06	79882.47
19	8.74	11.35	43.70	2.19	16.57	10.85	1.06	75976.43
20	7.96	13.42	38.78	2.12	17.94	9.89	1.06	79352.53
21	8.55	11.30	45.45	2.44	16.78	9.74	1.06	78347.72
22	13.85	12.22	54.17	2.75	16.67	9.92	1.04	80466.44
23	11.59	11.66	51.45	2.32	16.38	10.38	1.04	78640.34
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.92	11.97	50.69	1.98	16.27	10.83	1.06	79883.25
最 大 值	13.85	14.56	62.49	2.91	18.75	11.82	1.11	83383.98
發生時間	22	9	12	18	0	11		15
最 小 值	5.70	9.06	38.78	1.03	14.11	9.74	1.02	71441.60
發生時間	8	12	20	0	10	21		8
零點偏移(率)	-0.02 %	-0.04 %	-0.03 %	-0.01 %		-0.03	-0.01	0.10 %
全幅偏移(率)	-1.26 %	-0.16 %	-0.65 %	-1.79 %		-0.02	-0.06	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

報表日期: 115年01月09日

備註	
----	--