

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月16日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.96	11.02	53.73	1.30	18.25	11.00	1.09	76274.50
1	9.21	11.10	58.05	1.07	19.65	10.66	1.10	78318.01
2	9.30	10.65	56.57	1.29	18.35	10.53	1.08	77683.97
3	8.96	12.56	51.41	1.95	15.25	11.55	1.09	72351.57
4	8.76	10.66	47.77	1.74	16.21	11.40	1.10	74220.42
5	10.34	10.06	58.80	1.66	16.59	11.44	1.09	70690.94
6	9.40	9.35	45.16	1.50	17.16	10.40	1.07	77347.16
7	9.05	9.00	65.83	1.43	15.80	11.45	1.08	74268.37
8	8.55	11.51	62.12	1.00	17.01	11.54	1.10	74609.48
9	7.17	12.38	60.55	1.20	16.93	11.62	1.12	76293.10
10	9.33	11.27	50.71	1.90	15.74	11.71	1.10	76700.65
11	3.65	13.21	61.84	1.21	15.91	12.22	1.08	72952.08
12	0.11	11.22	67.45	0.67	16.73	11.92	1.09	74774.30
13	0.10	11.59	45.33	1.32	15.40	11.78	1.09	74459.26
14	1.27	12.70	47.26	1.30	16.40	11.11	1.08	74798.45
15	5.54	10.36	52.38	1.22	16.78	11.22	1.10	74184.63
16	9.24	9.61	44.77	1.77	15.43	11.39	1.10	73325.95
17	8.57	7.39	54.42	1.21	17.12	11.26	1.11	75401.72
18	9.32	7.22	57.09	0.97	17.35	11.23	1.12	75924.48
19	6.93	10.00	68.30	0.56	17.44	11.44	1.11	74361.97
20	7.26	7.72	53.30	0.86	17.99	10.83	1.10	78077.74
21	5.16	8.49	52.02	0.86	17.58	11.13	1.10	76228.32
22	7.42	12.77	46.80	0.92	17.62	11.08	1.09	76280.88
23	5.43	7.31	59.85	0.68	18.35	11.13	1.07	75364.07
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.04	10.38	55.06	1.23	16.96	11.29	1.09	75203.83
最大值	10.34	13.21	68.30	1.95	19.65	12.22	1.13	78318.01
發生時間	5	11	19	3	1	11		1
最小值	0.10	7.22	44.77	0.56	15.25	10.40	1.07	70690.94
發生時間	13	18	16	19	3	6		5
零點偏移(率)	-0.02 %	0.00 %	-0.00 %	-0.00 %		0.00		0.00 %
全幅偏移(率)	0.02 %	-0.10 %	-0.14 %	0.10 %		0.18		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月16日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.10	6.85	65.06	1.46	16.23	11.16	1.07	79552.08
1	6.05	8.14	58.46	1.37	18.60	10.09	1.11	85514.90
2	9.09	7.83	65.18	1.40	17.03	10.45	1.08	84234.80
3	10.08	8.05	56.04	1.38	17.88	9.74	1.07	89142.18
4	9.06	6.63	62.08	1.59	16.63	10.20	1.07	86801.11
5	8.88	7.01	53.01	1.59	16.41	10.43	1.07	85117.31
6	6.18	6.56	49.23	1.23	17.47	10.19	1.07	95468.08
7	9.21	6.19	56.87	1.63	17.00	10.64	1.07	82634.72
8	9.85	7.23	55.06	1.47	18.11	10.21	1.07	85089.18
9	4.94	9.15	59.13	1.26	16.59	10.72	1.05	82001.23
10	4.63	3.24	53.21	1.29	16.68	10.59	1.07	82643.23
11	0.09	4.34	60.48	0.95	17.25	10.91	1.09	80424.08
12	3.05	6.27	50.58	1.25	17.15	10.02	1.06	87920.79
13	9.36	3.78	58.19	1.74	15.87	10.57	1.06	84104.06
14	8.11	4.88	59.91	1.02	17.26	10.12	1.07	86182.49
15	7.78	5.34	65.21	1.66	15.76	10.45	1.07	84847.68
16	0.51	4.01	62.97	1.34	16.39	11.07	1.07	79241.52
17	0.65	3.72	45.08	0.59	18.20	9.84	1.05	87632.11
18	3.73	7.43	48.20	1.74	16.65	9.88	1.05	88544.92
19	6.93	6.18	51.36	1.77	17.09	9.95	1.05	87708.57
20	8.38	4.57	57.45	1.38	17.25	9.97	1.07	87591.72
21	7.04	6.16	49.36	1.22	18.16	9.93	1.07	86956.25
22	5.23	8.82	48.19	1.13	19.12	9.40	1.07	89457.69
23	6.78	5.62	54.97	1.45	17.87	10.35	1.07	83908.21
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.36	6.17	56.05	1.37	17.19	10.29	1.07	85529.95
最大值	10.08	9.15	65.21	1.77	19.12	11.16	1.29	95468.08
發生時間	3	9	15	19	22	0		6
最小值	0.09	3.24	45.08	0.59	15.76	9.40	1.05	79241.52
發生時間	11	10	17	17	15	22		16
零點偏移(率)	-0.07 %	-0.02 %	-0.02 %	0.00 %		0.04		-0.10 %
全幅偏移(率)	0.04 %	0.60 %	-0.45 %	-0.00 %		0.02		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月16日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.70	7.88	59.00	1.37	17.40	9.32	0.97	82299.18
1	6.64	5.40	51.79	0.98	16.74	10.24	0.97	78827.83
2	7.76	6.60	44.66	1.84	14.45	10.59	0.97	76180.26
3	8.14	6.06	56.02	0.91	15.36	10.95	0.97	74439.88
4	10.01	7.11	55.52	1.68	14.24	10.56	0.97	76156.53
5	7.80	5.25	51.44	1.41	14.17	10.67	0.97	74803.71
6	7.98	6.81	58.04	0.96	15.02	10.65	0.97	73687.59
7	5.16	9.95	65.08	0.60	16.15	10.35	0.99	72458.91
8	9.51	7.55	73.35	0.88	16.28	10.37	1.01	82479.68
9	10.52	9.25	49.28	1.33	15.33	10.58	1.00	80465.29
10	8.61	5.08	46.94	0.95	16.14	10.73	1.02	81268.05
11	4.51	3.20	47.05	0.81	15.36	10.68	1.00	79647.08
12	2.96	3.07	57.22	0.92	15.26	10.72	0.99	79202.48
13	4.89	5.26	44.23	1.20	14.42	10.84	0.98	76594.53
14	3.79	3.55	60.26	0.91	15.63	10.75	0.99	77001.41
15	5.67	4.92	48.30	1.37	14.47	10.41	0.99	80267.27
16	9.88	5.56	55.01	2.34	13.91	11.29	1.01	78993.85
17	8.96	3.65	57.50	1.17	15.33	10.85	1.01	83270.31
18	10.35	4.94	45.84	1.80	13.76	11.25	0.99	80352.78
19	6.00	4.45	58.51	0.91	15.69	10.95	1.00	82527.11
20	6.74	6.13	60.49	0.90	15.83	10.95	1.00	82969.88
21	5.87	5.22	50.58	0.86	15.53	11.06	0.99	81536.58
22	3.59	4.50	58.40	0.73	15.73	11.08	0.99	79707.93
23	3.38	4.60	58.62	0.72	15.79	10.98	0.99	80632.88
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.06	5.67	54.71	1.15	15.33	10.70	0.99	78990.46
最大值	10.70	9.95	73.35	2.34	17.40	11.29	1.03	83270.31
發生時間	0	7	8	16	0	16		17
最小值	2.96	3.07	44.23	0.60	13.76	9.32	0.96	72458.91
發生時間	12	12	13	7	18	0		7
零點偏移(率)	-0.02 %	0.00 %	-0.01 %	0.00 %		0.03		0.00 %
全幅偏移(率)	-0.31 %	-0.25 %	-0.51 %	0.01 %		0.30		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								