

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月08日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.64	1.84	44.33	4.02	16.43	10.98	1.28	71411.56
1	8.69	1.72	63.46	3.54	17.26	11.43	1.28	68387.41
2	6.31	2.13	44.52	3.75	16.48	12.00	1.28	66882.16
3	8.41	2.58	41.73	4.34	15.60	11.92	1.28	67976.40
4	9.04	2.64	45.89	3.93	16.15	11.45	1.28	70595.17
5	6.16	7.22	49.29	3.70	15.29	11.66	1.27	69594.09
6	8.95	3.75	49.86	5.01	14.35	11.75	1.28	66983.89
7	9.23	6.10	50.78	5.42	14.52	11.46	1.28	68893.35
8	9.27	2.89	53.05	4.66	15.36	11.15	1.27	69602.74
9	9.14	2.11	50.00	3.90	16.45	11.22	1.26	68278.50
10	14.00	2.75	51.09	4.85	15.16	11.41	1.28	67817.69
11	5.04	2.12	59.53	3.30	16.32	11.40	1.28	67866.37
12	7.84	2.27	51.42	3.42	16.49	11.15	1.28	69280.65
13	9.39	1.94	57.45	3.18	17.86	10.84	1.28	71681.97
14	6.91	1.83	54.68	3.38	16.23	11.34	1.27	68804.46
15	10.00	1.75	61.11	3.33	17.73	10.76	1.27	72761.47
16	6.55	2.24	51.21	3.53	15.84	11.42	1.27	68020.34
17	8.30	1.61	65.23	3.14	17.77	10.64	1.28	71611.81
18	8.08	1.77	53.96	3.19	17.71	10.69	1.28	71351.69
19	8.28	1.76	64.71	3.66	18.63	10.20	1.28	75886.00
20	8.50	2.63	50.89	3.26	17.59	10.68	1.28	71695.61
21	8.92	1.80	46.54	3.73	16.89	10.74	1.28	70342.68
22	9.27	1.87	57.60	3.93	15.36	11.20	1.28	68265.74
23	4.63	1.74	63.39	2.78	18.13	10.79	1.28	71180.76
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.31	2.54	53.41	3.79	16.48	11.18	1.28	69798.85
最大值	14.00	7.22	65.23	5.42	18.63	12.00	1.29	75886.00
發生時間	10	5	17	7	19	2		19
最小值	4.63	1.61	41.73	2.78	14.35	10.20	1.25	66882.16
發生時間	23	17	3	23	6	19		2
零點偏移(率)	-0.02 %	-0.01 %	-0.01 %	-0.03 %		0.05	0.00	0.00 %
全幅偏移(率)	0.25 %	0.98 %	0.35 %	0.41 %		0.13	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月08日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.67	3.31	42.69	2.41	18.43	9.35	1.38	80247.48
1	7.24	2.91	41.00	1.83	19.04	9.43	1.38	76026.46
2	7.92	2.94	42.82	1.84	20.58	8.90	1.39	81018.58
3	9.62	3.19	37.01	2.26	19.44	8.72	1.39	81758.35
4	8.84	2.51	43.07	2.09	18.64	9.06	1.40	79812.97
5	6.31	2.37	48.03	1.79	18.49	9.24	1.42	80476.42
6	2.00	9.79	44.53	1.83	17.11	9.50	1.46	81504.03
7	2.16	1.87	47.11	1.65	17.01	9.82	1.48	76119.92
8	5.05	1.57	57.85	1.51	19.06	9.57	1.48	82180.97
9	10.71	2.11	48.02	2.30	18.91	9.28	1.46	85050.48
10	6.21	1.87	54.54	1.46	19.32	9.60	1.46	82872.99
11	4.02	2.18	51.92	1.59	18.04	9.79	1.46	85230.90
12	8.80	1.73	64.63	1.82	18.07	10.08	1.46	82304.61
13	6.57	1.61	52.41	1.69	18.18	9.82	1.46	81682.61
14	8.18	1.60	56.20	1.90	18.26	9.84	1.46	80553.43
15	8.00	1.82	57.44	1.94	17.76	10.04	1.46	81133.91
16	7.46	2.10	52.52	1.72	18.18	9.73	1.46	82957.40
17	1.29	1.89	64.55	1.24	18.45	10.45	1.46	77472.65
18	3.56	2.39	60.37	1.28	18.92	10.36	1.46	79708.10
19	5.74	3.74	52.56	0.78	20.52	9.37	1.46	86735.76
20	10.66	3.84	50.51	1.37	19.97	9.18	1.45	89490.38
21	10.05	3.31	54.32	1.75	18.87	9.45	1.45	85718.99
22	9.03	2.33	56.72	1.92	17.56	9.85	1.46	84305.86
23	9.28	1.85	53.64	1.42	19.28	9.42	1.46	84465.81
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.02	2.70	51.44	1.72	18.67	9.58	1.44	82034.54
最大值	10.71	9.79	64.63	2.41	20.58	10.45	1.49	89490.38
發生時間	9	6	12	0	2	17		20
最小值	1.29	1.57	37.01	0.78	17.01	8.72	1.38	76026.46
發生時間	17	8	3	19	7	3		1
零點偏移(率)	-0.05 %	-0.00 %	-0.01 %	-0.04 %		0.02	0.00	0.00 %
全幅偏移(率)	-0.75 %	0.16 %	-0.07 %	0.25 %		0.00	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月08日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.17	3.53	53.64	3.98	15.55	9.89	1.25	78483.00
1	8.90	4.84	47.85	3.62	15.68	10.67	1.24	73968.58
2	12.62	5.74	46.81	6.60	14.47	10.34	1.24	78029.23
3	7.33	0.72	60.56	4.44	16.24	10.31	1.25	80392.07
4	8.66	2.74	54.65	4.53	14.33	11.00	1.26	79202.13
5	7.09	3.01	53.36	3.50	16.22	11.03	1.26	74859.62
6	11.59	4.40	49.29	4.31	16.28	10.04	1.27	82002.37
7	8.65	5.56	59.95	3.37	15.69	10.97	1.29	73118.27
8	5.34	2.65	68.15	3.08	16.67	10.58	1.32	75900.66
9	9.65	2.86	47.70	3.52	17.53	9.61	1.29	80516.09
10	11.73	2.01	50.27	3.80	15.26	10.76	1.29	81304.25
11	8.58	4.56	47.70	3.47	15.18	10.95	1.30	80777.19
12	10.77	2.26	61.09	3.28	15.71	10.80	1.32	80878.76
13	9.86	1.87	57.48	3.42	16.03	10.39	1.31	82044.73
14	3.05	1.70	68.24	3.23	14.97	10.76	1.31	78195.65
15	1.91	1.73	68.70	2.69	17.02	10.09	1.30	79431.70
16	4.77	2.81	52.26	3.20	15.82	10.22	1.29	79346.48
17	6.62	2.65	58.65	3.03	16.29	10.06	1.28	81557.15
18	8.34	2.31	58.60	3.44	15.53	10.49	1.25	79580.37
19	3.39	2.14	64.90	2.76	19.03	9.74	1.28	84744.81
20	5.77	2.38	61.14	3.01	18.28	10.09	1.31	84149.13
21	11.28	2.27	62.30	3.32	17.02	10.40	1.32	85625.99
22	9.30	3.38	57.81	3.84	14.85	10.91	1.31	81500.47
23	8.05	2.36	60.48	3.57	16.90	10.43	1.30	83604.17
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.10	2.94	57.15	3.63	16.11	10.44	1.28	79967.20
最大值	12.62	5.74	68.70	6.60	19.03	11.03	1.36	85625.99
發生時間	2	2	15	2	19	5		21
最小值	1.91	0.72	46.81	2.69	14.33	9.61	1.23	73118.27
發生時間	15	3	2	15	4	9		7
零點偏移(率)	-0.01 %	0.00 %	-0.07 %	-0.06 %		0.05	0.00	0.00 %
全幅偏移(率)	1.09 %	1.56 %	-0.42 %	0.63 %		0.38	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								