

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年03月04日

報表日期: 113年03月04日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.18	6.38	60.82	1.39	16.86	12.02	1.10	77941.18
1	7.93	6.70	52.64	1.32	17.45	11.73	1.09	79914.34
2	10.27	7.94	43.65	2.95	14.63	11.86	1.09	81754.58
3	9.00	8.52	54.98	2.27	15.42	12.14	1.08	78504.11
4	9.32	7.95	52.24	2.02	15.40	11.69	1.06	82547.66
5	8.35	8.06	43.17	2.02	14.80	11.70	1.06	80851.33
6	9.16	6.26	48.50	2.32	14.81	12.01	1.06	80098.79
7	8.92	6.11	60.49	1.73	14.75	12.09	1.06	79260.75
8	9.36	5.79	42.38	2.53	14.38	11.95	1.07	80519.64
9	8.22	6.30	47.00	1.25	16.43	11.56	1.08	77378.33
10	6.22	6.01	51.82	1.06	15.97	11.48	1.10	78011.66
11	8.76	6.34	55.04	1.37	15.88	11.58	1.12	78497.37
12	9.98	6.37	58.87	1.80	15.43	11.72	1.11	77988.57
13	5.33	5.77	58.86	1.41	15.22	11.66	1.12	77860.42
14	8.20	6.04	62.52	1.10	16.44	11.49	1.11	80321.19
15	8.90	6.39	56.92	1.86	15.44	11.64	1.06	79086.49
16	9.48	7.45	61.92	0.57	17.79	11.27	1.09	81844.12
17	8.39	7.77	54.75	0.39	19.59	10.33	1.11	88915.39
18	9.41	7.82	39.36	1.16	17.58	10.94	1.10	85820.36
19	8.33	6.46	39.12	1.55	16.76	11.34	1.07	83537.67
20	6.56	7.18	56.92	1.61	16.41	11.75	1.06	80340.14
21	5.90	6.63	56.95	0.91	17.43	11.45	1.06	82089.47
22	7.63	7.33	41.06	1.53	17.06	11.57	1.09	81307.48
23	6.37	8.17	39.09	2.36	15.85	12.00	1.11	78529.20
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.22	6.91	51.63	1.60	16.16	11.62	1.09	80538.34
最 大 值	10.27	8.52	62.52	2.95	19.59	12.14	1.13	88915.39
發生時間	2	3	14	2	17	3		17
最 小 值	5.33	5.77	39.09	0.39	14.38	10.33	1.05	77378.33
發生時間	13	13	23	17	8	17		9
零點偏移(率)	-0.14 %	-0.09 %	-0.02 %	-0.01 %		-0.06		0.10 %
全幅偏移(率)	0.00 %	0.00 %	-0.05 %	0.00 %		-0.01		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月04日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.14	7.26	55.61	1.93	17.14	11.55	1.07	75881.08
1	6.28	6.69	38.59	3.22	16.95	10.86	1.08	81361.49
2	9.23	4.92	54.38	3.60	15.12	11.38	1.07	79499.43
3	9.35	4.71	58.21	3.10	16.02	11.30	1.07	79565.83
4	11.04	4.99	51.30	3.91	15.25	11.21	1.07	80440.70
5	8.57	4.30	51.43	3.35	14.50	11.50	1.06	79433.04
6	11.08	5.58	53.24	3.32	14.50	11.53	1.06	77631.55
7	9.28	3.25	51.97	3.46	13.97	11.69	1.06	77449.42
8	9.86	3.19	58.79	3.93	14.52	11.63	1.07	77668.06
9	9.21	2.72	53.95	3.42	14.11	12.18	1.04	76994.82
10	9.59	3.58	47.35	2.06	14.48	12.01	1.05	79569.54
11	8.77	5.60	52.05	1.45	14.75	12.11	1.02	78254.66
12	7.31	6.69	48.66	1.37	14.70	11.95	1.02	80031.53
13	4.78	6.08	47.52	1.34	16.02	11.71	1.02	81356.95
14	5.01	7.40	36.44	2.61	15.56	11.69	1.02	81297.97
15	7.06	9.89	48.12	2.66	16.09	11.63	1.02	80744.11
16	7.25	5.51	47.90	2.88	15.27	11.86	1.05	80112.45
17	3.68	4.78	47.97	2.08	16.44	11.80	1.06	79186.12
18	2.05	6.38	40.76	2.39	16.04	11.50	1.06	78977.68
19	3.16	7.69	35.79	1.96	17.76	10.99	1.06	79721.06
20	3.36	2.33	39.75	2.44	16.99	11.14	1.04	78857.11
21	6.11	3.13	32.34	2.18	17.76	10.68	1.04	81409.18
22	5.52	1.63	40.85	1.29	18.44	10.80	1.04	80160.10
23	5.84	1.88	25.01	1.84	17.35	11.02	1.05	78926.86
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.06	5.01	46.58	2.57	15.82	11.49	1.05	79355.45
最 大 值	11.08	9.89	58.79	3.93	18.44	12.18	1.10	81409.18
發生時間	6	15	8	8	22	9		21
最 小 值	2.05	1.63	25.01	1.29	13.97	10.68	1.02	75881.08
發生時間	18	22	23	22	7	21		0
零點偏移(率)	-0.13 %	-0.02 %	-0.02 %	0.00 %		-0.05		0.10 %
全幅偏移(率)	0.13 %	0.72 %	-0.22 %	0.06 %		-0.09		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月04日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	9.05	9.83	43.46	1.64	15.43	10.91	1.13	75271.18
1	6.96	8.68	54.61	1.25	16.98	10.64	1.13	76422.87
2	9.16	12.99	50.70	2.78	14.48	10.82	1.13	75536.75
3	9.00	3.54	54.00	2.05	15.33	10.86	1.13	75169.68
4	9.42	3.30	48.79	2.36	14.75	10.78	1.15	75366.49
5	9.12	3.51	50.13	2.33	14.07	11.10	1.15	72877.72
6	5.99	3.33	62.99	1.30	15.39	10.90	1.15	74500.57
7	8.63	4.88	46.26	1.89	15.19	10.65	1.13	74264.70
8	8.32	3.16	57.15	1.46	15.88	10.65	1.13	77314.41
9	8.97	3.07	53.80	1.85	14.93	10.81	1.12	75524.86
10	8.56	3.37	54.53	1.38	15.45	10.80	1.15	75576.72
11	3.67	3.47	50.36	0.98	14.72	11.16	1.14	73747.99
12	2.04	3.57	55.29	1.00	14.80	11.14	1.15	72949.06
13	1.48	6.19	54.96	0.66	15.67	10.85	1.14	74590.69
14	4.73	6.30	51.82	1.03	15.85	10.45	1.13	77992.10
15	8.40	7.49	49.81	1.48	15.46	10.64	1.14	77158.84
16	6.92	7.10	54.41	1.12	15.85	10.61	1.14	77935.51
17	7.64	7.03	50.73	1.04	16.21	10.34	1.13	79034.28
18	6.44	7.53	55.51	0.74	16.54	10.43	1.13	78546.17
19	1.10	7.38	55.43	0.49	15.97	11.09	1.15	75006.48
20	4.23	8.69	46.87	0.75	16.26	10.81	1.14	78878.22
21	6.21	9.66	50.34	0.68	16.16	11.05	1.15	77688.70
22	2.72	9.41	52.52	0.93	16.05	11.25	1.15	75906.09
23	4.23	7.53	47.39	0.73	16.33	10.83	1.15	78398.91
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.37	6.29	52.16	1.33	15.57	10.82	1.14	76069.12
最 大 值	9.42	12.99	62.99	2.78	16.98	11.25	1.15	79034.28
發生時間	4	2	6	2	1	22		17
最 小 值	1.10	3.07	43.46	0.49	14.07	10.34	1.10	72877.72
發生時間	19	9	0	19	5	17		5
零點偏移(率)	-0.04 %	-0.05 %	-0.11 %	-0.03 %		-0.02		-0.10 %
全幅偏移(率)	0.18 %	0.23 %	-0.22 %	0.02 %		0.10		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								