

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月08日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.01	13.76	39.79	1.11	16.32	11.08	1.25	84604.94
1	9.20	13.45	34.25	2.56	14.79	11.39	1.25	83181.88
2	9.38	13.21	42.60	1.86	16.94	11.52	1.25	80580.21
3	8.96	12.43	49.65	3.06	14.79	11.14	1.25	84312.34
4	3.48	13.94	48.99	3.46	12.37	12.32	1.25	78036.57
5	10.26	13.21	45.89	3.34	14.64	11.78	1.28	82804.95
6	9.07	13.06	47.03	2.64	14.48	11.87	1.30	80430.76
7	9.66	13.20	50.89	3.15	13.48	12.05	1.30	79336.21
8	10.27	12.89	51.26	2.70	14.44	11.75	1.29	81124.22
9	8.76	12.99	46.96	2.80	14.23	11.84	1.28	80755.00
10	9.68	13.75	51.07	2.73	14.59	12.30	1.29	76498.52
11	9.20	13.04	51.89	1.55	15.80	11.71	1.29	80225.86
12	9.43	12.98	41.29	1.73	16.25	10.66	1.30	87630.68
13	10.01	13.29	49.32	3.36	13.47	11.83	1.29	80757.37
14	8.87	13.35	29.97	3.33	14.19	11.98	1.29	79443.39
15	9.23	13.83	43.10	2.93	14.06	12.36	1.29	76245.46
16	9.52	12.10	46.88	3.09	13.88	11.99	1.29	79827.43
17	9.65	11.63	52.61	2.41	14.44	11.61	1.29	82389.31
18	10.00	12.02	46.58	2.60	14.39	11.88	1.29	79408.87
19	8.34	11.72	41.59	1.85	14.84	11.63	1.29	81946.68
20	9.03	12.28	51.12	2.21	14.76	12.09	1.29	77880.04
21	9.29	12.73	49.71	2.49	14.34	12.45	1.27	75514.57
22	9.56	11.79	40.62	2.52	14.41	11.70	1.27	82130.95
23	9.14	12.12	49.65	2.17	14.70	12.00	1.27	78691.95
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.13	12.87	45.95	2.57	14.61	11.79	1.28	80573.26
最大值	10.27	13.94	52.61	3.46	16.94	12.45	1.33	87630.68
發生時間	8	4	17	4	2	21		12
最小值	3.48	11.63	29.97	1.11	12.37	10.66	1.25	75514.57
發生時間	4	17	14	0	4	12		21
零點偏移(率)	-0.13 %	-0.01 %	-0.13 %	-0.01 %		-0.27	-0.01	0.40 %
全幅偏移(率)	-0.45 %	0.03 %	0.67 %	0.22 %		0.20	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月08日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.33	11.85	42.55	1.40	15.73	10.67	1.01	76740.90
1	3.04	12.10	42.36	1.63	15.54	10.89	1.01	76073.56
2	5.23	12.29	47.26	2.24	16.32	10.83	1.01	75861.47
3	2.51	12.13	47.28	1.63	15.68	10.91	1.00	75059.15
4	1.78	12.94	45.14	2.14	15.36	10.33	0.99	76332.75
5	1.41	11.02	38.17	2.03	14.87	10.13	0.99	74577.12
6	1.27	11.23	35.10	2.09	14.69	10.20	1.01	72571.74
7	1.64	12.84	57.17	2.36	14.74	10.75	1.01	76639.78
8	2.74	12.21	55.76	1.67	14.79	11.23	0.99	77598.59
9	4.31	12.16	53.65	2.00	14.72	11.16	0.98	78729.30
10	4.00	11.89	32.94	2.23	14.93	10.95	0.99	76868.64
11	4.55	11.76	33.90	1.87	15.26	10.84	1.01	78720.14
12	3.58	12.07	53.92	2.12	14.56	11.04	1.02	79906.17
13	2.24	12.39	68.57	1.51	14.41	11.46	1.01	78731.48
14	1.97	12.25	66.77	1.37	14.01	11.38	1.02	78872.08
15	1.67	12.14	66.24	1.47	14.16	11.29	1.02	79354.80
16	1.73	12.68	55.62	1.81	15.08	10.69	1.00	78471.86
17	1.87	11.87	52.64	1.14	15.20	10.73	0.99	78111.13
18	1.83	11.89	50.75	1.05	15.68	10.65	0.98	77585.40
19	2.59	11.82	53.32	1.21	15.56	10.65	0.99	78263.66
20	1.88	11.91	54.10	1.06	15.72	10.74	0.99	78513.30
21	1.98	11.65	48.54	1.65	15.89	10.47	0.99	78493.14
22	1.67	11.70	49.43	1.06	16.25	10.49	0.99	78068.51
23	1.51	11.70	45.86	1.09	15.96	10.50	0.99	78363.43
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	2.51	12.02	49.88	1.66	15.21	10.79	1.00	77437.84
最大值	5.23	12.94	68.57	2.36	16.32	11.46	1.02	79906.17
發生時間	2	4	13	7	2	13		12
最小值	1.27	11.02	32.94	1.05	14.01	10.13	0.97	72571.74
發生時間	6	5	10	18	14	5		6
零點偏移(率)	-0.07 %	0.01 %	-0.01 %	0.01 %		-0.06	-0.01	0.20 %
全幅偏移(率)	-2.01 %	-1.04 %	0.52 %	-0.58 %		0.01	-0.06	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月08日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.25	11.30	37.73	1.75	17.66	9.29	1.42	73714.59
1	9.83	12.36	36.11	2.54	16.60	9.22	1.43	73659.50
2	8.90	11.16	38.76	2.78	17.62	9.14	1.43	73032.29
3	9.52	10.55	41.46	2.38	15.84	9.49	1.43	70832.54
4	8.86	10.84	43.05	3.12	14.87	9.69	1.43	71512.11
5	11.71	10.71	44.82	3.20	14.92	9.83	1.43	71634.22
6	9.75	10.56	44.14	2.64	15.31	9.60	1.43	72641.36
7	10.11	11.11	41.34	2.98	16.42	9.43	1.47	72835.95
8	9.32	10.51	42.74	2.00	16.38	9.44	1.48	72721.25
9	8.67	10.76	42.19	1.93	16.08	9.60	1.47	72134.20
10	8.42	10.73	37.63	1.95	15.94	9.30	1.47	72886.46
11	7.34	10.62	38.60	1.81	15.68	9.50	1.48	72375.73
12	6.11	10.95	41.33	2.08	14.84	9.65	1.48	71144.10
13	6.28	10.63	44.91	1.93	15.68	9.63	1.48	72172.10
14	6.75	11.21	40.04	2.37	15.12	9.61	1.48	71777.83
15	8.26	12.94	24.03	1.99	17.81	8.51	1.48	75598.16
16	6.87	11.22	34.90	1.38	16.55	8.86	1.48	74723.88
17	6.70	10.79	38.58	1.50	17.07	9.16	1.48	74481.24
18	7.01	10.98	38.04	1.45	17.12	9.16	1.47	74030.69
19	7.06	10.67	36.62	1.38	16.93	9.20	1.48	74894.07
20	6.83	10.75	37.69	1.43	16.75	9.34	1.46	74960.09
21	8.52	11.00	36.56	1.58	16.33	9.40	1.44	73958.11
22	6.93	11.44	31.34	1.40	17.34	8.89	1.45	74990.04
23	7.38	11.56	31.93	1.55	17.47	8.83	1.46	74149.57
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.18	11.06	38.52	2.05	16.35	9.32	1.46	73202.50
最大值	11.71	12.94	44.91	3.20	17.81	9.83	1.50	75598.16
發生時間	5	15	13	5	15	5		15
最小值	6.11	10.51	24.03	1.38	14.84	8.51	1.41	70832.54
發生時間	12	8	15	16	12	15		3
零點偏移(率)	-0.09 %	-0.04 %	-0.02 %	-0.01 %		-0.04	-0.01	0.30 %
全幅偏移(率)	1.09 %	-1.60 %	0.22 %	0.07 %		0.19	0.04	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								