

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月04日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.94	3.54	65.34	2.16	16.84	12.39	1.46	67774.43
1	1.70	3.41	61.07	1.98	17.80	11.70	1.44	72485.58
2	2.32	3.66	66.09	1.95	18.56	12.21	1.43	67857.49
3	1.72	4.03	68.05	2.00	17.95	12.27	1.43	68000.29
4	0.15	3.70	52.80	1.86	18.16	12.13	1.48	69199.98
5	0.17	5.82	46.81	2.29	17.44	12.55	1.52	67662.91
6	0.18	4.18	52.22	1.84	18.06	11.77	1.47	72194.18
7	2.12	4.15	50.91	2.18	17.33	11.79	1.46	72538.40
8	7.53	4.59	57.44	3.26	15.77	12.03	1.46	71501.71
9	7.34	4.93	56.40	3.71	16.11	12.13	1.48	70341.02
10	3.36	4.84	53.30	2.42	16.72	12.00	1.51	71052.44
11	6.00	4.06	62.40	2.14	17.79	11.70	1.48	72309.11
12	3.43	4.15	53.83	2.09	17.31	11.51	1.47	73852.51
13	1.58	4.53	58.30	2.29	17.07	12.38	1.51	66900.48
14	0.96	7.40	65.60	3.10	15.54	13.38	1.52	60058.69
15	1.48	4.36	47.71	2.22	17.01	11.85	1.50	72462.56
16	9.40	3.95	47.12	2.74	16.48	11.96	1.51	71319.73
17	7.73	3.21	52.19	2.57	16.74	11.96	1.51	70711.06
18	5.71	3.28	53.44	2.53	16.35	11.95	1.51	70630.59
19	6.45	3.34	58.05	2.66	16.49	12.16	1.47	69458.05
20	8.79	3.17	52.74	2.79	15.88	11.90	1.46	72099.98
21	8.37	3.42	52.50	2.77	16.14	12.08	1.44	70381.08
22	6.24	3.23	60.24	2.43	16.68	11.95	1.49	70839.42
23	7.18	3.46	59.82	2.08	18.19	11.72	1.51	71758.05
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.20	4.10	56.43	2.42	17.02	12.06	1.48	70141.24
最大值	9.40	7.40	68.05	3.71	18.56	13.38	1.58	73852.51
發生時間	16	14	3	9	2	14		12
最小值	0.15	3.17	46.81	1.84	15.54	11.51	1.42	60058.69
發生時間	4	20	5	6	14	12		14
零點偏移(率)	-0.01 %	-0.02 %	-0.03 %	0.00 %		-0.03	0.00	0.00 %
全幅偏移(率)	-1.10 %	0.32 %	-0.40 %	0.03 %		-0.01	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月04日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.08	6.99	42.21	1.57	18.69	10.19	1.54	85426.59
1	8.36	5.02	44.40	1.37	19.91	10.08	1.53	83934.88
2	2.49	5.96	54.03	1.13	19.30	11.50	1.52	74246.49
3	2.38	5.42	57.46	1.02	19.96	11.01	1.52	78859.99
4	2.72	5.92	69.02	1.22	19.62	11.51	1.51	75226.71
5	9.81	3.51	39.00	2.41	19.34	10.08	1.50	87045.90
6	10.96	2.74	35.77	2.50	18.70	10.03	1.50	80854.74
7	8.78	3.73	40.09	1.91	19.83	9.84	1.51	86807.13
8	8.83	5.73	40.31	2.15	19.35	9.95	1.53	84408.65
9	3.37	2.86	37.71	1.48	17.99	10.33	1.50	79861.19
10	2.15	2.58	32.94	1.38	18.80	9.84	1.49	82658.64
11	3.19	5.72	33.21	1.82	17.94	10.18	1.50	79915.98
12	7.51	2.85	41.20	1.91	18.52	10.07	1.50	83890.59
13	5.75	6.70	40.45	1.90	18.42	10.05	1.49	81848.01
14	4.28	4.05	32.49	1.97	20.19	9.61	1.47	82785.49
15	5.77	3.32	35.96	2.19	18.02	10.22	1.47	81097.34
16	8.98	8.12	37.95	2.87	18.47	9.67	1.49	80734.66
17	8.55	5.69	28.83	2.39	19.26	9.42	1.50	84261.89
18	8.41	4.92	36.02	1.59	20.20	9.76	1.50	85035.47
19	8.24	9.24	40.89	1.99	18.68	10.13	1.50	82321.63
20	7.05	8.64	40.41	2.15	17.95	10.15	1.50	81742.35
21	7.44	4.96	44.95	2.33	17.34	10.42	1.48	79910.98
22	8.95	4.98	40.49	1.91	18.45	10.35	1.46	78821.03
23	9.00	3.98	40.79	1.89	19.12	10.10	1.48	80085.54
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.63	5.15	41.11	1.88	18.92	10.19	1.50	81740.91
最大值	10.96	9.24	69.02	2.87	20.20	11.51	1.55	87045.90
發生時間	6	19	4	16	18	4		5
最小值	2.15	2.58	28.83	1.02	17.34	9.42	1.46	74246.49
發生時間	10	10	17	3	21	17		2
零點偏移(率)	0.00 %	-0.00 %	-0.00 %	-0.01 %		-0.10	0.00	0.00 %
全幅偏移(率)	0.32 %	0.33 %	-0.61 %	0.23 %		-0.16	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月04日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.58	3.67	51.78	1.46	16.83	10.82	1.42	83876.59
1	3.55	3.82	60.94	1.51	17.05	10.53	1.42	83909.42
2	1.95	2.70	65.09	1.39	17.67	11.11	1.43	80915.83
3	1.13	2.60	57.75	1.30	16.81	11.08	1.43	82011.27
4	0.89	4.02	62.89	1.50	16.31	11.23	1.43	81181.18
5	3.94	4.98	56.03	1.77	16.68	10.75	1.43	86890.69
6	8.66	5.09	57.97	2.08	16.06	10.69	1.43	86218.84
7	7.73	6.93	56.81	2.14	16.54	10.53	1.42	84232.37
8	6.55	5.70	57.20	2.18	15.61	10.91	1.43	82670.13
9	2.98	6.89	64.47	2.23	14.79	11.01	1.42	80170.41
10	5.47	4.58	58.36	2.76	14.25	11.06	1.42	79722.25
11	5.65	7.83	58.10	3.07	14.00	11.03	1.40	80469.22
12	3.85	2.38	53.61	2.69	14.06	11.15	1.40	77604.45
13	5.58	2.25	56.41	2.06	15.42	11.02	1.41	80357.94
14	3.62	2.91	57.65	1.60	17.18	10.49	1.42	84852.65
15	5.11	5.83	54.74	1.71	16.74	10.70	1.41	82698.92
16	3.41	7.77	62.57	1.62	17.30	10.60	1.41	84801.47
17	2.91	7.88	45.98	1.44	17.80	9.94	1.38	82900.72
18	3.05	4.86	58.68	1.59	16.83	10.76	1.39	81822.51
19	3.66	4.76	56.61	1.78	15.61	11.14	1.40	80624.47
20	1.42	4.89	59.05	1.99	14.75	11.23	1.38	79233.22
21	2.39	4.40	58.18	1.83	15.36	11.04	1.40	81862.65
22	4.61	4.39	59.79	1.82	16.52	10.92	1.41	83030.50
23	6.36	5.70	55.55	1.78	16.68	10.59	1.40	85448.83
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.13	4.87	57.76	1.89	16.12	10.85	1.41	82396.11
最大值	8.66	7.88	65.09	3.07	17.80	11.23	1.47	86890.69
發生時間	6	17	2	11	17	4		5
最小值	0.89	2.25	45.98	1.30	14.00	9.94	1.38	77604.45
發生時間	4	13	17	3	11	17		12
零點偏移(率)	-0.17 %	-0.04 %	-0.03 %	-0.05 %		-0.06	0.00	0.00 %
全幅偏移(率)	0.03 %	0.03 %	-0.58 %	0.03 %		0.14	-0.03	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								