

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月14日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.02	11.92	54.79	2.12	17.86	11.20	1.31	81237.70
1	9.70	12.10	56.62	1.48	18.53	11.24	1.32	81477.99
2	12.20	11.82	49.70	2.18	16.79	11.16	1.31	82535.42
3	8.96	11.99	48.95	2.23	15.43	11.51	1.31	79151.40
4	8.84	12.63	52.40	2.27	15.27	11.55	1.30	79376.76
5	7.11	13.46	55.56	2.44	15.52	11.89	1.31	75320.52
6	9.54	13.03	53.41	2.32	16.42	11.86	1.30	76235.68
7	9.38	11.77	48.10	2.74	15.92	11.41	1.29	80995.61
8	12.48	11.73	56.53	2.37	15.67	11.49	1.30	80035.86
9	8.71	11.58	55.31	2.39	15.64	11.37	1.32	81224.08
10	10.67	11.81	58.31	2.50	15.10	11.56	1.29	79760.21
11	8.46	12.01	51.20	1.84	16.58	11.45	1.30	77817.89
12	9.08	12.27	47.03	2.18	15.87	11.41	1.31	76430.29
13	12.77	14.44	57.78	1.98	16.85	11.28	1.31	79617.31
14	6.18	15.01	51.90	2.08	15.38	11.68	1.31	79355.69
15	9.33	12.27	63.00	1.89	16.65	11.67	1.32	79633.04
16	12.68	12.73	61.28	2.58	17.15	11.47	1.30	80635.30
17	7.27	12.92	61.42	2.53	17.10	11.12	1.28	83350.45
18	7.82	12.17	59.06	2.27	15.80	11.67	1.28	80348.77
19	9.86	12.58	55.75	1.70	17.10	11.55	1.31	79766.48
20	6.73	13.57	56.50	1.42	17.29	11.38	1.31	80581.96
21	8.43	15.08	55.85	1.75	17.79	11.30	1.31	81394.95
22	8.22	12.69	61.95	1.48	17.34	11.75	1.31	76224.10
23	11.42	14.17	57.19	1.63	17.63	11.25	1.32	81290.69
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.49	12.74	55.40	2.10	16.53	11.47	1.31	79741.59
最大值	12.77	15.08	63.00	2.74	18.53	11.89	1.34	83350.45
發生時間	13	21	15	7	1	5		17
最小值	6.18	11.58	47.03	1.42	15.10	11.12	1.27	75320.52
發生時間	14	9	12	20	10	17		5
零點偏移(率)	-0.43 %	-0.01 %	-0.02 %	-0.01 %		-0.07	-0.01	0.40 %
全幅偏移(率)	-1.53 %	-1.90 %	0.50 %	-0.33 %		0.26	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月14日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.57	12.16	44.41	1.02	18.25	10.65	1.02	79102.25
1	10.38	11.66	47.85	1.39	18.90	10.11	1.03	79735.53
2	8.40	11.78	41.73	2.14	16.46	10.26	1.02	78230.76
3	9.35	12.04	38.76	2.68	15.80	10.24	1.02	78306.15
4	8.97	15.01	54.33	2.29	16.36	10.79	1.02	75884.75
5	10.12	11.96	43.20	2.33	16.81	10.52	1.02	77884.85
6	9.63	11.98	56.43	2.02	15.95	10.70	1.04	80098.38
7	9.29	11.92	52.55	2.60	15.96	10.59	1.03	77769.69
8	8.87	12.48	44.72	3.00	15.05	10.65	1.05	78053.59
9	8.57	12.91	47.15	3.20	15.72	10.87	1.05	69944.55
10	8.52	11.82	48.45	2.24	14.87	10.95	1.04	78302.87
11	9.78	12.11	51.40	2.23	15.80	10.70	1.05	76899.41
12	9.51	12.43	59.09	2.11	15.55	10.99	1.06	79639.68
13	8.86	12.47	61.23	1.78	15.77	11.23	1.06	78893.75
14	10.15	11.98	45.50	2.06	17.29	10.59	1.06	79143.23
15	8.16	12.27	45.86	2.50	15.81	10.83	1.06	77297.35
16	11.79	12.32	46.36	3.03	15.32	10.59	1.04	77041.39
17	9.51	12.50	47.15	1.98	16.56	10.43	1.02	79768.93
18	7.93	14.21	53.84	1.67	18.22	10.44	1.03	83241.28
19	9.68	13.31	64.74	2.02	16.83	11.18	1.06	81736.43
20	9.38	13.31	45.83	1.38	18.18	10.76	1.06	83978.99
21	9.12	13.44	49.08	1.72	17.68	10.90	1.07	82945.15
22	10.61	15.53	54.72	1.24	18.02	10.89	1.08	83174.34
23	9.06	15.72	57.19	1.45	18.93	10.62	1.07	83927.92
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.30	12.81	50.07	2.09	16.67	10.69	1.04	79208.38
最大值	11.79	15.72	64.74	3.20	18.93	11.23	1.09	83978.99
發生時間	16	23	19	9	23	13		20
最小值	7.57	11.66	38.76	1.02	14.87	10.11	1.01	69944.55
發生時間	0	1	3	0	10	1		9
零點偏移(率)	-0.04 %	0.01 %	-0.09 %	-0.01 %		-0.05	-0.01	-0.10 %
全幅偏移(率)	1.44 %	-0.48 %	0.08 %	-0.25 %		0.08	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月14日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.15	11.16	58.03	2.78	18.54	9.49	1.39	77107.82
1	10.16	11.86	51.68	2.85	18.21	9.60	1.39	76166.00
2	11.06	11.70	60.40	3.08	15.46	10.09	1.38	73802.57
3	7.62	11.32	58.36	2.68	15.62	10.20	1.37	72775.16
4	8.81	11.33	59.57	2.72	16.02	10.20	1.37	74392.44
5	9.31	11.56	53.50	2.82	15.32	10.11	1.38	73382.43
6	10.01	12.86	53.23	3.44	15.04	10.05	1.40	74141.86
7	8.71	11.30	53.05	2.83	16.36	10.08	1.41	77048.17
8	9.48	12.74	55.06	3.45	15.12	10.16	1.41	74134.63
9	7.03	11.69	56.90	3.11	15.39	10.21	1.39	73876.11
10	7.63	12.67	57.20	3.36	14.73	10.34	1.39	74602.35
11	8.48	11.90	55.27	2.84	15.60	10.13	1.37	74071.52
12	9.81	11.44	48.74	2.82	15.86	9.92	1.36	74867.56
13	9.10	11.74	55.48	2.97	16.30	10.06	1.36	74557.03
14	9.84	11.49	55.57	2.92	16.96	9.99	1.36	75127.82
15	9.32	12.43	54.21	3.09	16.59	9.63	1.36	74554.13
16	8.69	11.86	49.04	2.82	15.80	9.56	1.36	73721.80
17	7.57	11.39	50.91	3.35	16.91	8.98	1.36	74574.40
18	8.51	14.66	50.38	2.80	18.78	8.83	1.36	75446.83
19	7.47	11.19	41.15	3.88	17.51	8.55	1.36	78664.29
20	8.83	10.63	53.61	2.91	15.13	9.93	1.37	75881.57
21	8.41	14.03	53.81	2.82	18.01	9.11	1.36	72962.60
22	6.43	11.46	54.87	3.44	19.23	8.60	1.36	70171.12
23	6.51	14.45	50.75	3.50	20.73	8.65	1.36	72771.82
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.54	12.04	53.78	3.05	16.63	9.69	1.37	74533.42
最大值	11.06	14.66	60.40	3.88	20.73	10.34	1.42	78664.29
發生時間	2	18	2	19	23	10		19
最小值	6.15	10.63	41.15	2.68	14.73	8.55	1.36	70171.12
發生時間	0	20	19	3	10	19		22
零點偏移(率)	0.00 %	-0.01 %	-0.03 %	0.00 %		-0.07	-0.01	0.00 %
全幅偏移(率)	-0.60 %	0.00 %	1.46 %	0.40 %		0.22	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								