

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月06日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.50	6.83	62.95	0.69	16.17	11.58	1.02	82541.55
1	5.96	6.76	59.05	1.83	16.05	12.03	1.02	78540.46
2	6.46	3.60	53.77	1.11	16.16	11.86	1.03	80588.25
3	9.95	6.47	43.99	1.95	15.07	11.41	1.03	85256.72
4	6.01	6.84	59.79	2.39	13.89	12.06	1.02	80678.98
5	9.96	12.38	57.58	1.94	15.72	11.74	1.06	79512.73
6	8.24	6.79	43.45	1.30	15.50	11.50	1.06	84237.12
7	6.95	5.72	44.21	2.06	14.73	11.85	1.06	81819.52
8	6.10	7.40	43.21	1.37	15.49	11.81	1.06	81359.62
9	3.64	8.88	50.79	0.82	16.30	12.15	1.05	77359.40
10	5.23	7.74	63.16	0.41	16.60	12.07	1.05	77410.01
11	10.14	5.89	49.43	0.86	16.81	11.32	1.06	83427.49
12	8.66	7.01	46.88	1.53	15.08	12.12	1.06	78364.31
13	8.99	7.74	45.01	0.85	16.65	11.36	1.07	83184.70
14	4.87	2.03	59.85	1.00	15.76	12.47	1.10	75029.90
15	7.43	4.46	39.90	1.32	15.58	11.56	1.06	82927.38
16	7.52	6.53	45.39	1.95	15.44	12.08	1.05	78739.69
17	4.16	4.89	56.88	0.76	16.21	11.90	1.04	79492.35
18	5.26	5.99	53.59	0.61	17.60	11.17	1.04	84202.58
19	9.47	5.30	48.68	0.80	17.60	11.22	1.02	84040.49
20	9.33	6.07	45.71	1.64	16.16	11.46	1.02	83404.99
21	5.95	6.83	61.99	0.74	16.35	12.26	1.02	76393.22
22	4.63	6.49	51.07	0.48	17.25	11.64	1.02	80718.28
23	4.23	5.60	54.71	0.36	18.00	11.72	1.04	79531.39
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.90	6.43	51.71	1.20	16.09	11.76	1.04	80781.71
最大值	10.14	12.38	63.16	2.39	18.00	12.47	1.12	85256.72
發生時間	11	5	10	4	23	14		3
最小值	3.64	2.03	39.90	0.36	13.89	11.17	1.02	75029.90
發生時間	9	14	15	23	4	18		14
零點偏移(率)	0.00 %	-0.00 %	-0.01 %	-0.01 %		-0.06		0.10 %
全幅偏移(率)	0.61 %	-0.10 %	0.15 %	0.02 %		-0.03		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月06日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.68	3.33	42.62	1.67	16.20	11.12	1.06	80361.97
1	2.45	2.97	49.26	1.94	17.58	10.92	1.04	80334.63
2	9.55	2.84	50.70	2.73	15.39	11.09	1.03	81232.26
3	9.93	3.05	50.99	3.06	15.86	11.09	1.04	81344.47
4	7.39	2.56	48.74	2.67	14.69	11.61	1.05	78630.82
5	10.29	3.11	49.06	2.98	15.26	11.28	1.05	80335.98
6	0.70	5.08	52.75	1.85	15.20	11.57	1.06	77426.24
7	5.09	6.47	34.61	2.67	15.34	11.18	1.06	81150.62
8	3.68	1.61	58.56	1.32	16.93	11.28	1.06	78714.76
9	1.43	1.62	47.17	1.55	17.18	11.06	1.05	80002.02
10	2.71	1.60	38.56	2.24	16.31	10.80	1.05	82437.56
11	5.91	1.43	38.27	2.48	15.37	10.91	1.06	82324.28
12	1.13	3.37	43.95	2.42	14.91	11.31	1.06	79641.12
13	1.92	3.89	46.45	2.25	15.42	11.15	1.06	80079.73
14	10.72	6.96	43.07	3.25	15.21	11.20	1.06	79265.07
15	8.00	8.49	33.79	4.02	13.41	11.78	1.06	76173.77
16	9.32	2.41	49.96	2.88	14.06	11.81	1.06	75850.22
17	6.57	3.84	48.14	2.21	15.26	11.71	1.06	75663.71
18	5.97	4.32	51.98	2.01	15.29	11.79	1.06	75152.87
19	8.10	4.31	45.11	2.29	15.32	11.42	1.05	77881.35
20	3.51	4.08	47.29	2.30	14.35	11.84	1.04	76133.75
21	5.22	3.92	50.55	2.34	14.72	11.87	1.04	76178.20
22	7.82	3.73	46.85	2.69	14.56	11.64	1.03	77615.40
23	9.07	4.37	54.08	2.37	15.54	11.55	1.03	77206.30
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.92	3.72	46.77	2.42	15.39	11.37	1.05	78797.38
最大值	10.72	8.49	58.56	4.02	17.58	11.87	1.07	82437.56
發生時間	14	15	8	15	1	21		10
最小值	0.70	1.43	33.79	1.32	13.41	10.80	1.02	75152.87
發生時間	6	11	15	8	15	10		18
零點偏移(率)	-0.05 %	0.00 %	-0.01 %	0.01 %		-0.02		-0.10 %
全幅偏移(率)	0.69 %	0.00 %	0.90 %	0.20 %		-0.20		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月06日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.21	4.56	59.03	0.62	17.53	10.49	1.04	81243.54
1	2.74	5.46	53.26	0.54	18.74	10.28	1.04	81913.81
2	2.83	5.07	61.28	0.82	16.53	10.78	1.04	80575.57
3	3.34	7.09	54.54	1.13	15.92	10.73	1.04	79843.73
4	6.01	2.64	61.92	0.99	16.36	10.73	1.04	79979.94
5	5.65	4.73	55.48	1.12	15.49	10.91	1.04	79016.13
6	2.53	4.59	64.10	0.78	16.16	10.92	1.04	78845.42
7	1.20	4.81	61.43	0.51	17.04	10.65	1.04	81091.63
8	2.58	4.27	62.35	0.30	17.83	10.40	1.05	81524.67
9	2.91	4.87	68.00	0.42	16.65	11.24	1.06	75101.37
10	2.48	6.51	51.00	0.92	15.38	11.41	1.05	76306.64
11	2.55	14.41	48.99	1.35	14.95	10.88	1.04	78936.00
12	2.36	4.14	47.98	0.55	15.93	10.89	1.04	76710.93
13	2.41	4.76	44.60	0.52	16.49	10.84	1.04	76896.00
14	3.54	4.98	45.78	0.58	16.59	10.52	1.04	80521.51
15	8.20	8.30	42.59	1.33	15.54	10.72	1.04	79131.31
16	5.49	4.74	52.12	0.98	15.78	10.93	1.04	78482.10
17	3.25	3.89	55.17	0.44	17.29	10.54	1.04	79546.37
18	5.09	4.14	61.13	0.75	16.60	10.97	1.04	77380.96
19	2.62	4.04	45.31	0.52	16.02	10.75	1.04	77355.49
20	2.05	4.91	54.22	0.73	15.34	11.32	1.04	73079.68
21	2.10	5.62	56.52	0.28	17.92	10.92	1.05	77391.39
22	4.78	4.76	57.97	0.46	18.45	10.15	1.06	82655.69
23	6.39	5.06	48.75	0.60	17.66	10.27	1.05	82153.93
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.60	5.35	54.73	0.72	16.59	10.76	1.04	78986.83
最大值	8.20	14.41	68.00	1.35	18.74	11.41	1.08	82655.69
發生時間	15	11	9	11	1	10		22
最小值	1.20	2.64	42.59	0.28	14.95	10.15	1.03	73079.68
發生時間	7	4	15	21	11	22		20
零點偏移(率)	-0.06 %	-0.00 %	-0.01 %	0.00 %		-0.04		0.20 %
全幅偏移(率)	0.02 %	0.08 %	0.11 %	0.37 %		0.05		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								