

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月11日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.67	6.90	65.07	1.06	15.82	12.29	1.02	76524.44
1	8.01	6.78	53.30	1.26	17.58	11.42	1.02	82329.70
2	9.81	6.31	54.67	1.37	16.52	11.16	1.02	85840.63
3	4.59	7.80	62.87	1.20	15.21	11.71	1.04	81520.05
4	5.50	7.05	58.19	0.63	17.35	10.85	1.06	87590.39
5	9.21	10.75	57.86	0.94	17.69	10.78	1.03	88946.88
6	8.77	5.15	53.60	1.19	17.39	11.19	1.03	84787.98
7	5.47	4.81	66.33	0.46	17.90	11.48	1.03	82039.62
8	1.96	5.03	55.93	0.52	16.66	11.80	1.00	80208.57
9	6.01	7.27	35.54	1.08	16.32	11.64	1.02	81849.09
10	2.53	3.81	66.14	0.65	16.61	11.85	1.04	79523.78
11	1.63	2.97	61.50	1.71	14.47	12.14	1.05	78656.73
12	0.22	12.69	68.43	1.68	14.84	12.39	1.04	76369.18
13	0.19	11.95	60.89	1.26	16.02	12.29	1.03	76064.83
14	0.13	14.20	51.43	1.25	16.01	12.03	1.05	78601.31
15	3.28	11.73	49.90	1.59	16.02	11.61	1.04	82147.75
16	9.31	8.71	50.57	1.42	16.66	11.31	1.04	83868.05
17	8.29	8.40	69.20	0.53	17.63	11.14	1.03	84598.81
18	4.72	6.35	46.13	1.18	16.41	11.31	1.02	84475.59
19	3.50	5.61	57.34	0.71	16.98	11.36	1.02	83263.24
20	1.08	6.47	58.94	1.06	16.04	11.96	1.03	79329.58
21	3.11	6.11	55.40	1.12	16.73	11.31	1.02	84146.92
22	8.74	6.19	48.37	2.09	15.20	11.84	1.02	81163.05
23	7.38	5.24	50.46	1.25	16.49	11.44	1.04	83424.63
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.96	7.43	56.59	1.13	16.44	11.60	1.03	81969.62
最大值	9.81	14.20	69.20	2.09	17.90	12.39	1.06	88946.88
發生時間	2	14	17	22	7	12		5
最小值	0.13	2.97	35.54	0.46	14.47	10.78	0.99	76064.83
發生時間	14	11	9	7	11	5		13
零點偏移(率)	-0.08 %	-0.02 %	-0.02 %	-0.01 %		-0.06		0.10 %
全幅偏移(率)	0.00 %	-0.33 %	-0.15 %	-0.06 %		0.03		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月11日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.69	5.09	52.65	1.89	16.99	11.10	1.01	79061.30
1	8.84	6.09	34.41	2.33	17.64	10.35	0.99	84952.16
2	7.74	6.36	33.57	3.32	14.58	11.08	0.99	81604.57
3	8.22	5.32	60.36	2.70	15.20	11.66	1.00	76482.39
4	5.30	3.03	61.18	2.54	15.18	11.77	1.02	76054.66
5	1.33	2.68	66.41	1.46	17.00	11.50	1.02	76413.75
6	5.44	5.75	50.85	1.66	18.25	10.68	1.03	89222.77
7	2.49	3.55	55.48	1.23	17.80	10.51	1.02	83471.31
8	2.96	6.08	40.40	2.65	14.95	11.49	1.00	77781.34
9	7.49	4.05	40.62	2.77	15.00	11.45	1.02	78776.89
10	8.90	3.05	41.71	2.81	14.73	11.53	1.02	78328.32
11	5.58	3.11	55.69	1.44	16.26	11.84	1.02	74224.19
12	2.87	2.89	55.50	1.10	18.31	10.68	1.02	81353.03
13	4.94	3.30	39.29	1.76	17.36	10.84	1.02	80117.00
14	8.85	3.24	43.11	1.70	18.24	10.50	1.02	81869.02
15	7.50	3.16	40.24	1.58	17.40	10.99	1.02	79031.10
16	6.94	3.41	35.63	1.96	16.96	10.66	1.02	81759.60
17	4.66	3.03	39.67	1.38	17.37	10.64	1.02	82311.10
18	3.27	3.95	43.20	1.77	16.52	10.66	1.02	82801.47
19	2.06	5.25	51.25	1.25	17.15	11.03	1.02	79363.42
20	3.75	5.58	49.24	1.71	17.02	10.76	1.00	81153.82
21	10.03	6.13	48.21	1.97	17.23	10.52	1.01	83158.83
22	4.04	3.57	43.63	2.69	15.32	11.17	1.00	75603.82
23	0.93	2.18	56.64	1.49	16.39	11.67	1.02	74957.94
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.53	4.16	47.46	1.97	16.62	11.05	1.01	79993.91
最大值	10.03	6.36	66.41	3.32	18.31	11.84	1.03	89222.77
發生時間	21	2	5	2	12	11		6
最小值	0.93	2.18	33.57	1.10	14.58	10.35	0.98	74224.19
發生時間	23	23	2	12	2	1		11
零點偏移(率)	-0.07 %	-0.00 %	-0.01 %	-0.02 %		-0.02		-0.10 %
全幅偏移(率)	0.14 %	-0.21 %	0.09 %	0.39 %		-0.05		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月11日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.69	4.58	44.93	0.33	17.73	9.92	1.09	78132.28
1	2.71	2.81	40.44	0.21	18.16	9.84	1.08	78211.24
2	3.23	2.70	40.58	0.37	16.65	10.13	1.09	76903.06
3	2.27	2.29	46.39	0.30	16.53	10.19	1.09	75496.29
4	2.92	2.51	48.67	0.38	17.03	10.22	1.08	74927.45
5	2.28	2.26	47.85	0.25	17.65	9.91	1.07	77662.29
6	2.14	3.46	40.14	0.24	17.32	9.59	1.07	78611.87
7	2.95	13.08	55.21	0.63	16.50	10.11	1.08	72346.99
8	0.41	4.91	44.83	0.53	15.96	10.46	1.07	75103.45
9	4.05	3.40	48.83	0.75	16.01	10.30	1.08	78577.67
10	2.08	4.12	50.81	0.48	16.25	10.52	1.09	75935.24
11	1.95	3.46	47.53	0.63	15.69	10.59	1.09	75909.83
12	1.51	4.48	53.43	0.29	17.07	10.52	1.10	75837.71
13	0.11	4.90	42.06	0.33	16.02	10.48	1.08	74078.58
14	2.79	3.84	43.71	0.35	16.71	10.30	1.08	74668.08
15	0.43	3.54	47.11	0.33	16.60	10.37	1.09	76879.02
16	1.24	3.94	44.08	0.44	15.57	10.31	1.09	77231.23
17	2.52	3.79	50.42	0.21	17.06	10.38	1.09	80211.85
18	2.27	4.01	53.98	0.22	16.99	10.31	1.09	80460.58
19	2.35	7.34	59.28	0.32	16.46	10.71	1.08	78455.60
20	2.17	4.32	50.47	0.22	17.92	9.71	1.08	81506.59
21	2.25	3.96	49.86	0.41	15.90	10.36	1.07	79248.50
22	2.43	4.78	62.50	0.93	14.55	11.36	1.07	72243.64
23	2.57	4.89	61.41	0.62	15.24	11.77	1.09	71396.08
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	2.26	4.31	48.94	0.41	16.57	10.35	1.08	76668.13
最大值	4.69	13.08	62.50	0.93	18.16	11.77	1.10	81506.59
發生時間	0	7	22	22	1	23		20
最小值	0.11	2.26	40.14	0.21	14.55	9.59	1.06	71396.08
發生時間	13	5	6	1	22	6		23
零點偏移(率)	-0.10 %	-0.03 %	-0.04 %	0.00 %		-0.05		0.30 %
全幅偏移(率)	0.02 %	0.58 %	-0.07 %	0.46 %		-0.04		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								