

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月09日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.32	11.14	62.22	0.32	20.08	10.63	1.09	81558.64
1	9.23	14.72	49.06	1.14	18.19	11.54	1.08	76527.64
2	9.46	12.94	53.37	1.95	16.51	11.77	1.06	75166.70
3	6.52	4.24	54.63	2.12	15.83	11.93	1.07	75257.42
4	10.84	9.60	54.18	1.14	18.18	11.40	1.06	78852.87
5	6.85	10.07	47.09	1.31	17.09	12.31	1.07	73320.72
6	9.94	10.77	54.15	2.39	17.95	11.79	1.07	77136.67
7	7.48	13.10	65.45	1.03	18.70	11.94	1.08	75548.09
8	9.63	8.94	55.41	1.47	18.32	11.47	1.10	78882.33
9	9.44	12.47	60.24	1.99	17.33	11.98	1.11	75258.34
10	7.07	9.53	57.40	1.68	17.29	12.01	1.09	74672.94
11	8.95	15.24	49.36	1.98	18.54	11.25	1.09	78528.99
12	6.22	4.49	59.57	1.23	18.40	11.81	1.10	76554.95
13	7.07	6.17	53.15	1.65	17.35	11.81	1.10	76995.09
14	8.59	5.11	68.29	1.59	17.92	11.61	1.10	76432.02
15	9.18	4.98	50.77	1.98	16.83	11.62	1.08	76970.02
16	9.59	7.00	51.34	1.65	17.91	11.48	1.08	77412.29
17	8.29	8.66	46.23	1.80	17.27	11.58	1.07	74257.90
18	14.54	9.33	63.21	1.80	19.35	11.24	1.07	78711.13
19	9.05	10.60	50.47	1.77	18.56	11.30	1.09	78452.97
20	7.53	9.06	64.73	1.54	18.76	11.24	1.10	80099.40
21	10.02	12.01	52.43	3.96	18.02	11.54	1.11	77790.46
22	8.79	12.95	56.32	2.89	18.69	11.16	1.08	79333.56
23	8.57	12.53	46.37	1.59	18.07	11.29	1.06	77285.32
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.76	9.82	55.23	1.75	17.96	11.57	1.08	77125.27
最大值	14.54	15.24	68.29	3.96	20.08	12.31	1.15	81558.64
發生時間	18	11	14	21	0	5		0
最小值	6.22	4.24	46.23	0.32	15.83	10.63	1.05	73320.72
發生時間	12	3	17	0	3	0		5
零點偏移(率)	-0.07 %	0.00 %	-0.05 %	-0.02 %		0.01		0.00 %
全幅偏移(率)	-0.77 %	-3.97 %	-0.74 %	-2.04 %		0.02		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月09日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.48	4.90	54.95	1.22	19.22	9.86	1.10	85250.78
1	8.85	4.39	47.11	1.56	19.86	9.75	1.10	84960.74
2	8.22	13.53	65.21	2.24	15.96	10.61	1.10	82765.18
3	10.16	6.96	47.44	2.58	16.16	10.39	1.07	79786.76
4	8.91	5.80	54.87	2.19	17.15	10.38	1.08	81390.19
5	10.19	8.94	55.13	2.29	16.94	10.41	1.09	81575.92
6	7.26	7.73	54.74	1.73	18.59	9.82	1.06	79451.24
7	9.00	3.88	55.01	2.04	18.02	10.17	1.05	84118.52
8	9.19	3.93	56.59	2.18	17.13	10.27	1.06	82422.91
9	8.79	3.93	60.47	2.64	16.26	10.79	1.07	78388.26
10	8.94	5.97	48.38	1.58	18.22	10.63	1.08	80455.73
11	8.78	3.59	61.48	1.53	18.73	10.00	1.09	83902.63
12	8.76	4.25	55.27	1.62	19.50	9.80	1.08	84388.16
13	9.58	14.25	44.82	2.60	16.24	10.42	1.08	81017.43
14	9.38	5.72	58.92	1.61	17.75	10.27	1.07	81035.00
15	9.82	8.05	56.60	1.85	17.48	10.52	1.08	78867.90
16	8.27	5.70	58.57	1.01	18.45	9.75	1.09	86083.22
17	9.85	2.78	52.55	1.65	17.80	10.05	1.10	84795.00
18	8.49	2.84	63.30	0.79	19.74	10.38	1.08	79950.73
19	9.58	3.05	60.84	0.96	18.99	10.16	1.09	83004.58
20	9.91	3.58	55.98	1.79	17.98	9.99	1.08	85747.53
21	9.73	4.31	55.99	2.14	17.54	10.08	1.08	85241.90
22	9.88	9.51	54.65	2.93	16.56	10.49	1.06	83019.97
23	11.54	15.69	57.93	2.53	17.04	10.22	1.05	83992.77
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.23	6.39	55.70	1.89	17.80	10.22	1.08	82567.21
最大值	11.54	15.69	65.21	2.93	19.86	10.79	1.11	86083.22
發生時間	23	23	2	22	1	9		16
最小值	7.26	2.78	44.82	0.79	15.96	9.75	1.05	78388.26
發生時間	6	17	13	18	2	1		9
零點偏移(率)	-0.11 %	-0.06 %	-0.05 %	-0.01 %		0.03		0.00 %
全幅偏移(率)	1.28 %	-1.68 %	0.87 %	-2.79 %		-0.18		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月09日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.28	10.37	54.61	0.52	17.53	10.68	1.07	82433.86
1	0.22	3.23	55.45	0.65	17.02	11.22	1.08	80712.05
2	2.57	21.88	53.06	1.73	14.43	11.20	1.10	77830.99
3	0.65	3.05	34.47	0.73	16.29	10.31	1.09	75111.04
4	8.49	7.89	40.42	2.15	16.59	10.69	1.10	77573.11
5	0.17	11.48	49.71	0.97	15.72	11.16	1.10	75415.94
6	1.61	10.18	48.95	0.44	17.53	11.01	1.12	77705.45
7	0.11	9.12	49.64	0.85	17.37	10.25	1.10	92028.67
8	0.22	8.92	53.91	1.14	16.35	11.04	1.09	79140.92
9	2.47	12.11	52.14	1.40	16.80	10.80	1.06	80242.77
10	8.86	3.32	52.06	1.45	17.89	10.75	1.10	77897.83
11	12.00	9.48	47.70	1.83	17.14	10.64	1.06	79689.35
12	8.02	10.94	51.01	1.25	17.22	10.69	1.05	79548.90
13	6.40	4.02	50.74	1.64	15.93	11.49	1.06	77904.44
14	10.19	6.10	53.77	1.64	16.97	10.54	1.10	79090.98
15	8.88	6.92	45.63	1.62	16.19	10.75	1.10	77285.41
16	11.39	4.04	52.08	1.57	16.47	10.47	1.07	82044.60
17	12.62	5.45	51.91	2.04	14.95	10.97	1.08	79110.57
18	11.85	3.38	59.26	1.37	17.16	10.70	1.10	80965.53
19	8.10	4.34	67.74	1.08	17.09	11.31	1.07	77602.50
20	12.92	4.49	58.71	1.74	16.88	10.53	1.05	87300.25
21	13.33	9.38	44.19	3.60	15.75	10.37	1.07	80915.06
22	14.39	12.49	49.30	4.17	14.28	10.85	1.05	76178.39
23	12.78	9.83	43.51	3.95	14.92	10.96	1.02	77932.04
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.02	8.02	50.83	1.65	16.44	10.81	1.08	79652.53
最大值	14.39	21.88	67.74	4.17	17.89	11.49	1.16	92028.67
發生時間	22	2	19	22	10	13		7
最小值	0.11	3.05	34.47	0.44	14.28	10.25	1.02	75111.04
發生時間	7	3	3	6	22	7		3
零點偏移(率)	-0.11 %	-0.03 %	-0.05 %	-0.01 %		0.00		0.00 %
全幅偏移(率)	0.04 %	-3.12 %	-0.81 %	-2.03 %		0.05		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								