

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月01日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.65	9.02	56.23	0.98	17.72	11.63	1.06	72920.05
1	4.65	8.35	63.88	0.55	20.90	11.11	1.07	74189.67
2	8.65	7.79	51.82	0.59	21.44	10.13	1.07	80882.57
3	8.46	12.97	39.62	0.93	19.57	10.70	1.07	78288.67
4	8.62	9.50	53.02	1.10	19.16	11.19	1.07	75177.00
5	10.28	11.01	47.44	1.23	20.18	10.95	1.10	75314.81
6	8.22	8.38	49.52	1.08	19.13	11.15	1.09	75138.71
7	6.96	8.39	62.76	0.81	19.27	11.49	1.10	72201.19
8	7.57	7.63	58.33	0.61	20.58	10.65	1.12	77698.71
9	9.55	11.36	45.60	1.43	17.63	11.23	1.12	75345.52
10	9.50	9.34	45.99	1.46	18.78	11.05	1.10	76344.12
11	8.31	7.90	52.09	1.27	18.36	11.38	1.10	73330.36
12	8.68	6.56	50.66	1.17	18.62	11.04	1.12	76027.41
13	10.53	8.53	46.44	1.87	17.68	11.19	1.11	75422.32
14	13.33	9.91	49.88	2.13	16.92	11.55	1.10	73530.75
15	9.34	10.42	47.77	1.90	16.70	11.60	1.12	73722.44
16	9.35	7.89	47.57	1.40	17.81	11.20	1.10	76035.28
17	9.08	7.92	43.95	1.60	17.63	11.01	1.10	77924.05
18	9.89	8.59	53.40	1.52	18.12	11.16	1.10	75424.61
19	9.28	9.25	53.48	0.68	19.58	10.90	1.12	76626.09
20	7.90	8.72	61.41	0.57	20.74	10.54	1.12	78545.59
21	10.09	9.34	41.64	0.95	20.56	10.16	1.12	81226.18
22	9.20	5.97	46.82	1.30	19.89	10.48	1.12	78753.62
23	8.62	9.65	51.54	0.60	20.42	10.38	1.12	79251.67
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.90	8.93	50.87	1.16	19.06	10.99	1.10	76221.72
最大值	13.33	12.97	63.88	2.13	21.44	11.63	1.13	81226.18
發生時間	14	3	1	14	2	0		21
最小值	4.65	5.97	39.62	0.55	16.70	10.13	1.05	72201.19
發生時間	1	22	3	1	15	2		7
零點偏移(率)	-0.16 %	-0.01 %	-0.00 %	-0.00 %		0.03		0.00 %
全幅偏移(率)	0.01 %	0.01 %	-0.31 %	0.10 %		0.03		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月01日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.36	8.29	43.86	1.31	18.75	10.40	0.97	83039.42
1	2.53	5.07	53.03	1.29	19.76	10.43	0.99	82377.65
2	2.56	4.63	50.53	2.33	17.21	10.39	0.99	85285.39
3	1.44	3.34	56.46	2.11	16.40	10.87	0.99	82361.45
4	1.93	2.97	57.76	2.10	16.79	10.64	0.99	83849.38
5	8.84	6.56	53.95	2.91	16.02	10.77	0.99	83100.86
6	10.22	8.72	50.91	3.07	15.65	10.62	1.00	84740.74
7	6.66	5.40	52.13	2.37	16.21	10.64	1.01	83324.46
8	3.56	6.02	48.56	2.44	15.46	10.75	1.02	83191.19
9	0.65	2.54	54.82	1.88	16.09	10.56	0.99	84402.07
10	6.10	4.03	55.71	2.55	15.60	10.79	0.99	82778.15
11	6.68	3.16	58.51	2.20	15.33	11.30	1.01	78756.94
12	7.59	2.75	52.85	1.84	16.56	10.57	1.00	83538.13
13	12.74	6.19	54.17	3.20	14.41	11.03	1.02	81675.71
14	9.94	2.90	56.38	2.82	14.07	11.56	1.00	79528.11
15	11.57	7.64	58.71	2.39	14.97	10.97	0.99	82550.40
16	11.99	9.56	54.98	3.04	14.33	10.90	0.99	83351.10
17	7.53	6.09	56.91	3.05	13.81	11.12	0.99	82388.20
18	8.18	5.03	58.56	2.30	15.16	10.73	0.99	84096.97
19	8.97	3.46	47.53	1.85	16.61	10.38	0.99	84897.00
20	8.46	3.91	48.75	1.54	17.09	10.13	0.99	85867.08
21	8.10	5.05	49.18	1.98	16.00	10.51	0.99	84729.10
22	8.86	7.20	58.30	2.19	16.01	10.61	0.99	84602.60
23	8.52	5.56	54.57	1.83	16.32	10.74	0.98	83398.30
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.96	5.25	53.63	2.27	16.03	10.73	0.99	83242.93
最大值	12.74	9.56	58.71	3.20	19.76	11.56	1.02	85867.08
發生時間	13	16	15	13	1	14		20
最小值	0.65	2.54	43.86	1.29	13.81	10.13	0.97	78756.94
發生時間	9	9	0	1	17	20		11
零點偏移(率)	-0.06 %	-0.02 %	-0.01 %	-0.05 %		0.05		-0.20 %
全幅偏移(率)	0.02 %	0.19 %	-0.01 %	0.11 %		-0.09		-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月01日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.79	3.86	54.91	1.19	16.04	11.08	0.95	80673.20
1	6.28	5.60	55.54	1.17	16.09	11.65	0.94	75756.60
2	7.07	8.78	58.26	1.43	16.69	11.04	0.94	81227.08
3	7.35	3.14	43.82	1.65	15.90	10.65	0.94	81329.63
4	7.34	4.22	46.80	1.46	15.57	11.01	0.94	78553.48
5	5.31	3.50	52.17	1.26	16.02	10.95	0.94	79324.01
6	5.58	4.34	54.48	1.63	15.21	11.19	0.94	78698.65
7	1.53	3.87	48.49	1.47	14.85	11.29	0.94	82347.38
8	1.86	3.18	57.82	1.10	15.67	11.34	0.94	77982.89
9	4.99	3.82	49.33	1.46	15.41	11.02	0.95	79453.30
10	8.72	5.53	49.96	2.09	14.88	10.98	0.94	80608.39
11	6.26	5.38	47.91	2.26	13.96	10.99	0.91	73866.31
12	3.65	5.95	44.81	2.10	13.85	11.00	0.91	73371.55
13	6.21	3.43	52.62	2.13	13.94	11.03	0.93	73217.62
14	11.15	6.44	51.90	2.82	13.19	11.17	0.94	71999.36
15	8.41	7.42	51.53	2.56	13.04	11.15	0.92	72305.73
16	8.75	6.57	50.03	2.95	12.65	11.35	0.91	74441.92
17	9.25	3.22	54.67	2.04	14.08	11.30	0.93	76351.98
18	13.07	5.11	54.50	2.50	14.21	11.03	0.94	79203.28
19	11.32	6.34	60.56	4.66	14.30	11.31	0.94	78444.58
20	9.48	6.01	49.64	2.07	15.44	10.78	0.94	82205.56
21	10.65	5.11	53.76	1.64	15.71	10.93	0.94	82597.87
22	7.84	9.97	48.11	1.80	14.46	11.00	0.94	76642.14
23	10.71	8.13	55.37	1.40	16.08	10.37	0.96	82552.60
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.52	5.37	51.96	1.95	14.88	11.07	0.94	78048.13
最大值	13.07	9.97	60.56	4.66	16.69	11.65	0.97	82597.87
發生時間	18	22	19	19	2	1		21
最小值	1.53	3.14	43.82	1.10	12.65	10.37	0.91	71999.36
發生時間	7	3	3	8	16	23		14
零點偏移(率)	-0.04 %	0.00 %	-0.02 %	0.00 %		0.01		0.00 %
全幅偏移(率)	-0.64 %	-0.36 %	-0.77 %	-0.06 %		0.17		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								