

## P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年09月02日

| 項目<br>單位<br>小時\限標 | #1-HCl_C | #1-CO_C  | #1-NOx_C | #1-SO2_C | #1-H2O   | #1-O2_C  | #1-OPAC  | #1-FLOW_C |
|-------------------|----------|----------|----------|----------|----------|----------|----------|-----------|
|                   | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
|                   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0                 | 1.51     | 4.20     | 58.61    | 1.52     | 17.78    | 11.69    | 0.92     | 79687.69  |
| 1                 | 2.03     | 4.03     | 57.05    | 1.59     | 18.66    | 11.22    | 0.92     | 82876.58  |
| 2                 | 3.79     | 5.66     | 64.50    | 1.83     | 18.97    | 11.62    | 0.93     | 79489.14  |
| 3                 | 2.15     | 5.81     | 58.19    | 1.82     | 17.02    | 11.78    | 0.93     | 79897.85  |
| 4                 | 3.00     | 9.51     | 50.07    | 2.31     | 16.76    | 11.69    | 0.92     | 78190.61  |
| 5                 | 6.68     | 3.52     | 51.79    | 1.37     | 16.35    | 11.74    | 0.91     | 78894.73  |
| 6                 | 5.81     | 2.77     | 60.93    | 1.14     | 18.19    | 11.51    | 0.90     | 78760.39  |
| 7                 | 6.24     | 2.46     | 42.88    | 0.74     | 17.83    | 11.33    | 0.90     | 80711.07  |
| 8                 | 4.56     | 2.54     | 37.49    | 1.24     | 17.11    | 11.86    | 0.90     | 78154.86  |
| 9                 | 6.08     | 2.46     | 40.77    | 1.23     | 17.91    | 11.54    | 0.92     | 80324.04  |
| 10                | 6.25     | 2.60     | 36.70    | 1.28     | 17.43    | 11.69    | 0.90     | 78787.76  |
| 11                | 5.34     | 4.98     | 41.92    | 0.82     | 17.85    | 11.93    | 0.91     | 75644.08  |
| 12                | 5.80     | 3.02     | 50.61    | 1.19     | 16.07    | 12.17    | 0.91     | 76926.57  |
| 13                | 3.37     | 2.86     | 40.00    | 0.88     | 18.07    | 11.72    | 0.92     | 78762.58  |
| 14                | 1.65     | 2.62     | 40.43    | 0.66     | 17.95    | 11.76    | 0.92     | 78141.34  |
| 15                | 4.65     | 2.43     | 42.09    | 0.92     | 17.62    | 11.66    | 0.92     | 79619.74  |
| 16                | 6.87     | 2.41     | 43.19    | 0.90     | 18.35    | 11.29    | 0.92     | 82281.20  |
| 17                | 8.49     | 2.54     | 44.83    | 1.06     | 17.65    | 11.14    | 0.91     | 84383.69  |
| 18                | 8.24     | 2.63     | 44.98    | 0.78     | 18.46    | 11.13    | 0.91     | 84143.49  |
| 19                | 9.07     | 2.40     | 47.51    | 0.93     | 17.55    | 11.28    | 0.90     | 83885.08  |
| 20                | 7.80     | 3.23     | 37.00    | 1.45     | 16.18    | 11.68    | 0.91     | 81865.26  |
| 21                | 9.18     | 4.23     | 49.84    | 1.21     | 16.90    | 11.69    | 0.92     | 80869.14  |
| 22                | 8.34     | 4.42     | 55.51    | 1.02     | 17.22    | 11.71    | 0.90     | 80540.36  |
| 23                | 10.43    | 5.28     | 55.22    | 1.23     | 16.93    | 11.56    | 0.90     | 81985.62  |
| 監測時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數              | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平 均 值             | 5.72     | 3.69     | 48.00    | 1.21     | 17.53    | 11.60    | 0.91     | 80200.95  |
| 最 大 值             | 10.43    | 9.51     | 64.50    | 2.31     | 18.97    | 12.17    | 0.94     | 84383.69  |
| 發生時間              | 23       | 4        | 2        | 4        | 2        | 12       |          | 17        |
| 最 小 值             | 1.51     | 2.40     | 36.70    | 0.66     | 16.07    | 11.13    | 0.90     | 75644.08  |
| 發生時間              | 0        | 19       | 10       | 14       | 12       | 18       |          | 11        |
| 零點偏移(率)           | -0.16 %  | -0.00 %  | -0.21 %  | 0.00 %   |          | -0.07    |          | 0.00 %    |
| 全幅偏移(率)           | 0.00 %   | 0.23 %   | 0.66 %   | 0.62 %   |          | -0.10    |          | 0.10 %    |
| 有效比率              | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註                |          |          |          |          |          |          |          |           |



P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年09月02日

| 項目<br>單位<br>小時\限標 | #3-HCl_C<br>ppm | #3-CO_C<br>ppm | #3-NOx_C<br>ppm | #3-SO2_C<br>ppm | #3-H2O<br>% | #3-O2_C<br>% | #3-OPAC<br>% | #3-FLOW_C<br>m3/Hour |
|-------------------|-----------------|----------------|-----------------|-----------------|-------------|--------------|--------------|----------------------|
| 0                 | 3.57            | 3.79           | 55.57           | 1.39            | 16.21       | 11.04        | 1.83         | 75906.53             |
| 1                 | 2.10            | 3.57           | 59.33           | 1.38            | 17.55       | 10.98        | 1.83         | 76935.66             |
| 2                 | 1.97            | 3.82           | 61.72           | 1.21            | 18.12       | 10.94        | 1.82         | 78056.27             |
| 3                 | 5.37            | 4.33           | 53.41           | 1.35            | 17.36       | 10.71        | 1.81         | 80554.82             |
| 4                 | 10.19           | 4.16           | 54.11           | 1.99            | 16.05       | 10.91        | 1.81         | 77782.41             |
| 5                 | 10.94           | 3.61           | 54.80           | 1.92            | 16.01       | 10.83        | 1.79         | 77206.62             |
| 6                 | 9.95            | 4.41           | 58.03           | 1.74            | 17.61       | 10.62        | 1.81         | 78442.91             |
| 7                 | 8.47            | 2.89           | 40.93           | 0.53            | 17.68       | 10.47        | 1.84         | 80426.09             |
| 8                 | 11.23           | 2.18           | 46.05           | 0.91            | 17.63       | 10.60        | 1.81         | 78849.53             |
| 9                 | 8.53            | 2.45           | 42.11           | 0.42            | 16.29       | 10.99        | 1.84         | 72857.91             |
| 10                | 6.51            | 2.45           | 44.86           | 0.18            | 17.86       | 10.74        | 1.81         | 74748.14             |
| 11                | 8.26            | 2.18           | 43.13           | 0.28            | 17.78       | 10.59        | 1.80         | 75644.74             |
| 12                | 9.26            | 2.16           | 41.34           | 0.48            | 16.32       | 10.98        | 1.82         | 72482.55             |
| 13                | 3.56            | 2.14           | 49.12           | 0.38            | 16.57       | 11.17        | 1.79         | 73089.01             |
| 14                | 3.89            | 2.43           | 44.52           | 0.31            | 16.94       | 11.16        | 1.78         | 75755.43             |
| 15                | 6.15            | 2.75           | 49.48           | 0.32            | 17.72       | 11.19        | 1.77         | 76024.30             |
| 16                | 4.17            | 2.25           | 51.82           | 0.51            | 18.04       | 10.66        | 1.82         | 80952.75             |
| 17                | 3.37            | 2.15           | 46.27           | 0.33            | 16.45       | 10.90        | 1.79         | 79275.27             |
| 18                | 1.95            | 2.39           | 52.17           | 0.21            | 17.74       | 10.61        | 1.80         | 81536.65             |
| 19                | 4.68            | 2.42           | 52.30           | 0.37            | 16.90       | 10.79        | 1.82         | 80792.44             |
| 20                | 1.85            | 2.21           | 53.64           | 0.25            | 16.98       | 10.81        | 1.79         | 80676.96             |
| 21                | 10.10           | 3.81           | 51.52           | 0.46            | 16.29       | 10.85        | 1.80         | 80651.76             |
| 22                | 6.28            | 3.66           | 58.19           | 0.83            | 14.68       | 11.53        | 1.82         | 74848.65             |
| 23                | 6.60            | 3.30           | 59.87           | 0.58            | 15.20       | 11.46        | 1.85         | 74934.84             |
| 監測時數              | 24              | 24             | 24              | 24              | 24          | 24           | 24           | 24                   |
| 超限次數              | 0               | 0              | 0               | 0               | 0           | 0            | 0            | 0                    |
| 有效時數              | 24              | 24             | 24              | 24              | 24          | 24           | 24           | 24                   |
| 平 均 值             | 6.21            | 2.98           | 51.01           | 0.76            | 16.92       | 10.90        | 1.81         | 77434.68             |
| 最 大 值             | 11.23           | 4.41           | 61.72           | 1.99            | 18.12       | 11.53        | 1.85         | 81536.65             |
| 發生時間              | 8               | 6              | 2               | 4               | 2           | 22           |              | 18                   |
| 最 小 值             | 1.85            | 2.14           | 40.93           | 0.18            | 14.68       | 10.47        | 1.76         | 72482.55             |
| 發生時間              | 20              | 13             | 7               | 10              | 22          | 7            |              | 12                   |
| 零點偏移(率)           | 0.00 %          | -0.00 %        | -0.42 %         | 0.00 %          |             | -0.11        |              | 0.00 %               |
| 全幅偏移(率)           | 0.02 %          | -0.22 %        | 0.81 %          | 0.28 %          |             | 0.05         |              | 0.20 %               |
| 有效比率              | 100.00 %        | 100.00 %       | 100.00 %        | 100.00 %        | 100.00 %    | 100.00 %     | 100.00 %     | 100.00 %             |
| 備註                |                 |                |                 |                 |             |              |              |                      |