

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年10月10日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.92	13.37	61.30	2.11	16.20	11.70	1.24	78670.64
1	8.72	12.81	49.67	2.44	17.69	11.06	1.23	82583.72
2	12.59	13.45	53.34	3.99	16.50	11.64	1.23	78464.31
3	9.10	13.13	56.45	3.19	16.47	11.45	1.23	80590.70
4	5.64	13.44	65.85	1.91	17.34	11.60	1.23	78715.33
5	12.31	13.10	50.96	2.56	17.52	11.21	1.23	81805.27
6	9.63	13.20	58.82	2.39	17.29	11.46	1.23	79700.28
7	10.02	12.62	62.36	3.53	15.91	11.16	1.24	83596.84
8	9.61	13.17	56.54	3.06	16.85	11.49	1.23	79717.91
9	9.04	13.14	56.37	3.11	16.32	11.53	1.21	80223.99
10	6.66	13.34	56.82	3.20	15.79	11.75	1.22	78392.27
11	7.68	13.14	54.78	3.61	14.99	11.62	1.21	79615.81
12	7.72	14.32	54.64	3.86	14.90	11.72	1.22	78024.97
13	9.87	13.59	52.53	3.50	15.34	11.51	1.22	79772.66
14	11.86	13.19	62.19	4.47	14.81	11.64	1.20	79325.68
15	9.54	13.86	53.76	3.94	14.68	11.44	1.20	80354.44
16	8.81	13.15	49.30	2.53	14.57	11.42	1.19	76654.02
17	8.54	12.77	55.93	1.43	16.19	11.58	1.19	77502.32
18	8.42	13.62	45.89	2.30	18.57	10.44	1.19	83349.32
19	9.88	13.01	59.24	2.39	15.64	11.16	1.18	80223.23
20	6.17	14.39	37.82	2.27	15.22	11.71	1.19	75701.78
21	8.10	13.13	44.31	2.46	16.07	11.42	1.19	77116.16
22	9.93	12.78	48.01	3.16	16.14	11.30	1.19	77151.98
23	8.58	13.49	52.48	2.71	16.06	11.80	1.19	72617.55
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.97	13.30	54.14	2.92	16.13	11.45	1.21	79161.30
最 大 值	12.59	14.39	65.85	4.47	18.57	11.80	1.25	83596.84
發生時間	2	20	4	14	18	23		7
最 小 值	5.64	12.62	37.82	1.43	14.57	10.44	1.18	72617.55
發生時間	4	7	20	17	16	18		23
零點偏移(率)	-0.31 %	-0.00 %	-0.01 %	-0.01 %		0.03		0.20 %
全幅偏移(率)	-0.60 %	0.52 %	0.22 %	0.28 %		0.01		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年10月10日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.29	12.87	51.20	0.75	16.54	11.06	1.46	78897.00
1	6.72	12.61	42.73	0.60	18.76	10.24	1.44	79545.29
2	7.04	11.68	57.74	0.65	18.37	9.96	1.43	79015.70
3	7.69	13.00	57.34	1.07	18.87	9.40	1.44	84404.30
4	8.73	11.29	63.36	0.85	17.18	10.06	1.45	80122.23
5	9.43	11.32	62.87	0.95	17.19	10.09	1.46	80382.92
6	9.33	11.19	64.86	0.85	17.59	9.94	1.48	79099.53
7	8.16	11.26	58.76	0.92	17.27	10.49	1.44	81815.56
8	9.98	10.33	39.42	0.80	17.65	10.08	1.42	81228.44
9	6.18	10.50	41.72	0.74	16.48	10.57	1.45	77645.97
10	9.34	10.08	37.00	1.25	16.69	9.72	1.40	79978.57
11	8.83	10.60	32.71	1.58	16.43	8.89	1.43	76494.34
12	9.24	10.42	41.41	1.23	16.76	8.96	1.43	73630.88
13	11.05	3.74	42.34	0.67	15.79	9.69	1.40	73197.04
14	10.90	5.51	51.07	1.05	14.91	10.06	1.39	69934.87
15	10.60	10.26	46.64	1.47	16.37	9.58	1.37	72595.69
16	8.55	11.38	45.18	1.35	15.26	9.68	1.42	72420.96
17	6.03	11.34	58.97	1.34	14.68	10.46	1.39	70928.06
18	5.84	12.40	59.62	0.97	15.99	11.00	1.42	75344.31
19	8.03	12.86	60.38	0.73	17.11	10.43	1.43	76908.48
20	8.92	12.90	51.60	0.94	16.09	10.23	1.40	77107.04
21	9.44	12.91	59.90	0.87	16.52	10.20	1.39	76512.22
22	9.70	12.90	53.03	0.67	17.50	9.77	1.39	79740.92
23	9.14	12.61	56.26	0.57	17.47	9.97	1.41	78738.43
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.63	11.08	51.50	0.95	16.81	10.02	1.42	77320.36
最 大 值	11.05	13.00	64.86	1.58	18.87	11.06	1.48	84404.30
發生時間	13	3	6	11	3	0		3
最 小 值	5.84	3.74	32.71	0.57	14.68	8.89	1.36	69934.87
發生時間	18	13	11	23	17	11		14
零點偏移(率)	-0.12 %	-0.00 %	-0.04 %	-0.01 %		-0.03		0.00 %
全幅偏移(率)	-0.35 %	0.18 %	-0.11 %	0.14 %		0.38		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								