

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年09月23日

報表日期: 114年09月23日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.76	11.78	52.99	2.16	16.57	11.32	1.25	82336.05
1	6.66	12.65	65.02	2.29	16.62	11.91	1.25	77032.21
2	13.62	12.14	60.26	2.54	16.57	10.90	1.25	86430.33
3	10.33	12.45	44.87	2.48	16.15	11.49	1.25	81301.00
4	8.21	13.69	47.09	2.88	14.96	11.78	1.25	79598.47
5	12.53	12.79	70.35	2.58	15.93	11.58	1.22	77076.89
6	7.72	13.55	55.22	2.29	15.60	11.83	1.23	78509.97
7	11.77	13.16	65.06	2.40	15.52	11.62	1.24	80954.54
8	10.32	15.93	54.45	3.48	13.42	12.00	1.24	77780.18
9	9.68	13.38	56.67	2.84	14.76	11.85	1.23	76932.44
10	6.61	13.60	60.08	2.35	15.45	11.96	1.23	77282.54
11	4.27	13.43	58.95	2.93	14.68	11.98	1.24	78751.64
12	9.14	13.25	61.13	2.75	15.35	11.78	1.23	79730.73
13	7.40	13.09	61.65	2.73	15.31	11.69	1.23	80378.60
14	8.79	13.35	64.79	2.87	15.03	11.90	1.23	79549.98
15	8.61	13.38	67.72	2.73	16.17	11.73	1.23	79904.31
16	13.04	12.92	53.13	3.09	15.61	11.51	1.23	81763.37
17	13.48	13.13	50.43	3.46	15.43	11.39	1.24	83476.18
18	7.14	13.19	52.86	2.62	15.80	11.60	1.24	80904.05
19	11.38	12.65	52.06	2.66	16.67	11.15	1.25	84595.94
20	11.83	13.11	51.06	3.32	14.86	11.70	1.24	80782.34
21	16.02	13.21	59.06	3.07	16.72	11.41	1.24	81965.96
22	14.61	13.01	50.74	3.04	15.35	11.57	1.24	81186.36
23	7.67	12.89	51.81	4.06	16.44	11.35	1.25	82495.32
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.86	13.16	56.98	2.82	15.62	11.63	1.24	80446.64
最 大 值	16.02	15.93	70.35	4.06	16.72	12.00	1.26	86430.33
發生時間	21	8	5	23	21	8		2
最 小 值	4.27	11.78	44.87	2.16	13.42	10.90	1.20	76932.44
發生時間	11	0	3	0	8	2		9
零點偏移(率)	-0.08 %	-0.04 %	-0.01 %	-0.03 %		-0.01		0.10 %
全幅偏移(率)	0.00 %	-0.02 %	0.40 %	0.22 %		-0.01		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年09月23日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.56	13.77	54.76	1.69	16.74	11.18	0.97	80787.17
1	3.95	14.17	57.56	2.13	16.63	11.45	0.97	77618.22
2	2.82	14.08	51.27	2.63	15.89	11.27	0.98	80695.28
3	4.81	14.18	58.98	2.03	16.37	11.42	0.99	79081.86
4	5.40	14.42	62.43	1.90	16.72	11.60	0.99	77377.89
5	5.55	14.12	49.32	1.85	17.25	11.33	0.97	78527.98
6	3.88	13.28	48.02	2.22	17.06	11.53	1.02	81258.37
7	6.83	13.35	44.48	2.44	16.94	10.90	1.00	82673.95
8	6.71	12.69	58.79	2.56	15.72	11.37	1.01	79442.42
9	5.81	13.63	58.01	2.87	15.52	11.26	1.02	81148.07
10	4.02	12.96	56.40	2.25	15.44	11.58	1.02	76660.38
11	6.24	12.59	57.64	1.67	17.47	11.09	1.02	79590.82
12	6.35	13.62	50.19	2.12	16.40	11.16	1.02	79950.63
13	9.98	13.00	58.89	2.86	15.58	11.40	1.02	78772.37
14	7.76	12.63	54.76	1.90	16.76	11.12	1.02	78578.01
15	11.80	12.32	54.04	2.12	16.40	11.01	1.03	81953.01
16	14.63	12.37	52.30	2.96	15.47	11.12	1.03	77940.83
17	3.85	11.93	49.11	1.57	17.22	10.37	1.02	82350.28
18	9.28	12.25	54.55	1.78	17.06	10.49	1.02	81896.84
19	11.91	11.93	50.12	1.88	16.68	10.41	1.03	80546.36
20	5.89	11.86	56.04	1.47	17.46	10.43	1.03	80165.54
21	13.20	12.14	56.96	3.17	17.42	10.55	1.03	82997.67
22	12.34	11.73	62.96	2.12	17.20	10.87	1.04	81013.05
23	9.22	13.35	57.02	1.64	17.22	10.93	1.04	82500.30
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.41	13.02	54.77	2.16	16.61	11.08	1.01	80146.97
最 大 值	14.63	14.42	62.96	3.17	17.47	11.60	1.04	82997.67
發生時間	16	4	22	21	11	4		21
最 小 值	2.82	11.73	44.48	1.47	15.44	10.37	0.95	76660.38
發生時間	2	22	7	20	10	17		10
零點偏移(率)	-0.09 %	-0.00 %	-0.10 %	0.01 %		-0.03		-0.10 %
全幅偏移(率)	0.89 %	0.31 %	1.26 %	-0.08 %		-0.38		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年09月23日

[illegible]