

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月20日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.03	5.05	47.73	0.48	18.98	10.73	1.03	76452.93
1	4.41	5.25	50.41	0.52	20.34	10.72	1.05	75841.52
2	9.10	8.12	42.16	1.73	17.57	11.09	1.04	73763.96
3	8.84	5.30	59.81	0.77	18.45	11.18	1.03	74609.82
4	8.95	8.47	46.38	0.81	19.30	10.63	1.02	77576.45
5	10.59	6.38	32.75	1.06	19.06	10.45	1.02	76805.36
6	6.70	9.41	49.23	0.58	19.67	11.10	1.04	72644.66
7	5.07	8.60	47.89	0.29	20.69	10.53	1.05	76470.41
8	4.74	8.71	54.03	0.43	19.60	11.18	1.05	72340.61
9	7.89	2.37	48.76	0.84	20.93	10.25	1.05	78436.52
10	2.12	6.79	37.16	1.69	18.96	10.72	1.06	77127.35
11	6.93	5.95	42.55	1.98	18.82	11.07	1.06	74568.60
12	8.78	4.02	56.79	0.34	19.70	11.06	1.05	74684.96
13	9.89	4.81	44.10	0.94	19.01	10.98	1.05	75739.56
14	10.50	5.55	40.92	1.56	17.94	11.49	1.05	72525.81
15	7.36	4.22	62.51	0.58	19.12	11.30	1.07	73660.10
16	7.26	4.53	54.77	0.56	19.20	11.27	1.04	74060.10
17	8.00	4.40	57.32	0.56	18.95	10.93	1.01	77114.00
18	7.27	5.84	59.01	0.62	18.64	11.16	1.00	74973.88
19	4.75	5.36	65.70	0.36	19.69	11.47	1.04	72288.32
20	0.12	5.16	42.71	0.31	18.87	11.73	1.08	70774.53
21	1.18	6.23	41.56	0.39	19.54	11.00	1.04	75722.80
22	8.86	5.32	46.38	0.70	19.60	10.49	1.02	79204.29
23	7.75	5.99	47.79	1.12	17.44	11.48	1.02	73774.97
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.67	5.91	49.10	0.80	19.17	11.00	1.04	75048.40
最大值	10.59	9.41	65.70	1.98	20.93	11.73	1.14	79204.29
發生時間	5	6	19	11	9	20		22
最小值	0.12	2.37	32.75	0.29	17.44	10.25	0.99	70774.53
發生時間	20	9	5	7	23	9		20
零點偏移(率)	-0.02 %	-0.04 %	-0.03 %	0.00 %		-0.09		0.00 %
全幅偏移(率)	-1.30 %	0.00 %	-0.02 %	0.01 %		0.07		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月20日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.95	8.17	48.68	1.25	19.98	9.57	1.04	87308.81
1	2.20	5.58	48.88	1.86	19.86	9.75	1.02	86558.45
2	8.88	7.57	66.25	3.38	16.76	10.54	1.01	83478.12
3	2.52	2.36	56.70	1.41	19.76	10.12	1.03	84533.01
4	4.93	4.61	54.63	3.08	16.50	10.28	1.02	85979.61
5	6.37	4.03	56.62	2.77	16.03	10.39	1.03	86186.74
6	8.16	6.33	63.95	1.43	18.52	10.10	1.05	86257.51
7	7.18	5.78	54.20	1.53	18.66	9.63	1.05	89051.53
8	8.45	3.95	58.94	2.30	17.29	10.22	1.05	85996.14
9	8.16	7.88	59.23	3.17	16.64	10.28	1.05	86128.50
10	5.81	2.84	59.72	1.97	17.11	10.54	1.05	84027.59
11	4.23	2.46	56.06	1.73	17.99	10.24	1.06	85074.67
12	7.34	8.79	53.69	3.19	16.38	10.53	1.05	84295.94
13	2.76	4.52	58.09	2.09	17.82	10.29	1.04	84716.73
14	9.17	10.32	56.44	3.93	15.25	10.60	1.03	84944.34
15	7.71	5.95	60.28	3.36	14.66	10.95	1.00	82793.26
16	7.89	2.30	58.88	2.95	16.44	10.56	1.03	84302.10
17	3.98	2.94	59.23	2.35	17.47	10.18	1.03	86702.37
18	5.36	10.37	59.00	3.06	17.18	10.11	1.02	87047.79
19	3.48	1.97	60.08	2.10	17.77	10.16	0.99	86754.32
20	5.47	1.64	52.18	1.91	18.09	9.80	1.00	89038.17
21	1.14	5.30	57.67	2.62	16.37	10.65	1.00	84052.76
22	6.65	9.61	60.31	3.49	15.53	10.57	1.00	85198.87
23	7.56	6.32	59.87	3.25	15.30	10.84	0.99	83706.81
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.89	5.48	57.48	2.51	17.22	10.29	1.03	85588.92
最大值	9.17	10.37	66.25	3.93	19.98	10.95	1.07	89051.53
發生時間	14	18	2	14	0	15		7
最小值	1.14	1.64	48.68	1.25	14.66	9.57	0.99	82793.26
發生時間	21	20	0	0	15	0		15
零點偏移(率)	-0.01 %	-0.03 %	-0.01 %	-0.07 %		-0.04		-0.20 %
全幅偏移(率)	0.02 %	1.07 %	0.07 %	0.68 %		-0.13		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月20日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.26	9.33	43.00	0.47	17.64	10.17	1.03	80181.40
1	6.63	8.85	43.97	0.62	18.15	10.23	1.05	81559.44
2	6.81	9.14	42.66	1.18	15.57	10.67	1.05	76944.29
3	7.59	4.11	52.88	1.61	15.12	10.72	1.04	79621.70
4	9.20	5.93	53.29	1.36	15.57	11.02	1.05	81088.20
5	8.77	8.18	57.00	1.49	15.20	10.87	1.05	80065.63
6	9.47	8.84	47.51	1.23	16.63	10.53	1.03	79074.59
7	10.14	8.18	44.69	1.44	16.70	10.10	1.02	83098.86
8	7.69	8.14	48.72	1.16	16.17	10.48	1.05	79714.61
9	5.72	3.07	46.17	0.79	17.45	10.10	1.03	79013.46
10	5.98	2.84	39.51	0.83	16.14	10.47	1.02	78533.51
11	4.62	2.28	45.65	1.04	16.01	10.50	1.01	77599.36
12	3.19	1.83	48.64	0.74	16.21	10.47	0.99	75882.42
13	6.06	5.10	34.96	1.07	16.03	10.08	1.00	78026.05
14	9.23	4.42	41.30	1.65	15.21	10.46	0.99	77774.82
15	11.02	5.20	48.35	2.77	13.89	10.60	1.01	74750.72
16	8.92	4.61	50.28	1.99	14.52	10.54	0.99	78569.92
17	9.32	3.08	47.12	1.34	15.96	10.54	0.99	78248.08
18	5.60	2.58	52.81	0.94	16.47	10.82	1.01	78102.26
19	4.04	3.63	48.20	0.88	16.27	10.66	1.01	82700.10
20	3.02	3.45	59.68	0.74	17.17	10.63	1.00	86378.29
21	7.32	6.72	47.13	1.12	15.95	10.88	1.02	82213.58
22	7.96	9.78	52.89	1.45	15.15	11.15	1.00	78520.89
23	9.39	6.05	60.04	1.51	15.91	10.87	0.99	83368.47
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.21	5.64	48.19	1.23	16.05	10.57	1.02	79626.28
最大值	11.02	9.78	60.04	2.77	18.15	11.15	1.05	86378.29
發生時間	15	22	23	15	1	22		20
最小值	3.02	1.83	34.96	0.47	13.89	10.08	0.98	74750.72
發生時間	20	12	13	0	15	13		15
零點偏移(率)	-0.04 %	-0.01 %	-0.04 %	-0.02 %		-0.01		0.00 %
全幅偏移(率)	0.04 %	-0.02 %	-0.75 %	0.26 %		0.37		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								