

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月02日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.96	6.98	52.79	1.14	18.25	11.17	1.06	83581.39
1	3.83	7.14	57.42	1.13	18.61	11.69	1.08	78949.66
2	4.64	6.25	59.06	1.13	16.79	11.74	1.06	80000.82
3	5.01	7.00	40.81	1.27	16.76	11.37	1.06	83720.42
4	6.30	9.12	46.06	1.73	16.72	11.57	1.06	80739.14
5	5.58	5.64	55.80	0.70	17.44	11.61	1.02	79972.92
6	7.48	5.31	63.79	1.03	17.38	11.34	1.02	82863.08
7	10.42	5.99	55.90	1.76	16.46	11.48	1.04	82557.03
8	11.03	6.04	52.99	2.30	15.76	11.71	1.06	81273.93
9	9.20	6.71	62.08	1.38	17.38	11.48	1.03	81932.14
10	11.57	7.23	60.43	1.82	16.92	11.24	1.04	84410.51
11	11.70	7.33	45.34	2.61	14.77	11.97	1.03	79412.50
12	9.77	4.31	51.00	2.38	14.80	11.88	1.02	79191.91
13	9.73	4.70	49.81	2.05	14.79	11.87	1.03	78838.63
14	5.92	4.89	43.35	2.93	13.81	12.02	1.02	77459.70
15	6.43	7.11	55.72	2.33	15.24	12.25	1.02	75769.13
16	9.86	6.18	46.86	2.48	15.18	11.71	1.04	81422.45
17	8.28	5.01	51.83	1.34	16.05	11.87	1.03	79980.31
18	5.11	4.78	67.12	1.02	16.76	11.72	1.01	80588.57
19	9.03	4.73	49.61	1.99	15.98	11.35	0.99	84056.03
20	9.96	4.59	58.15	1.95	16.24	11.46	0.99	82837.04
21	5.92	4.80	61.00	1.45	16.01	11.91	0.99	79293.68
22	6.43	6.09	71.41	1.78	15.83	12.80	1.00	71014.84
23	6.96	6.47	48.97	0.91	17.05	11.66	1.01	80520.17
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.84	6.02	54.47	1.69	16.29	11.70	1.03	80432.75
最大值	11.70	9.12	71.41	2.93	18.61	12.80	1.09	84410.51
發生時間	11	4	22	14	1	22		10
最小值	3.83	4.31	40.81	0.70	13.81	11.17	0.99	71014.84
發生時間	1	12	3	5	14	0		22
零點偏移(率)	-0.03 %	-0.11 %	-0.00 %	-0.04 %		-0.01		0.10 %
全幅偏移(率)	0.00 %	1.14 %	-0.21 %	0.23 %		0.00		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月02日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.55	5.30	46.77	1.79	17.81	10.98	1.04	79610.95
1	2.90	3.54	45.29	2.45	16.94	11.31	1.04	77606.75
2	2.72	2.83	55.87	2.14	16.49	11.32	1.05	78335.12
3	2.98	2.88	54.18	2.12	16.16	11.63	1.05	75797.35
4	2.60	3.06	59.99	1.89	16.55	11.70	1.05	74762.62
5	2.40	3.17	53.84	2.14	16.66	11.02	1.04	79652.19
6	4.46	3.80	51.37	2.07	16.68	11.10	1.06	78213.38
7	8.38	4.54	56.50	3.05	16.16	11.67	1.06	76141.84
8	8.35	4.39	43.95	2.95	16.45	11.52	1.04	78924.57
9	10.15	4.21	43.83	3.65	14.86	11.87	1.02	78816.73
10	11.07	4.83	56.51	3.12	15.29	11.96	1.02	78345.67
11	9.96	4.93	60.01	2.75	14.78	12.12	1.04	77397.38
12	7.51	7.52	59.33	3.42	13.97	12.33	1.02	76697.10
13	3.59	9.01	59.22	3.60	13.18	12.52	1.02	75573.28
14	12.47	7.66	54.34	2.94	13.97	12.17	1.02	77349.13
15	8.53	5.81	54.28	1.92	13.17	12.46	1.02	76299.38
16	8.49	6.21	59.33	1.41	15.32	12.17	1.02	76049.85
17	8.70	4.59	56.90	1.16	17.51	11.29	1.02	81420.81
18	4.20	5.36	63.41	0.92	17.44	11.17	1.04	79253.51
19	10.20	5.98	54.71	1.44	16.22	10.79	1.05	82909.10
20	7.83	3.08	54.22	1.17	16.78	10.79	1.06	81430.82
21	9.89	3.22	59.88	1.35	16.33	11.16	1.06	78779.48
22	7.21	3.15	60.03	1.40	16.10	11.37	1.06	77909.79
23	0.32	9.16	47.08	2.11	16.29	11.77	1.05	73946.71
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.60	4.93	54.62	2.21	15.88	11.59	1.04	77967.65
最大值	12.47	9.16	63.41	3.65	17.81	12.52	1.06	82909.10
發生時間	14	23	18	9	0	13		19
最小值	0.32	2.83	43.83	0.92	13.17	10.79	1.02	73946.71
發生時間	23	2	9	18	15	19		23
零點偏移(率)	-0.12 %	-0.17 %	-0.02 %	-0.06 %		-0.03		-0.10 %
全幅偏移(率)	1.12 %	0.96 %	-0.29 %	0.17 %		-0.18		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月02日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.21	6.11	62.74	0.62	17.80	10.59	1.02	78190.51
1	2.96	7.09	60.49	0.49	19.99	10.06	1.02	81509.72
2	4.33	7.78	47.23	0.61	16.86	10.44	1.00	79598.27
3	2.36	6.32	57.25	0.71	17.04	10.62	1.02	77587.45
4	2.69	5.96	49.94	0.53	16.49	10.33	1.01	78921.67
5	6.56	5.82	53.05	0.82	17.00	10.32	1.03	80111.70
6	6.20	5.67	62.17	1.02	16.05	11.00	1.03	77871.58
7	5.91	4.23	59.25	1.28	15.55	11.33	1.02	76577.12
8	6.08	3.56	56.33	0.96	16.18	10.67	1.04	79986.58
9	10.17	3.33	58.15	1.38	15.62	10.74	1.03	78513.11
10	8.27	4.91	56.32	1.09	16.22	10.51	1.02	79478.67
11	7.41	4.26	56.48	1.29	15.33	10.70	1.02	76915.39
12	8.98	3.96	55.50	2.72	13.06	10.96	1.04	73455.03
13	4.12	4.12	54.14	2.37	12.90	10.85	1.00	73944.39
14	8.06	4.70	55.51	3.32	13.48	10.88	1.01	73559.16
15	9.02	5.79	50.74	2.76	14.23	10.86	1.00	74191.20
16	7.51	4.23	55.50	1.17	15.29	10.78	1.00	77944.20
17	6.75	3.53	62.27	1.14	15.35	10.80	1.04	78736.46
18	0.73	4.19	63.05	0.39	17.99	10.42	1.04	81014.80
19	5.75	4.32	53.89	1.04	16.57	10.28	1.03	83408.64
20	4.44	4.97	57.00	1.15	15.36	10.82	1.00	77656.99
21	2.66	3.90	57.84	0.77	16.33	10.54	0.99	80245.43
22	3.77	4.02	62.71	0.73	16.38	10.90	0.99	77709.72
23	0.73	5.76	58.47	0.34	17.38	10.62	1.00	79392.94
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.36	4.94	56.92	1.20	16.02	10.67	1.02	78188.36
最大值	10.17	7.78	63.05	3.32	19.99	11.33	1.06	83408.64
發生時間	9	2	18	14	1	7		19
最小值	0.73	3.33	47.23	0.34	12.90	10.06	0.99	73455.03
發生時間	18	9	2	23	13	1		12
零點偏移(率)	-0.03 %	-0.09 %	-0.02 %	-0.04 %		-0.03		0.20 %
全幅偏移(率)	0.02 %	0.63 %	-0.17 %	0.43 %		-0.14		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								