

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月08日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.52	13.00	66.91	0.80	21.22	11.21	1.03	72371.11
1	7.42	8.16	64.87	0.84	21.88	10.35	1.02	78219.57
2	8.20	8.19	51.56	1.52	19.48	10.86	1.02	76336.38
3	8.43	7.83	59.09	1.76	17.95	11.68	1.02	71906.27
4	4.09	9.38	66.28	1.01	18.35	12.19	1.04	67546.01
5	5.16	8.64	54.40	1.21	19.95	11.00	1.00	77503.20
6	7.63	7.57	51.62	1.51	18.89	10.99	0.99	75388.47
7	7.66	7.72	55.74	1.73	17.89	11.51	1.00	72969.06
8	9.05	8.77	57.81	1.75	18.04	11.32	1.00	74343.24
9	7.83	10.87	57.68	1.87	17.52	11.64	1.00	72509.68
10	9.66	10.46	55.27	2.05	17.11	11.50	0.99	74032.65
11	9.34	10.79	60.34	2.35	16.75	11.67	1.01	73536.09
12	10.98	11.57	54.59	2.31	16.41	11.83	1.02	72231.38
13	9.55	10.24	59.21	1.86	17.46	11.57	1.03	73523.04
14	9.25	9.93	58.05	2.12	16.92	11.64	1.03	73521.61
15	8.56	10.94	64.15	1.21	18.96	11.55	1.03	72242.26
16	6.96	7.53	57.28	0.82	20.20	10.55	1.02	78774.14
17	8.72	4.80	58.39	0.96	19.71	10.95	1.00	76148.93
18	6.50	6.99	64.72	0.69	19.85	11.24	1.01	74046.47
19	2.75	7.06	51.07	0.71	20.07	10.88	1.03	75898.54
20	6.91	8.07	43.53	1.30	18.55	11.22	1.02	74467.13
21	9.39	9.66	49.50	2.43	16.05	11.93	1.02	71049.31
22	10.15	7.53	49.55	2.06	17.17	11.35	1.02	73093.18
23	7.88	5.04	52.66	1.86	16.96	11.63	1.02	72699.00
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.82	8.78	56.84	1.53	18.47	11.34	1.02	73931.53
最大值	10.98	13.00	66.91	2.43	21.88	12.19	1.07	78774.14
發生時間	12	0	0	21	1	4		16
最小值	2.75	4.80	43.53	0.69	16.05	10.35	0.99	67546.01
發生時間	19	17	20	18	21	1		4
零點偏移(率)	-0.01 %	-0.01 %	-0.05 %	-0.00 %		0.02		0.00 %
全幅偏移(率)	0.02 %	-0.70 %	0.19 %	0.01 %		0.07		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月08日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.78	6.25	49.32	1.34	19.86	9.81	1.05	86781.24
1	2.37	4.09	60.69	1.75	19.14	10.30	1.05	84008.38
2	4.71	7.25	54.37	1.94	18.56	10.14	1.05	85984.06
3	4.46	12.67	60.65	2.81	17.37	10.42	1.05	85296.10
4	2.34	11.83	59.40	2.26	17.94	10.46	1.05	84966.76
5	6.96	4.67	58.55	2.50	17.77	10.34	1.03	85711.02
6	1.57	7.31	65.49	2.64	16.09	11.06	1.02	92079.99
7	3.31	11.48	60.95	2.94	16.36	11.21	1.02	78966.68
8	6.04	5.02	62.10	2.66	17.15	10.53	1.02	84648.45
9	7.92	6.98	58.66	2.81	16.58	10.69	1.03	83409.56
10	9.96	4.06	60.53	3.97	15.59	10.75	1.04	83712.61
11	10.60	7.79	54.77	3.66	16.33	10.44	1.03	85789.32
12	8.67	3.21	56.13	2.10	18.66	10.27	1.04	85224.70
13	9.72	3.55	57.09	1.96	18.71	10.01	1.05	86868.63
14	8.90	3.13	59.32	1.67	19.06	10.13	1.05	85057.58
15	9.38	5.61	65.89	1.16	19.91	9.74	1.05	88096.29
16	8.55	7.30	57.98	1.32	18.94	10.21	1.04	85303.13
17	5.62	7.74	68.62	0.80	19.36	10.52	1.03	82330.86
18	9.82	8.52	47.96	1.30	19.95	9.41	1.03	90555.56
19	10.90	6.93	50.59	2.11	18.17	9.74	1.00	88840.95
20	9.71	7.13	61.35	2.86	15.93	10.48	0.99	85575.81
21	8.72	6.63	60.60	2.75	15.09	10.63	1.00	86241.03
22	9.35	4.77	37.17	2.00	17.17	10.39	1.01	85640.00
23	9.43	4.88	45.24	1.48	18.57	10.06	1.02	86808.32
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.24	6.62	57.23	2.20	17.84	10.32	1.03	85745.71
最大值	10.90	12.67	68.62	3.97	19.95	11.21	1.05	92079.99
發生時間	19	3	17	10	18	7		6
最小值	1.57	3.13	37.17	0.80	15.09	9.41	0.99	78966.68
發生時間	6	14	22	17	21	18		7
零點偏移(率)	-0.04 %	0.00 %	-0.01 %	-0.03 %		0.05		-0.20 %
全幅偏移(率)	0.04 %	0.04 %	-0.41 %	-0.00 %		0.38		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月08日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.11	14.89	53.55	1.48	17.67	10.32	0.97	87596.58
1	8.77	7.49	56.05	1.50	17.41	10.94	0.97	82129.31
2	8.01	6.43	55.32	1.38	17.36	10.66	0.98	83165.11
3	9.02	9.52	49.43	1.84	16.54	10.58	0.97	84644.90
4	8.49	9.75	51.95	1.66	17.11	10.62	0.97	83143.57
5	7.27	11.41	49.82	1.61	16.23	10.64	0.97	80633.32
6	8.99	4.75	50.54	2.02	15.21	10.76	0.97	77952.21
7	5.12	4.66	46.00	1.72	15.38	10.88	0.98	74886.60
8	8.84	6.25	51.31	1.64	16.70	10.55	0.99	80292.45
9	9.40	12.20	48.09	1.90	15.65	10.74	0.97	78265.82
10	9.37	11.84	50.72	2.56	14.24	10.97	0.98	75560.36
11	10.40	6.53	50.92	2.32	14.36	10.77	0.97	77778.75
12	8.77	5.79	51.39	1.97	15.25	10.83	0.99	77961.28
13	9.63	7.63	45.03	1.96	16.17	10.23	0.99	79825.70
14	9.49	5.97	50.84	2.50	14.25	10.93	0.99	75180.85
15	7.62	5.08	49.55	1.88	15.10	10.92	0.97	73917.41
16	5.80	8.07	48.99	1.16	17.83	10.41	0.97	82845.14
17	10.42	3.81	46.49	1.77	16.11	10.33	0.98	82665.31
18	8.55	6.44	51.29	1.97	15.35	10.70	0.98	82599.10
19	9.72	6.51	61.82	1.79	17.00	10.53	0.99	82929.35
20	10.74	10.30	48.95	1.86	15.79	10.41	0.99	81320.37
21	8.85	5.97	57.10	2.71	16.66	9.83	0.99	85074.62
22	10.32	6.79	41.55	2.79	14.99	9.70	0.98	77924.34
23	8.22	5.74	49.65	2.30	13.84	10.86	0.99	74307.99
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.79	7.66	50.68	1.93	15.93	10.59	0.98	80108.35
最大值	10.74	14.89	61.82	2.79	17.83	10.97	1.03	87596.58
發生時間	20	0	19	22	16	10		0
最小值	5.12	3.81	41.55	1.16	13.84	9.70	0.97	73917.41
發生時間	7	17	22	16	23	22		15
零點偏移(率)	-0.05 %	-0.01 %	-0.02 %	0.00 %		0.01		0.00 %
全幅偏移(率)	0.04 %	-0.10 %	-0.75 %	0.05 %		0.45		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								