

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月23日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.68	2.98	46.68	2.21	16.53	11.31	1.02	72912.06
1	8.62	6.15	51.14	1.72	18.41	11.05	1.02	74442.13
2	8.71	8.90	46.55	2.09	17.61	11.03	1.02	73481.17
3	9.32	8.38	51.08	1.38	17.66	10.97	1.02	73613.03
4	8.68	8.27	50.27	1.47	17.08	11.19	1.02	72502.96
5	13.86	6.08	44.57	2.00	18.01	10.62	1.06	74864.98
6	7.65	10.46	43.58	1.62	16.60	11.16	1.07	73462.95
7	6.68	8.54	49.69	1.72	16.57	11.45	1.08	70637.07
8	7.28	7.33	45.38	1.01	18.28	10.76	1.10	74518.11
9	4.67	6.61	55.81	0.47	19.26	10.75	1.10	72968.89
10	2.43	1.45	47.62	0.26	21.33	9.67	1.08	78750.65
11	7.95	9.28	46.90	0.74	17.56	10.98	1.09	75220.54
12	8.95	8.07	35.40	1.86	17.46	11.03	1.06	74685.10
13	5.52	6.51	45.27	0.84	18.83	11.22	1.07	74121.41
14	1.69	11.07	59.17	0.84	17.88	11.79	1.07	70753.38
15	8.10	6.50	49.33	0.88	18.40	10.68	1.10	78617.49
16	7.23	8.06	45.32	0.85	18.06	10.77	1.09	78134.05
17	7.78	9.14	49.95	1.00	18.18	10.93	1.07	77652.76
18	5.71	10.49	60.46	0.41	19.89	10.64	1.07	78231.30
19	3.29	11.68	56.12	0.32	20.38	10.52	1.09	78242.98
20	4.83	11.76	46.15	0.54	19.92	10.47	1.08	78985.61
21	5.20	11.60	52.60	0.57	20.16	10.36	1.10	80066.01
22	5.25	11.73	59.22	0.54	19.79	10.87	1.10	75982.19
23	2.93	13.19	61.81	0.35	19.82	11.12	1.10	74173.09
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.75	8.51	50.00	1.07	18.49	10.89	1.07	75292.50
最大值	13.86	13.19	61.81	2.21	21.33	11.79	1.12	80066.01
發生時間	5	23	23	0	10	14		21
最小值	1.69	1.45	35.40	0.26	16.53	9.67	1.02	70637.07
發生時間	14	10	12	10	0	10		7
零點偏移(率)	-0.08 %	-0.05 %	-0.03 %	-0.00 %		-0.05		0.00 %
全幅偏移(率)	0.00 %	-0.60 %	-0.03 %	-0.19 %		0.17		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月23日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.71	1.05	47.68	1.58	17.69	10.30	1.04	85436.96
1	9.62	4.39	49.06	2.36	17.64	10.32	1.02	85219.15
2	8.41	7.26	54.35	2.11	15.97	10.54	1.02	85102.33
3	8.98	6.36	62.41	1.72	16.27	11.00	1.02	81682.02
4	9.53	5.58	56.34	1.69	16.75	10.55	1.02	84633.84
5	8.32	6.87	70.10	1.82	15.95	10.86	1.02	83124.02
6	7.76	6.86	54.85	1.96	17.14	10.06	1.05	90609.28
7	9.80	7.28	59.98	2.22	16.17	10.35	1.05	86572.64
8	9.14	7.23	56.51	2.24	14.95	10.88	1.03	82629.81
9	9.24	6.40	60.11	1.89	15.31	11.12	1.01	80861.91
10	5.86	1.98	42.74	1.28	16.21	10.84	1.03	81901.21
11	9.91	3.59	35.61	1.54	16.72	10.48	1.05	84391.10
12	8.44	2.58	50.13	1.20	16.68	10.81	1.05	81921.22
13	7.95	8.30	55.18	1.10	16.58	10.66	1.05	82428.48
14	8.99	4.62	59.17	1.34	16.24	10.21	1.05	86655.77
15	3.80	5.80	55.08	1.46	14.76	12.15	1.08	73295.49
16	3.01	2.83	56.43	0.63	17.79	10.12	1.06	87233.09
17	5.40	2.45	45.82	0.86	18.22	9.89	1.05	87467.57
18	5.22	8.05	44.51	1.25	17.89	9.92	1.02	87461.73
19	5.18	9.26	55.68	0.38	19.85	9.71	1.02	86874.47
20	8.91	8.71	60.01	1.05	18.21	9.82	1.02	87875.07
21	7.65	8.86	51.04	1.08	18.14	9.97	1.02	86904.93
22	9.57	8.32	60.70	1.58	17.14	10.46	1.01	84018.55
23	2.87	8.45	60.47	0.77	17.13	11.27	1.02	77848.36
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.59	5.96	54.33	1.46	16.89	10.51	1.03	84256.21
最大值	9.91	9.26	70.10	2.36	19.85	12.15	1.17	90609.28
發生時間	11	19	5	1	19	15		6
最小值	2.87	1.05	35.61	0.38	14.76	9.71	1.00	73295.49
發生時間	23	0	11	19	15	19		15
零點偏移(率)	-0.11 %	-0.06 %	-0.02 %	-0.06 %		0.02		-0.10 %
全幅偏移(率)	0.02 %	0.13 %	-0.38 %	0.23 %		-0.01		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月23日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.08	6.04	41.50	2.29	13.39	10.43	1.00	75813.56
1	9.97	6.73	42.87	2.06	13.25	10.83	1.01	75838.71
2	9.29	8.55	53.35	3.06	12.69	11.42	1.02	75974.88
3	8.82	4.55	56.24	2.10	13.87	11.31	1.02	75822.02
4	9.78	4.02	63.31	1.76	14.51	10.94	1.02	80923.36
5	9.20	4.63	50.79	2.14	13.70	11.26	1.02	78403.81
6	8.77	7.16	51.30	2.46	12.88	11.71	1.02	78245.80
7	6.55	5.34	58.26	1.84	13.95	11.20	1.02	80909.73
8	9.99	4.76	58.95	2.27	14.07	11.06	1.03	79117.66
9	4.49	3.79	58.01	1.94	13.67	11.47	1.03	74005.19
10	4.80	2.51	56.04	0.63	17.91	10.28	1.03	87353.54
11	9.49	6.07	49.47	0.97	16.35	10.62	1.05	86229.76
12	9.82	4.72	57.82	1.26	15.45	10.73	1.03	85021.64
13	9.02	7.45	34.72	1.73	13.68	11.26	1.01	78521.93
14	7.80	6.97	40.40	1.68	13.86	11.54	1.01	75514.54
15	7.02	4.63	60.38	1.20	15.37	11.52	1.04	78707.44
16	8.74	5.81	43.26	1.81	14.90	11.00	1.02	82477.60
17	7.93	4.19	53.77	1.42	14.71	11.09	1.02	82238.40
18	8.10	8.56	52.23	1.70	13.53	11.39	1.02	79159.75
19	3.08	3.99	55.86	0.49	16.08	11.14	1.02	82981.12
20	3.12	6.93	54.96	0.60	16.21	10.93	1.02	85000.80
21	4.15	9.60	48.80	0.59	16.47	10.66	1.02	85247.14
22	4.84	12.41	47.91	1.23	14.91	10.75	1.02	79477.41
23	1.81	7.68	52.99	0.80	15.95	11.16	1.02	78987.45
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.32	6.13	51.80	1.58	14.64	11.07	1.02	80082.22
最大值	9.99	12.41	63.31	3.06	17.91	11.71	1.06	87353.54
發生時間	8	22	4	2	10	6		10
最小值	1.81	2.51	34.72	0.49	12.69	10.28	0.99	74005.19
發生時間	23	10	13	19	2	10		9
零點偏移(率)	-0.01 %	-0.04 %	-0.01 %	0.00 %		0.01		0.00 %
全幅偏移(率)	0.13 %	-0.12 %	-0.58 %	0.01 %		0.44		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								