

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月18日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.80	1.91	59.52	3.45	18.48	11.42	1.33	65015.95
1	4.51	1.55	53.85	3.25	20.55	10.26	1.33	72826.95
2	8.98	1.73	47.94	3.85	20.01	9.83	1.33	74093.93
3	8.16	1.80	47.20	3.58	18.79	10.78	1.33	71706.99
4	8.18	2.41	48.61	4.17	18.69	10.22	1.33	75205.97
5	5.23	1.45	48.39	2.90	19.06	10.17	1.32	70497.15
6	7.34	1.50	52.48	3.15	19.18	10.32	1.30	72355.97
7	5.17	1.56	58.22	2.55	19.49	10.55	1.32	72869.69
8	5.82	1.60	61.36	2.12	21.21	9.88	1.34	76745.11
9	6.60	2.04	39.14	2.61	19.09	10.69	1.35	72825.30
10	5.31	2.19	34.42	2.69	17.87	10.99	1.33	71516.21
11	7.54	3.07	45.66	3.01	17.96	10.68	1.30	72758.87
12	5.88	2.22	49.78	3.15	17.66	11.20	1.31	68306.06
13	9.03	1.73	62.77	2.56	20.71	10.36	1.35	73851.18
14	8.45	2.32	49.17	2.50	19.92	10.27	1.34	74663.02
15	8.02	2.03	52.56	2.79	18.96	10.94	1.33	70930.83
16	7.12	2.22	56.40	2.45	21.05	10.08	1.33	73542.03
17	8.91	1.74	51.35	3.03	20.66	9.66	1.33	76840.51
18	10.94	3.68	31.30	3.67	18.23	10.64	1.33	71144.64
19	9.24	2.01	39.25	3.23	18.49	10.57	1.33	71857.48
20	9.56	1.64	53.87	2.75	20.29	10.17	1.31	74734.30
21	9.26	2.18	43.29	2.84	18.79	10.56	1.31	73230.96
22	9.62	1.74	48.71	3.02	18.16	10.94	1.30	70672.38
23	8.24	1.77	56.42	2.54	20.04	10.55	1.30	72090.25
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.50	2.00	49.65	2.99	19.31	10.49	1.32	72511.74
最大值	10.94	3.68	62.77	4.17	21.21	11.42	1.37	76840.51
發生時間	18	18	13	4	8	0		17
最小值	2.80	1.45	31.30	2.12	17.66	9.66	1.28	65015.95
發生時間	0	5	18	8	12	17		0
零點偏移(率)	-0.05 %	-0.00 %	-0.11 %	0.00 %		0.06	0.00	0.00 %
全幅偏移(率)	-1.34 %	0.36 %	0.06 %	0.14 %		0.08	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月18日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.11	1.85	58.62	1.00	19.72	10.27	1.44	75682.64
1	0.33	1.86	58.19	0.87	20.31	9.81	1.45	79025.60
2	3.34	2.41	43.22	1.65	19.31	8.91	1.44	83848.39
3	4.83	2.92	42.95	1.81	19.38	8.85	1.44	84455.71
4	3.46	3.11	50.47	2.03	16.64	9.45	1.45	79606.32
5	6.24	2.15	50.67	2.53	17.44	9.17	1.44	80346.82
6	1.67	1.52	49.42	0.92	18.73	9.95	1.45	75341.54
7	0.24	1.66	56.73	0.84	19.63	10.08	1.45	76269.74
8	0.57	3.10	55.70	0.48	21.64	9.33	1.46	85037.87
9	0.87	2.61	45.11	0.79	19.71	9.13	1.47	87772.42
10	5.74	4.74	49.44	4.07	17.41	9.65	1.46	80620.97
11	7.48	3.76	52.78	1.91	18.33	9.52	1.45	82247.91
12	7.33	1.68	64.30	1.12	20.47	9.35	1.46	84187.68
13	7.53	1.81	56.43	1.31	19.08	9.55	1.46	84809.50
14	9.06	1.87	55.92	2.13	17.15	9.76	1.45	81458.32
15	7.48	4.63	54.08	1.58	19.11	9.26	1.45	83157.20
16	9.90	2.29	55.12	1.87	20.04	9.08	1.45	85134.19
17	10.43	3.73	59.42	1.86	20.08	8.94	1.45	87430.07
18	10.80	3.33	55.05	1.96	18.75	9.40	1.46	84412.86
19	9.97	1.76	57.18	2.09	19.89	9.37	1.45	86524.45
20	9.53	2.77	38.47	2.18	19.52	9.17	1.44	85552.46
21	8.23	6.39	44.99	1.75	19.90	9.39	1.46	84860.07
22	9.09	2.80	53.17	1.64	20.50	9.13	1.45	87606.08
23	9.65	2.13	52.32	2.13	18.75	9.64	1.46	83979.16
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.00	2.79	52.49	1.69	19.23	9.42	1.45	82890.33
最大值	10.80	6.39	64.30	4.07	21.64	10.27	1.48	87772.42
發生時間	18	21	12	10	8	0		9
最小值	0.11	1.52	38.47	0.48	16.64	8.85	1.43	75341.54
發生時間	0	6	20	8	4	3		6
零點偏移(率)	-0.45 %	-0.01 %	-0.11 %	-0.07 %		0.04	0.00	-0.10 %
全幅偏移(率)	-2.40 %	-0.63 %	-0.34 %	-0.09 %		0.06	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月18日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.13	3.00	57.66	3.51	18.90	10.16	1.30	83652.46
1	6.30	2.59	53.88	3.74	17.06	10.50	1.30	83289.45
2	6.12	2.24	67.35	3.58	16.89	10.46	1.31	84244.54
3	5.32	1.78	53.01	3.71	16.24	10.46	1.30	82865.46
4	7.90	3.46	54.45	4.13	15.48	10.68	1.30	80265.64
5	6.15	5.49	58.02	4.12	14.91	10.35	1.30	78996.91
6	7.47	4.74	59.73	4.15	15.50	10.46	1.28	78120.16
7	1.06	1.92	57.85	2.65	16.90	11.15	1.32	78887.27
8	0.86	1.94	60.13	2.44	17.37	10.73	1.33	78547.72
9	1.75	2.97	50.49	2.49	18.33	10.19	1.31	83785.65
10	4.20	4.29	40.51	5.09	17.06	10.04	1.35	81280.90
11	4.23	7.02	52.12	2.68	16.06	10.42	1.37	78224.34
12	5.02	0.23	64.28	2.78	18.60	10.04	1.32	83210.78
13	5.29	6.89	47.83	2.99	18.97	9.58	1.30	86793.34
14	5.31	3.50	53.50	2.59	18.33	9.90	1.31	82436.71
15	7.20	14.75	52.10	3.13	17.46	10.23	1.32	79990.15
16	9.48	2.62	60.92	4.11	16.19	10.48	1.33	79255.53
17	10.18	5.16	61.19	3.55	17.04	10.16	1.30	83287.86
18	8.57	5.51	48.10	2.80	15.75	10.69	1.30	78714.95
19	11.19	3.61	54.13	3.73	17.33	10.11	1.34	83744.83
20	8.32	3.04	58.33	3.08	18.06	10.14	1.37	84946.00
21	10.02	4.04	51.74	3.11	16.70	10.17	1.38	82455.34
22	6.39	3.77	54.79	2.85	18.06	9.92	1.34	82906.69
23	8.80	2.55	59.20	3.09	17.48	10.34	1.30	82544.34
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.34	4.05	55.47	3.34	17.11	10.31	1.32	81768.63
最大值	11.19	14.75	67.35	5.09	18.97	11.15	1.38	86793.34
發生時間	19	15	2	10	13	7		13
最小值	0.86	0.23	40.51	2.44	14.91	9.58	1.27	78120.16
發生時間	8	12	10	8	5	13		6
零點偏移(率)	-0.11 %	0.00 %	-0.18 %	-0.07 %		0.01	0.00	0.00 %
全幅偏移(率)	-0.14 %	1.31 %	-0.19 %	0.31 %		0.29	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								