

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年06月14日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	8.62	5.34	58.63	0.59	19.33	11.66	0.98	78784.49
1	9.10	5.54	48.92	0.70	20.96	10.45	0.99	87077.71
2	8.64	6.31	47.87	1.34	18.31	11.07	0.99	84174.47
3	7.58	5.95	54.84	1.23	18.19	11.36	1.00	82527.98
4	9.54	6.10	56.14	1.29	18.62	11.04	1.01	84300.54
5	9.00	3.23	45.51	2.13	16.50	10.98	1.00	89660.53
6	9.67	3.26	54.03	1.74	17.59	11.23	1.01	84460.37
7	9.86	4.36	52.30	1.66	17.74	11.15	1.01	84846.55
8	11.62	3.36	47.13	1.28	18.73	11.02	1.01	84759.59
9	11.09	3.20	43.24	1.45	18.20	11.30	0.99	83188.92
10	12.00	3.67	41.36	1.73	17.41	11.59	0.98	81727.50
11	15.26	3.76	40.89	2.28	16.25	11.74	1.00	81489.31
12	14.82	3.45	47.71	2.38	16.86	11.78	1.01	80864.35
13	11.11	5.49	44.80	1.99	17.38	11.89	0.99	79077.70
14	9.43	9.98	41.61	1.16	19.14	10.92	1.00	84704.25
15	5.43	3.30	46.67	0.92	18.92	11.02	1.02	84109.48
16	13.42	3.32	44.09	1.91	16.93	11.41	1.02	83227.64
17	9.30	3.03	40.58	1.84	17.49	11.38	1.02	82814.22
18	8.69	2.80	39.58	2.37	16.62	11.42	1.02	81874.70
19	15.18	2.01	43.63	2.52	17.21	11.33	1.01	83530.26
20	14.80	2.32	44.41	1.63	18.41	11.00	1.00	84901.57
21	8.11	2.10	50.67	0.67	19.80	10.60	1.02	87228.43
22	9.12	3.06	52.16	1.86	17.01	11.47	1.02	82674.10
23	12.65	4.67	61.66	1.89	18.14	11.27	1.02	83192.35
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.59	4.15	47.85	1.61	17.99	11.25	1.00	83549.88
最 大 值	15.26	9.98	61.66	2.52	20.96	11.89	1.04	89660.53
發生時間	11	14	23	19	1	13		5
最 小 值	5.43	2.01	39.58	0.59	16.25	10.45	0.97	78784.49
發生時間	15	19	18	0	11	1		0
零點偏移(率)	-0.26 %	-0.00 %	-0.11 %	-0.00 %		-0.01		0.00 %
全幅偏移(率)	0.00 %	-0.30 %	-0.20 %	0.50 %		-0.04		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年06月14日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.88	3.74	52.52	0.71	19.15	11.52	1.02	74427.10
1	2.38	3.89	52.29	1.38	20.03	10.92	1.02	78232.25
2	2.33	3.77	56.59	2.01	18.71	10.82	1.02	80812.90
3	8.51	5.51	48.69	1.79	18.22	10.36	1.01	84737.62
4	8.29	6.90	45.04	2.38	17.52	10.45	1.01	84613.43
5	8.71	2.17	50.99	2.60	17.24	10.47	1.00	83508.51
6	8.20	3.10	48.40	1.33	19.30	10.03	1.02	90610.29
7	8.04	4.14	44.82	1.95	18.29	10.33	1.02	84860.07
8	7.85	7.32	43.34	2.49	17.76	10.63	1.02	82551.35
9	7.18	2.23	44.18	2.22	17.78	10.90	1.02	81392.40
10	8.58	1.81	47.67	1.86	18.16	11.00	1.04	79769.99
11	7.73	3.12	43.89	2.51	16.63	11.34	1.04	78477.69
12	4.39	2.16	45.21	2.03	17.83	11.12	1.02	79282.14
13	6.86	3.75	46.07	3.06	15.80	11.55	1.02	77774.63
14	3.45	1.98	44.54	1.94	17.37	11.14	1.03	79530.10
15	1.65	5.63	46.13	1.37	18.86	10.79	1.03	80517.63
16	9.21	2.30	42.33	2.61	17.66	10.81	1.05	81386.23
17	10.63	6.61	42.84	2.53	17.33	10.89	1.04	81334.54
18	12.66	6.17	37.28	2.66	17.20	10.78	1.03	81605.21
19	8.07	6.99	38.41	2.45	15.95	11.03	1.04	81365.34
20	9.66	3.31	38.63	1.55	19.09	10.32	1.02	83757.12
21	10.03	5.09	35.91	1.76	18.48	10.37	1.02	83882.67
22	10.08	2.03	48.74	1.94	18.13	10.72	1.02	82017.80
23	9.52	3.28	61.77	2.46	18.12	11.09	1.02	79682.08
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.29	4.04	46.09	2.07	17.94	10.81	1.02	81505.38
最 大 值	12.66	7.32	61.77	3.06	20.03	11.55	1.08	90610.29
發生時間	18	8	23	13	1	13		6
最 小 值	0.88	1.81	35.91	0.71	15.80	10.03	0.97	74427.10
發生時間	0	10	21	0	13	6		0
零點偏移(率)	-0.09 %	-0.00 %	-0.03 %	-0.08 %		-0.08		0.00 %
全幅偏移(率)	0.13 %	0.18 %	0.22 %	0.53 %		-0.09		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年06月14日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.90	6.21	57.37	0.92	16.73	12.10	0.93	70086.51
1	1.82	4.78	61.84	0.72	19.10	9.96	0.94	83986.17
2	1.90	3.66	52.45	0.97	18.04	10.32	0.94	81085.87
3	1.24	3.41	51.88	0.68	18.08	10.30	0.98	80721.03
4	3.14	5.22	46.52	0.88	18.78	9.65	0.98	83723.83
5	2.27	3.05	41.33	0.69	18.06	9.89	0.99	79464.82
6	1.57	4.02	45.01	0.61	18.92	9.97	0.99	80837.94
7	0.12	2.12	48.95	0.58	18.31	10.82	0.99	78881.62
8	6.40	6.22	43.25	0.88	19.10	9.93	0.98	84375.05
9	4.75	2.98	50.78	0.88	18.14	10.70	1.00	79523.09
10	5.16	4.10	48.29	1.00	18.05	10.53	0.97	81359.58
11	4.19	2.83	49.62	0.99	18.11	10.55	0.97	81341.08
12	2.78	3.09	53.16	0.92	17.20	11.34	0.98	73395.89
13	2.51	3.52	50.22	1.27	15.89	11.48	0.99	72788.19
14	4.90	2.81	53.45	1.39	16.01	11.27	1.02	75853.15
15	3.32	2.72	51.25	1.27	16.43	10.82	1.02	80859.20
16	5.40	5.01	46.69	1.28	18.03	10.28	1.00	81666.98
17	9.91	3.00	43.82	2.94	17.24	10.26	0.97	78164.76
18	5.49	2.94	44.12	1.31	16.20	10.60	0.97	77771.46
19	3.12	5.08	45.29	1.46	15.06	10.68	0.97	78096.20
20	4.97	5.51	51.72	1.26	16.33	10.81	1.01	77977.62
21	6.21	5.30	54.90	1.07	17.57	10.42	1.02	81904.40
22	10.54	3.49	50.41	2.19	16.28	10.91	0.99	78358.63
23	9.28	4.84	58.07	2.96	17.58	10.90	0.97	78028.76
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.29	4.00	50.02	1.21	17.47	10.60	0.98	79177.16
最 大 值	10.54	6.22	61.84	2.96	19.10	12.10	1.04	84375.05
發生時間	22	8	1	23	1	0		8
最 小 值	0.12	2.12	41.33	0.58	15.06	9.65	0.92	70086.51
發生時間	7	7	5	7	19	4		0
零點偏移(率)	-0.15 %	-0.04 %	-0.04 %	-0.01 %		-0.15		0.20 %
全幅偏移(率)	0.02 %	0.13 %	-0.94 %	0.29 %		0.12		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								