

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月16日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.76	3.36	65.92	3.43	16.08	12.66	1.43	67239.46
1	0.57	3.60	41.25	3.51	16.28	12.91	1.47	67786.37
2	3.77	3.27	62.04	3.03	16.62	12.04	1.43	72901.84
3	7.56	3.77	43.80	3.36	16.12	12.01	1.45	71508.92
4	9.38	4.76	52.10	3.26	16.90	12.00	1.46	70845.43
5	9.74	4.25	60.13	2.75	17.30	12.18	1.42	64463.79
6	10.46	3.22	43.74	2.97	16.84	11.64	1.41	72921.99
7	9.13	3.24	38.10	2.87	17.22	11.48	1.42	74044.87
8	7.66	3.62	49.10	3.02	16.65	11.73	1.39	72845.42
9	9.95	3.67	48.60	3.59	15.81	11.98	1.41	71276.66
10	9.27	3.75	55.16	3.36	16.63	12.02	1.41	70204.67
11	7.16	3.19	54.88	2.74	17.34	11.78	1.42	71020.53
12	5.22	3.24	56.22	2.42	18.38	11.57	1.41	71731.74
13	8.29	3.35	57.74	3.40	16.08	12.72	1.38	67134.13
14	5.65	3.24	62.55	2.74	17.76	12.04	1.35	71375.00
15	10.08	3.34	47.73	3.13	17.05	12.09	1.35	69166.14
16	9.37	3.33	53.65	2.81	17.26	11.70	1.36	71958.91
17	9.56	3.28	58.78	2.51	18.42	11.59	1.37	71655.29
18	8.92	3.50	52.90	2.89	16.60	11.80	1.41	71529.24
19	9.56	3.35	54.85	2.71	17.43	11.88	1.42	70155.95
20	8.39	3.70	61.24	2.79	17.15	12.00	1.40	69462.17
21	11.24	3.31	55.66	2.69	17.45	11.66	1.41	71631.28
22	8.89	3.73	47.50	3.07	16.44	12.15	1.38	68887.39
23	12.60	3.35	52.75	3.04	16.58	11.92	1.38	70678.00
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.22	3.52	53.18	3.00	16.93	11.98	1.41	70517.72
最大值	12.60	4.76	65.92	3.59	18.42	12.91	1.57	74044.87
發生時間	23	4	0	9	17	1		7
最小值	0.57	3.19	38.10	2.42	15.81	11.48	1.34	64463.79
發生時間	1	11	7	12	9	7		5
零點偏移(率)	-0.06 %	-0.00 %	-0.02 %	-0.00 %		-0.02	0.00	0.00 %
全幅偏移(率)	-2.66 %	-0.78 %	0.09 %	0.01 %		-0.12	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月16日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.42	3.90	46.41	2.21	19.14	10.04	1.45	85942.31
1	9.48	3.84	50.54	2.09	20.13	10.24	1.43	85379.54
2	7.90	4.32	51.02	2.45	18.91	10.21	1.43	85369.25
3	9.61	4.28	26.77	2.48	18.98	10.25	1.42	84969.64
4	11.10	4.85	43.39	3.76	18.01	10.13	1.43	84197.48
5	6.85	9.71	60.94	2.93	18.37	10.57	1.44	79959.43
6	6.15	6.10	63.46	1.89	19.50	11.34	1.39	76906.21
7	6.38	4.60	52.24	2.01	20.20	11.22	1.38	76432.84
8	10.45	4.71	41.41	3.16	19.02	10.46	1.41	84528.32
9	10.19	3.87	53.45	3.72	17.25	10.43	1.41	86524.05
10	10.57	4.56	46.12	6.05	16.35	10.73	1.40	82793.06
11	8.38	3.46	54.60	4.45	17.74	10.31	1.40	82612.85
12	10.94	3.92	52.58	4.17	17.66	10.47	1.41	83195.54
13	10.23	3.79	57.59	2.89	18.52	10.42	1.41	81668.00
14	9.66	4.61	41.35	2.62	18.43	10.30	1.39	84893.81
15	9.43	4.50	46.53	3.00	19.12	10.16	1.40	84769.76
16	7.12	4.50	56.74	2.11	20.05	10.19	1.41	82940.90
17	10.04	4.89	37.47	2.65	18.90	10.01	1.42	82566.54
18	8.58	4.12	66.16	1.52	20.66	10.33	1.42	82444.56
19	10.10	4.75	37.54	1.95	19.90	10.11	1.40	84027.11
20	5.72	4.67	48.87	1.83	18.75	10.79	1.38	79883.30
21	3.21	5.08	54.55	1.89	18.31	10.84	1.38	77003.24
22	7.01	5.68	34.57	2.46	18.63	10.07	1.39	80343.89
23	6.55	3.05	51.49	1.76	19.83	10.62	1.41	79745.54
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.59	4.66	48.99	2.75	18.85	10.43	1.41	82462.38
最大值	11.10	9.71	66.16	6.05	20.66	11.34	1.45	86524.05
發生時間	4	5	18	10	18	6		9
最小值	3.21	3.05	26.77	1.52	16.35	10.01	1.38	76432.84
發生時間	21	23	3	18	10	17		7
零點偏移(率)	-0.05 %	-0.01 %	-0.04 %	0.00 %		-0.06	0.00	0.00 %
全幅偏移(率)	2.68 %	-0.87 %	-0.04 %	-0.03 %		-0.03	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月16日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.24	4.63	61.24	2.49	17.07	11.15	1.49	81348.85
1	4.39	5.37	33.06	2.20	20.45	9.88	1.49	87747.75
2	7.78	6.31	48.30	2.60	16.27	10.69	1.48	85437.15
3	6.70	3.34	64.41	2.70	16.14	11.08	1.46	79959.55
4	6.48	6.40	60.28	2.70	17.25	10.76	1.46	83406.12
5	9.30	9.95	60.15	3.14	16.13	11.21	1.45	80672.71
6	10.45	22.45	56.63	4.37	16.75	10.55	1.46	86218.50
7	10.61	10.89	51.21	2.52	20.44	9.89	1.48	92176.63
8	9.29	6.81	48.58	1.92	17.94	10.52	1.49	87110.05
9	8.73	2.51	58.27	2.17	17.13	10.53	1.49	85743.01
10	9.72	2.78	52.51	2.31	17.88	10.50	1.49	86054.42
11	9.41	3.34	58.19	2.05	18.69	10.25	1.49	86212.14
12	9.86	5.64	47.66	2.20	17.59	10.23	1.47	84081.29
13	11.16	7.44	45.97	2.21	18.18	9.99	1.45	85809.74
14	8.10	3.68	50.24	1.87	17.86	10.50	1.44	81320.81
15	9.24	6.19	51.63	1.79	17.90	10.31	1.44	83275.33
16	9.95	5.09	52.70	2.50	17.07	10.63	1.50	84435.60
17	9.97	2.03	48.57	2.00	18.18	10.28	1.68	86511.87
18	9.47	1.35	59.19	1.97	17.29	11.13	1.63	85827.36
19	5.50	2.70	64.58	1.89	17.27	12.51	1.57	69299.49
20	1.58	2.62	43.89	1.31	17.95	11.10	1.46	80042.06
21	7.44	3.87	43.61	1.66	17.99	10.27	1.47	85500.86
22	4.20	2.14	52.59	1.46	20.03	9.78	1.45	86208.59
23	7.99	5.46	47.21	1.72	18.90	10.11	1.46	86243.18
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.06	5.54	52.53	2.24	17.85	10.58	1.49	84193.46
最大值	11.16	22.45	64.58	4.37	20.45	12.51	1.82	92176.63
發生時間	13	6	19	6	1	19		7
最小值	1.58	1.35	33.06	1.31	16.13	9.78	1.43	69299.49
發生時間	20	18	1	20	5	22		19
零點偏移(率)	-0.07 %	-0.01 %	-0.02 %	-0.06 %		-0.02	0.00	0.00 %
全幅偏移(率)	0.44 %	-0.41 %	0.03 %	0.10 %		0.11	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								