

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年01月26日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.73	4.06	50.99	3.11	14.09	12.09	1.26	78755.84
1	8.58	2.76	54.46	2.01	15.35	12.14	1.26	77036.14
2	8.03	2.37	55.15	2.27	14.60	11.80	1.26	78933.83
3	9.88	2.54	48.05	3.40	13.56	12.16	1.25	76890.70
4	5.87	6.01	55.03	3.05	13.71	13.26	1.27	68662.45
5	3.12	2.86	64.62	1.15	14.80	12.16	1.27	74073.26
6	6.97	4.40	63.31	0.52	16.63	11.25	1.28	76201.37
7	10.01	3.88	62.60	0.61	16.24	11.45	1.28	82477.30
8	10.88	4.03	46.00	1.62	16.14	11.82	1.27	79586.13
9	11.00	9.55	35.02	1.26	16.04	11.55	1.26	82057.93
10	10.30	5.27	31.90	1.80	14.97	11.67	1.27	81977.32
11	10.98	3.42	34.27	2.89	13.83	11.82	1.27	81451.36
12	8.67	3.13	36.65	3.03	13.92	11.88	1.28	80917.87
13	9.73	3.37	42.00	2.40	14.57	11.97	1.27	79729.96
14	11.21	5.45	43.74	3.55	13.44	12.18	1.26	78621.04
15	8.78	3.07	40.64	3.26	13.89	12.04	1.29	79900.92
16	8.47	2.81	46.26	2.11	14.79	12.32	1.30	76198.76
17	8.77	2.88	48.08	2.92	14.03	11.96	1.29	80399.83
18	12.84	3.49	47.75	3.76	13.94	11.94	1.24	80765.88
19	13.75	6.38	54.29	2.81	15.53	11.43	1.24	83403.76
20	6.79	2.68	53.78	3.11	13.66	12.40	1.24	72273.82
21	10.43	2.08	57.82	3.08	13.95	12.03	1.25	79859.23
22	9.53	2.89	62.45	2.66	14.03	11.81	1.28	81745.97
23	7.17	4.40	62.85	3.24	13.21	12.45	1.29	76266.12
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.15	3.91	49.90	2.48	14.54	11.98	1.27	78674.45
最 大 值	13.75	9.55	64.62	3.76	16.63	13.26	1.31	83403.76
發生時間	19	9	5	18	6	4		19
最 小 值	3.12	2.08	31.90	0.52	13.21	11.25	1.23	68662.45
發生時間	5	21	10	6	23	6		4
零點偏移(率)	-0.07 %	-0.06 %	-0.22 %	-0.02 %		-0.03		0.20 %
全幅偏移(率)	0.00 %	0.10 %	0.04 %	0.13 %		-0.26		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年01月26日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.57	2.63	54.02	1.66	13.44	11.28	1.10	78430.64
1	8.28	2.53	55.68	1.96	13.53	11.60	1.10	77850.12
2	9.72	2.09	51.77	2.11	12.69	11.49	1.10	80309.42
3	8.45	2.61	47.48	1.90	12.69	11.33	1.10	78168.65
4	8.73	4.07	47.85	2.02	13.81	11.12	1.10	77189.67
5	12.32	5.24	55.00	2.69	12.75	11.41	1.10	80940.48
6	12.08	1.66	45.54	2.21	15.50	10.82	1.11	80570.68
7	9.76	2.42	42.02	2.34	14.97	11.07	1.13	81747.05
8	8.74	4.64	36.34	3.10	14.21	10.98	1.12	82717.85
9	8.74	0.90	41.07	2.53	14.37	11.34	1.13	79774.15
10	11.48	1.48	46.11	2.79	13.98	11.44	1.15	80353.38
11	18.49	2.91	40.29	3.30	12.86	11.11	1.16	83674.76
12	9.72	3.10	40.93	3.14	12.34	11.55	1.16	82352.41
13	3.38	1.51	54.03	2.14	12.09	11.65	1.14	82173.32
14	3.43	2.15	42.42	2.12	12.65	11.38	1.13	83818.43
15	3.97	1.51	40.96	2.25	12.76	11.50	1.12	82521.10
16	3.23	2.52	44.35	1.99	13.34	11.32	1.16	83201.50
17	4.73	2.81	41.02	2.37	12.14	11.60	1.17	81354.38
18	3.51	1.62	51.34	2.02	12.78	11.63	1.11	81423.40
19	3.34	1.40	57.60	2.01	12.92	11.50	1.10	82504.47
20	3.66	1.49	56.42	2.32	12.29	11.46	1.10	83717.45
21	3.96	1.37	57.75	2.02	12.47	11.55	1.10	81978.89
22	1.95	2.33	57.30	1.63	12.31	11.66	1.12	81038.71
23	4.56	2.01	56.59	2.39	12.15	11.52	1.13	82617.42
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.28	2.37	48.49	2.29	13.13	11.39	1.12	81267.85
最 大 值	18.49	5.24	57.75	3.30	15.50	11.66	1.18	83818.43
發生時間	11	5	21	11	6	22		14
最 小 值	1.95	0.90	36.34	1.63	12.09	10.82	1.10	77189.67
發生時間	22	9	8	22	13	6		4
零點偏移(率)	-0.01 %	0.01 %	-0.01 %	-0.06 %		-0.01		0.10 %
全幅偏移(率)	-0.12 %	0.32 %	0.44 %	0.39 %		0.03		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年01月26日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	7.48	2.16	51.97	1.93	13.56	11.49	1.51	77438.70
1	7.92	0.78	62.24	1.61	15.31	11.24	1.51	78759.04
2	6.32	4.55	58.34	2.43	12.76	11.28	1.51	80817.98
3	8.81	3.20	52.52	2.47	13.54	11.17	1.51	81614.03
4	8.33	3.10	55.89	2.22	14.45	10.84	1.51	82444.21
5	8.38	3.10	52.25	2.75	13.36	11.12	1.51	81124.88
6	8.67	3.76	51.65	2.46	13.15	11.44	1.52	78656.80
7	9.71	9.62	53.82	4.17	12.46	11.49	1.50	75826.99
8	15.50	3.28	55.43	3.78	13.06	11.21	1.50	80692.28
9	12.38	5.40	53.35	3.36	13.98	11.00	1.50	81320.56
10	11.29	7.41	54.38	3.85	13.88	11.00	1.50	81014.54
11	8.34	5.37	55.08	4.30	13.33	11.13	1.52	79920.36
12	9.35	3.14	57.08	2.44	12.94	11.39	1.51	78982.12
13	7.95	7.42	52.06	2.22	13.47	11.30	1.52	78575.14
14	8.96	2.95	53.56	2.35	13.65	11.22	1.52	78575.66
15	9.16	8.51	51.35	2.15	14.52	10.77	1.52	81242.19
16	7.66	2.76	54.32	2.79	11.60	12.02	1.51	73960.67
17	15.19	3.30	61.20	2.15	11.92	12.37	1.49	71490.00
18	13.43	3.06	59.21	1.56	12.31	12.28	1.48	69044.11
19	14.71	1.86	48.81	1.84	11.38	11.85	1.48	68882.30
20	16.03	2.47	51.09	2.04	11.56	11.58	1.48	72928.66
21	13.53	4.16	47.95	2.83	13.18	10.96	1.49	81151.38
22	14.41	1.38	47.61	3.00	12.03	11.49	1.49	76747.67
23	12.97	3.33	52.17	2.61	12.66	11.40	1.48	76326.02
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.69	4.00	53.89	2.64	13.09	11.38	1.50	77814.01
最 大 值	16.03	9.62	62.24	4.30	15.31	12.37	1.52	82444.21
發生時間	20	7	1	11	1	17		4
最 小 值	6.32	0.78	47.61	1.56	11.38	10.77	1.48	68882.30
發生時間	2	1	22	18	19	15		19
零點偏移(率)	-0.01 %	-0.04 %	-0.01 %	-0.00 %		-0.01		-0.10 %
全幅偏移(率)	-0.03 %	-0.08 %	-0.24 %	-0.03 %		-0.14		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								