

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月11日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.46	4.26	54.15	4.00	13.45	12.71	1.36	67830.14
1	10.12	5.29	58.50	3.60	14.45	12.68	1.38	67649.77
2	9.32	3.61	62.65	3.99	13.47	12.82	1.40	67545.33
3	7.55	6.21	56.36	4.17	12.89	12.99	1.41	66181.08
4	8.20	5.94	54.30	4.25	12.52	12.78	1.41	67801.63
5	8.52	7.85	60.33	4.16	12.53	12.75	1.42	63051.22
6	7.89	3.52	65.23	3.76	13.35	12.60	1.42	68586.72
7	4.69	3.62	64.27	3.59	13.43	12.92	1.40	65362.91
8	6.22	4.46	47.72	3.88	13.03	12.74	1.42	67431.19
9	8.58	3.85	53.43	3.32	14.05	12.44	1.40	68537.05
10	8.57	3.31	55.03	3.05	14.26	12.28	1.40	69830.90
11	10.30	4.11	57.20	3.67	13.26	12.44	1.41	68254.37
12	7.11	4.88	50.91	3.81	12.78	12.66	1.43	67646.54
13	7.36	4.49	52.98	3.66	13.11	12.49	1.41	68459.24
14	8.16	6.33	51.03	4.29	12.25	12.59	1.41	68440.04
15	11.36	8.21	51.97	5.41	11.90	12.79	1.42	67260.17
16	10.34	5.30	60.30	4.67	12.10	12.89	1.46	66395.56
17	9.89	3.40	63.52	3.94	12.98	12.73	1.44	66987.31
18	9.98	3.21	56.01	3.45	13.70	12.48	1.41	68676.63
19	7.09	4.08	56.99	3.65	13.12	12.78	1.38	66505.92
20	7.67	3.44	62.44	2.98	14.20	12.34	1.38	69383.21
21	7.21	4.61	51.23	3.58	13.34	12.67	1.41	67361.08
22	4.86	4.30	52.95	3.52	13.28	12.69	1.40	67631.53
23	5.45	3.25	64.58	3.06	14.09	12.51	1.37	68476.90
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.29	4.65	56.84	3.81	13.23	12.66	1.41	67553.60
最大值	12.46	8.21	65.23	5.41	14.45	12.99	1.46	69830.90
發生時間	0	15	6	15	1	3		10
最小值	4.69	3.21	47.72	2.98	11.90	12.28	1.36	63051.22
發生時間	7	18	8	20	15	10		5
零點偏移(率)	-0.05 %	0.00 %	-0.02 %	0.00 %		-0.01	0.00	0.00 %
全幅偏移(率)	0.35 %	0.22 %	-0.46 %	0.13 %		0.00	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月11日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.62	5.24	46.29	2.52	16.18	10.82	1.42	83264.84
1	11.34	6.44	53.47	2.83	18.06	10.16	1.41	84048.77
2	9.57	5.35	44.82	4.03	13.72	10.77	1.40	77415.19
3	9.25	2.54	43.00	3.47	15.84	10.44	1.38	79536.10
4	6.64	2.01	42.69	2.48	16.71	10.30	1.39	81506.95
5	5.90	9.30	45.99	2.38	16.14	10.34	1.39	81780.69
6	2.47	6.93	44.59	1.84	15.05	10.44	1.42	74034.36
7	9.93	5.59	45.43	3.06	14.69	10.70	1.43	78468.84
8	8.68	4.22	48.37	2.56	16.05	10.34	1.42	81098.33
9	10.11	4.16	43.81	2.79	16.97	10.12	1.44	81559.44
10	9.66	7.36	43.88	2.09	18.30	9.74	1.40	84651.27
11	8.65	4.58	41.64	5.06	16.25	10.13	1.43	82014.11
12	8.44	1.85	29.74	2.92	17.21	9.53	1.38	80060.92
13	10.38	1.52	33.11	3.10	16.43	9.94	1.38	79141.16
14	10.00	1.69	41.28	2.98	15.75	10.10	1.38	79794.87
15	10.08	5.38	41.37	2.75	14.98	10.16	1.38	82080.96
16	9.18	4.16	48.21	2.56	14.62	10.57	1.39	80561.16
17	10.38	5.66	61.85	1.84	17.37	10.62	1.42	81429.34
18	8.92	4.38	46.41	1.70	17.70	10.26	1.43	86162.68
19	8.31	4.22	46.74	2.03	16.86	10.48	1.40	83090.27
20	7.65	3.93	44.27	2.14	16.32	10.59	1.38	83975.61
21	8.51	4.51	49.49	2.24	15.88	10.88	1.40	82801.11
22	9.91	4.14	51.49	2.32	16.16	10.79	1.43	82622.49
23	10.05	7.56	55.41	2.20	16.92	10.61	1.43	83449.41
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.86	4.70	45.56	2.66	16.26	10.37	1.41	81439.54
最大值	11.34	9.30	61.85	5.06	18.30	10.88	1.45	86162.68
發生時間	1	5	17	11	10	21		18
最小值	2.47	1.52	29.74	1.70	13.72	9.53	1.38	74034.36
發生時間	6	13	12	18	2	12		6
零點偏移(率)	-0.02 %	-0.01 %	0.00 %	-0.06 %		0.01	0.00	0.00 %
全幅偏移(率)	0.47 %	2.22 %	0.15 %	1.34 %		0.05	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月11日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.99	7.60	47.28	2.01	15.19	10.99	1.38	81873.74
1	10.50	5.77	54.81	2.35	15.17	11.32	1.38	80772.59
2	7.87	7.55	56.10	2.91	13.54	11.39	1.38	78982.13
3	9.62	3.97	59.89	2.91	14.46	11.43	1.38	80388.51
4	7.51	3.79	56.69	2.98	13.51	11.55	1.38	81358.11
5	7.26	3.53	61.38	2.79	13.84	11.48	1.38	82204.80
6	4.79	3.71	58.13	2.23	14.28	11.39	1.36	82180.11
7	6.04	6.63	52.19	2.25	14.99	11.15	1.36	85395.29
8	6.66	3.44	61.71	2.06	15.48	11.05	1.38	83534.65
9	6.73	3.33	53.05	2.43	14.65	11.02	1.38	82790.14
10	6.83	4.06	57.15	2.25	14.84	11.08	1.37	82384.22
11	1.45	3.66	69.21	1.28	16.22	11.53	1.36	77703.20
12	1.02	3.85	55.22	1.17	16.42	11.01	1.36	81427.18
13	1.61	7.32	49.26	1.90	14.73	11.05	1.37	79905.68
14	4.77	8.33	52.74	2.69	13.63	11.07	1.36	79466.08
15	5.91	8.09	47.76	2.86	12.85	11.18	1.36	76640.44
16	4.63	3.88	61.55	2.71	13.40	11.47	1.38	77900.90
17	2.87	4.36	58.43	1.64	15.89	11.31	1.35	78655.08
18	2.91	5.48	51.46	1.51	15.90	10.80	1.36	82790.91
19	2.84	3.84	57.59	2.20	14.20	11.36	1.34	80095.39
20	3.75	5.19	59.57	2.04	14.73	11.30	1.35	78919.72
21	5.26	3.53	52.68	1.88	15.06	10.99	1.35	81560.91
22	6.31	3.52	60.23	2.17	14.50	11.41	1.35	80154.27
23	4.87	3.63	59.39	2.04	14.67	11.55	1.36	79421.39
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.46	4.92	56.39	2.22	14.67	11.25	1.37	80687.73
最大值	10.50	8.33	69.21	2.98	16.42	11.55	1.40	85395.29
發生時間	1	14	11	4	12	4		7
最小值	1.02	3.33	47.28	1.17	12.85	10.80	1.33	76640.44
發生時間	12	9	0	12	15	18		15
零點偏移(率)	-0.02 %	-0.03 %	-0.02 %	-0.01 %		-0.01	0.00	0.00 %
全幅偏移(率)	0.03 %	0.06 %	-0.80 %	0.17 %		0.02	-0.03	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								