

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月10日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	0.83	3.70	62.66	2.87	14.00	12.73	1.44	67660.29
1	0.29	6.16	48.37	4.28	12.26	13.40	1.41	60667.02
2	1.34	3.67	66.10	2.52	14.65	12.65	1.41	67367.37
3	0.20	6.64	48.39	3.16	14.43	13.46	1.43	60921.31
4	0.13	3.99	68.33	1.65	16.71	12.13	1.40	69936.48
5	1.08	14.72	59.19	2.78	15.11	12.94	1.43	69935.02
6	0.14	3.34	54.95	2.63	15.15	13.04	1.46	64795.24
7	0.14	6.60	53.99	4.11	13.52	13.92	1.37	57564.02
8	0.70	4.29	51.54	2.72	14.66	12.42	1.41	70045.54
9	0.09	4.90	62.96	3.03	14.01	12.81	1.38	67456.89
10	0.09	4.98	51.32	2.74	14.17	12.50	1.43	68934.64
11	0.39	3.83	45.19	2.30	15.42	12.16	1.37	70916.18
12	4.66	4.93	56.42	3.40	13.60	12.66	1.44	67980.04
13	9.53	7.27	46.91	4.58	12.05	12.93	1.43	66415.21
14	9.33	5.67	53.47	4.58	12.75	12.83	1.41	66925.16
15	9.80	1.97	54.88	4.32	13.49	12.47	1.39	69353.04
16	9.36	2.14	47.77	4.63	12.55	12.91	1.37	66498.58
17	9.88	2.80	49.45	4.60	12.25	12.85	1.42	67689.25
18	9.54	2.25	58.79	4.30	12.83	12.82	1.42	67412.67
19	8.53	1.74	61.58	3.44	13.86	12.41	1.40	69988.16
20	10.86	3.23	54.43	3.69	13.73	12.55	1.38	69050.53
21	8.28	5.66	54.26	3.81	13.52	12.66	1.38	68268.56
22	7.44	3.30	71.99	2.97	14.59	12.41	1.37	69628.61
23	9.54	3.67	50.47	3.70	13.54	12.65	1.36	68097.25
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.67	4.64	55.56	3.45	13.87	12.76	1.40	67229.46
最 大 值	10.86	14.72	71.99	4.63	16.71	13.92	1.89	70916.18
發生時間	20	5	22	16	4	7		11
最 小 值	0.09	1.74	45.19	1.65	12.05	12.13	1.34	57564.02
發生時間	9	19	11	4	13	4		7
零點偏移(率)	-0.01 %	0.00 %	-0.02 %	-0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	1.09 %	0.03 %	-0.33 %	0.21 %		0.06	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月10日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.69	5.27	49.69	2.03	16.42	10.57	1.49	85863.66
1	9.00	8.28	57.13	2.08	17.05	10.44	1.50	86700.99
2	8.42	3.81	47.86	1.63	17.71	10.36	1.49	86217.48
3	6.44	3.60	55.03	1.55	17.95	10.88	1.49	82302.96
4	0.56	4.31	59.44	0.69	20.47	10.69	1.49	81654.23
5	4.64	9.18	45.99	1.34	20.16	9.67	1.48	88173.10
6	8.34	8.61	33.47	2.05	19.30	9.63	1.44	90930.27
7	9.75	4.49	40.94	4.16	18.64	10.05	1.44	86801.04
8	3.45	5.59	37.94	1.05	19.74	10.07	1.47	86076.40
9	1.71	2.39	37.05	1.48	17.09	10.35	1.44	82839.34
10	1.32	1.92	47.57	1.49	17.87	10.34	1.44	83822.43
11	1.90	4.34	42.27	1.08	19.77	9.59	1.42	85253.81
12	3.39	1.86	38.72	1.59	18.61	9.88	1.43	84192.11
13	7.57	2.20	47.19	2.42	17.13	10.29	1.45	83672.52
14	8.38	2.73	46.69	2.25	17.41	10.34	1.45	81857.59
15	8.35	4.32	40.83	2.80	16.36	10.78	1.43	75744.94
16	5.93	5.43	56.51	2.44	17.01	10.68	1.43	82805.31
17	7.22	3.67	45.07	2.26	17.90	10.31	1.40	86222.08
18	9.11	2.67	43.75	2.24	17.60	10.53	1.43	85156.20
19	9.22	2.26	46.79	2.38	17.19	10.55	1.44	85941.28
20	9.25	5.72	50.43	2.82	15.30	10.98	1.43	83070.16
21	10.39	7.68	48.00	2.76	16.68	10.53	1.43	86002.30
22	9.67	3.38	56.26	2.20	16.71	10.76	1.43	84282.96
23	11.01	6.30	42.16	2.53	16.88	10.55	1.43	84539.44
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.78	4.58	46.53	2.06	17.79	10.37	1.45	84588.44
最 大 值	11.01	9.18	59.44	4.16	20.47	10.98	1.50	90930.27
發生時間	23	5	4	7	4	20		6
最 小 值	0.56	1.86	33.47	0.69	15.30	9.59	1.38	75744.94
發生時間	4	12	6	4	20	11		15
零點偏移(率)	-0.02 %	-0.01 %	-0.02 %	-0.00 %		-0.06	0.00	0.00 %
全幅偏移(率)	3.94 %	0.01 %	-0.21 %	0.33 %		-0.05	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月10日

[illegible]