

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月10日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.48	8.47	58.95	1.45	17.88	12.09	1.01	73317.31
1	2.83	6.24	45.77	1.29	19.09	11.37	1.00	78685.24
2	6.15	9.09	49.11	1.77	18.37	11.23	1.02	80416.27
3	8.29	7.38	56.88	1.95	17.15	11.79	1.02	76904.18
4	8.60	6.17	51.22	1.51	18.60	11.33	1.00	79300.57
5	6.47	12.14	50.13	2.24	17.00	11.55	0.99	76676.58
6	5.42	7.97	53.98	1.61	18.02	11.60	0.99	77526.94
7	9.74	6.68	49.59	2.15	18.76	10.96	1.00	81707.61
8	8.03	7.33	64.40	1.04	20.25	11.25	1.02	78366.44
9	8.74	9.70	51.99	1.57	18.24	11.21	1.01	80053.09
10	8.93	11.73	46.22	2.14	17.77	11.76	0.99	76084.86
11	9.72	8.45	54.85	1.92	18.61	11.34	1.02	78912.23
12	9.35	10.60	50.46	2.16	17.61	11.54	1.00	78121.54
13	9.21	9.74	55.14	1.37	18.77	11.42	0.99	78066.28
14	9.72	11.14	47.62	1.96	17.89	11.53	0.99	77731.78
15	6.65	9.52	61.10	1.11	19.62	11.24	1.00	78613.35
16	9.59	9.50	36.27	2.03	18.47	10.95	0.99	81782.84
17	9.20	9.13	45.39	1.65	18.88	11.16	1.02	80409.96
18	8.37	8.58	60.23	0.95	20.84	10.53	1.01	83242.25
19	9.29	8.82	39.83	2.23	17.12	11.27	0.99	80315.85
20	7.56	5.17	51.85	1.33	18.75	11.38	0.99	78338.57
21	7.83	7.97	47.01	1.99	17.04	11.57	1.00	77879.55
22	3.95	13.30	56.47	1.34	18.92	11.48	1.02	77320.39
23	7.64	4.65	44.42	2.51	18.52	10.44	1.00	83579.45
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.57	8.73	51.20	1.72	18.42	11.33	1.00	78889.71
最大值	9.74	13.30	64.40	2.51	20.84	12.09	1.03	83579.45
發生時間	7	22	8	23	18	0		23
最小值	0.48	4.65	36.27	0.95	17.00	10.44	0.98	73317.31
發生時間	0	23	16	18	5	23		0
零點偏移(率)	-0.01 %	-0.03 %	-0.02 %	-0.01 %		0.00		0.00 %
全幅偏移(率)	0.04 %	0.18 %	0.02 %	0.19 %		0.10		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月10日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.83	4.02	56.79	1.51	18.16	10.49	0.97	84037.43
1	0.27	5.29	47.78	2.07	19.40	10.29	0.95	83957.80
2	1.57	3.56	51.11	2.07	18.29	10.36	0.94	85120.80
3	1.05	5.00	50.03	2.41	17.31	10.49	0.94	85432.98
4	4.20	2.06	57.01	3.23	17.16	10.65	0.95	83762.40
5	0.90	3.56	59.17	0.97	19.94	10.21	0.97	84572.00
6	3.22	4.55	50.11	1.75	18.92	10.20	0.97	86012.31
7	2.75	4.84	52.55	1.55	19.14	9.80	0.97	88849.80
8	7.57	3.16	43.50	2.09	18.18	10.22	0.96	86186.48
9	9.53	5.12	46.91	2.41	18.24	10.02	0.98	87664.92
10	9.76	7.26	47.58	3.38	15.71	10.71	0.98	84617.02
11	7.02	9.76	49.79	2.36	17.72	10.47	0.98	84342.18
12	8.47	4.96	51.85	2.04	18.24	10.25	0.98	85964.50
13	9.14	4.44	52.27	1.88	18.38	9.78	0.98	88936.01
14	8.20	5.26	43.87	2.65	16.70	10.66	0.98	83919.93
15	8.47	4.11	57.68	1.91	18.15	10.17	0.97	86083.59
16	7.12	4.69	44.43	2.33	16.60	10.68	0.97	83797.39
17	7.64	4.77	46.18	1.92	17.61	10.47	0.97	85153.55
18	9.30	5.78	53.39	2.10	16.74	10.45	0.97	85978.78
19	6.42	4.87	46.80	1.95	17.57	10.54	0.97	84519.95
20	3.46	6.13	52.74	1.70	17.79	10.59	0.99	83725.77
21	0.15	9.65	51.33	1.14	18.98	10.33	0.99	84950.78
22	0.10	9.34	54.51	1.43	18.63	10.11	0.97	86418.71
23	0.08	4.92	59.90	1.09	19.67	9.57	0.97	89698.66
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.88	5.30	51.14	2.00	18.05	10.31	0.97	85570.99
最大值	9.76	9.76	59.90	3.38	19.94	10.71	1.00	89698.66
發生時間	10	11	23	10	5	10		23
最小值	0.08	2.06	43.50	0.97	15.71	9.57	0.94	83725.77
發生時間	23	4	8	5	10	23		20
零點偏移(率)	-0.02 %	-0.06 %	-0.03 %	-0.03 %		0.01		-0.10 %
全幅偏移(率)	0.04 %	0.04 %	-0.02 %	0.09 %		-0.27		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月10日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.16	7.88	47.27	1.24	16.19	10.77	1.02	78632.44
1	3.53	4.48	50.19	1.28	17.33	11.12	1.04	77586.20
2	3.82	4.75	58.55	1.40	16.72	11.14	1.04	78202.45
3	6.70	5.33	49.25	1.73	16.46	10.82	1.02	81066.13
4	3.24	5.13	61.74	1.26	17.48	11.34	1.02	75195.22
5	2.61	5.62	49.25	1.23	17.05	10.75	1.03	80685.01
6	4.17	6.42	52.24	1.34	16.46	11.19	1.04	80157.24
7	4.91	4.99	51.87	1.25	17.31	11.05	1.05	85144.81
8	5.04	4.94	51.47	1.01	17.54	10.85	1.05	81543.15
9	5.01	6.97	45.39	1.36	16.36	10.71	1.07	81834.85
10	7.76	7.03	41.01	1.73	16.32	10.46	1.06	78716.85
11	9.01	6.98	41.74	2.17	14.61	10.90	1.06	72225.13
12	9.49	5.79	49.51	1.67	15.94	10.85	1.03	77775.41
13	8.03	7.91	44.47	1.54	16.36	10.46	1.05	80754.28
14	8.18	9.51	43.69	1.81	15.64	10.70	1.07	80106.86
15	5.80	5.14	48.72	1.25	16.31	10.97	1.05	76661.26
16	5.74	6.30	43.01	1.15	16.50	10.76	1.03	78168.93
17	6.82	6.54	42.86	2.05	14.45	11.25	1.05	74796.76
18	6.90	6.03	42.62	1.29	16.24	11.04	1.05	74987.42
19	5.88	5.74	43.56	1.29	16.29	10.91	1.01	76593.43
20	6.37	7.00	39.47	1.12	16.29	10.75	1.02	78339.55
21	4.10	9.78	41.47	2.07	14.63	10.81	1.02	75562.07
22	3.05	3.93	46.52	1.25	16.29	10.50	1.04	75349.65
23	3.76	6.05	50.23	1.25	17.28	10.16	1.04	78963.01
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.50	6.26	47.34	1.45	16.34	10.84	1.04	78293.67
最大值	9.49	9.78	61.74	2.17	17.54	11.34	1.14	85144.81
發生時間	12	21	4	11	8	4		7
最小值	2.16	3.93	39.47	1.01	14.45	10.16	0.99	72225.13
發生時間	0	22	20	8	17	23		11
零點偏移(率)	-0.07 %	-0.01 %	-0.11 %	-0.02 %		0.00		0.00 %
全幅偏移(率)	0.04 %	0.08 %	-0.55 %	0.25 %		0.18		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								