

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月18日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.44	4.24	48.35	2.33	17.75	11.75	1.42	73883.55
1	9.25	4.26	55.70	2.15	18.63	11.74	1.43	73665.13
2	9.50	4.12	59.07	1.99	19.16	11.78	1.43	73284.36
3	10.56	4.73	55.42	2.21	18.41	11.96	1.43	72255.62
4	11.75	3.77	46.95	2.37	18.33	11.51	1.41	75572.34
5	13.62	12.18	48.44	2.84	16.03	12.32	1.40	72040.60
6	10.20	3.37	45.38	2.79	16.29	11.87	1.39	74078.68
7	9.55	1.90	48.63	2.52	16.43	11.96	1.39	74272.71
8	10.33	2.70	48.28	2.64	16.25	12.09	1.39	72538.94
9	11.19	2.32	48.75	2.49	16.66	12.01	1.40	73655.04
10	10.16	2.34	52.52	2.39	17.00	11.97	1.41	73190.46
11	10.05	1.93	46.97	2.30	17.77	11.79	1.42	73327.91
12	9.75	1.68	56.88	2.16	17.82	11.72	1.42	74116.81
13	9.44	2.95	45.65	2.33	17.40	11.95	1.41	72574.23
14	6.48	2.01	55.44	2.20	17.52	12.17	1.43	70935.28
15	6.06	3.20	56.07	2.03	17.82	11.72	1.43	74277.61
16	9.32	4.39	56.07	2.22	17.41	11.98	1.42	72617.23
17	8.55	7.42	66.79	2.52	17.16	12.96	1.44	65302.17
18	8.69	5.13	68.98	2.59	16.88	13.03	1.43	64617.23
19	7.98	2.25	44.34	2.18	17.70	11.99	1.42	72568.24
20	9.83	1.39	50.15	2.21	17.59	11.81	1.42	73661.12
21	9.95	1.22	48.47	2.23	17.30	11.86	1.41	73711.70
22	9.62	1.20	50.87	2.22	17.26	11.89	1.41	73786.08
23	9.15	2.36	48.93	2.40	16.43	12.10	1.42	72542.63
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.73	3.46	52.21	2.35	17.38	12.00	1.42	72603.15
最大值	13.62	12.18	68.98	2.84	19.16	13.03	1.50	75572.34
發生時間	5	5	18	5	2	18		4
最小值	6.06	1.20	44.34	1.99	16.03	11.51	1.38	64617.23
發生時間	15	22	19	2	5	4		18
零點偏移(率)	-0.04 %	-0.02 %	-0.01 %	-0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	0.86 %	0.27 %	-0.38 %	0.09 %		0.42	-0.03	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月18日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.73	8.85	43.57	1.90	17.04	9.84	1.36	65974.65
1	10.62	2.02	61.14	1.60	17.77	10.58	1.38	65687.78
2	11.78	14.08	50.16	2.44	16.21	10.66	1.38	65282.64
3	10.39	3.82	47.49	2.73	15.14	10.90	1.39	63027.80
4	10.70	1.32	58.24	3.21	14.70	11.17	1.41	64699.35
5	10.66	1.61	58.44	2.43	14.68	11.24	1.42	64690.35
6	5.66	3.85	56.88	2.39	13.81	11.34	1.46	62866.32
7	11.16	5.61	57.50	3.04	13.45	11.21	1.46	62253.57
8	11.03	5.99	46.13	2.54	15.50	9.95	1.44	62277.69
9	9.81	1.59	55.79	2.93	12.94	11.01	1.45	61619.22
10	11.19	7.01	41.98	3.96	16.43	10.55	1.43	60271.46
11	14.64	2.09	61.04	4.36	16.38	10.76	1.39	62920.73
12	8.66	1.87	50.33	4.32	14.65	10.54	1.38	64541.71
13	10.32	1.60	41.40	2.39	15.61	10.37	1.43	64500.01
14	11.19	4.61	54.71	2.35	14.75	10.61	1.44	64843.65
15	8.77	3.07	69.98	2.10	15.52	11.32	1.46	62323.61
16	10.47	1.79	52.67	1.74	17.23	10.34	1.45	64802.50
17	9.89	1.64	57.05	2.08	15.17	10.89	1.46	63297.08
18	10.83	2.14	48.65	1.90	16.50	10.66	1.44	63370.76
19	11.03	1.03	56.19	2.22	15.51	10.86	1.44	63855.39
20	10.49	1.24	65.91	2.02	16.29	10.99	1.45	66354.42
21	10.11	1.66	47.27	2.35	15.25	11.20	1.46	65830.72
22	11.52	0.91	62.33	2.42	14.80	11.18	1.46	65157.96
23	9.77	1.77	48.55	2.44	15.10	11.08	1.46	64046.62
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.43	3.38	53.89	2.58	15.43	10.80	1.43	63937.33
最大值	14.64	14.08	69.98	4.36	17.77	11.34	1.47	66354.42
發生時間	11	2	15	11	1	6		20
最小值	5.66	0.91	41.40	1.60	12.94	9.84	1.36	60271.46
發生時間	6	22	13	1	9	0		10
零點偏移(率)	0.00 %	-0.00 %	-0.01 %	0.00 %		-0.02	0.00	0.00 %
全幅偏移(率)	0.02 %	-0.09 %	-0.11 %	0.03 %		0.42	-0.06	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月18日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	13.49	6.79	51.07	2.43	14.40	11.19	1.71	81071.69
1	10.62	4.39	56.84	2.01	15.74	11.27	1.72	81611.19
2	11.62	4.93	50.19	1.93	15.52	11.10	1.72	81244.41
3	10.87	9.51	52.03	2.45	14.14	11.11	1.72	82317.48
4	9.19	8.83	53.70	2.81	13.56	11.40	1.74	83088.02
5	12.62	11.50	60.42	3.16	12.94	11.93	1.77	83289.57
6	11.02	7.26	55.92	3.22	12.91	11.60	1.76	84652.85
7	13.18	6.26	55.21	3.63	12.41	12.09	1.76	84690.43
8	12.30	11.37	53.93	3.54	12.61	11.71	1.78	79811.12
9	13.59	5.79	53.50	3.61	12.35	11.74	1.75	80644.64
10	12.44	6.27	53.43	3.50	12.50	12.02	1.75	82241.11
11	10.28	2.48	55.10	3.26	12.71	12.15	1.80	82378.94
12	8.96	2.33	55.42	2.98	12.89	11.86	1.80	81917.98
13	10.29	6.97	51.56	3.18	12.89	11.53	1.79	79559.63
14	10.48	4.75	53.54	3.44	12.46	11.95	1.79	80667.30
15	12.65	2.71	53.38	2.75	13.72	11.70	1.79	81606.60
16	10.52	1.87	54.97	2.28	14.42	11.55	1.79	80039.82
17	6.70	1.30	57.29	1.51	16.37	11.26	1.78	83061.40
18	9.76	2.51	49.56	1.87	15.02	11.32	1.80	82093.08
19	10.73	1.77	52.66	1.88	15.71	11.19	1.80	84653.36
20	10.52	4.68	56.01	2.51	14.17	11.61	1.78	83808.90
21	12.29	2.83	50.77	2.19	15.14	11.29	1.78	85086.30
22	11.79	4.87	50.65	2.78	13.94	11.52	1.80	81645.14
23	9.06	5.08	48.54	2.78	13.98	11.45	1.80	81391.03
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	11.04	5.29	53.57	2.74	13.85	11.56	1.77	82190.50
最大值	13.59	11.50	60.42	3.63	16.37	12.15	1.81	85086.30
發生時間	9	5	5	7	17	11		21
最小值	6.70	1.30	48.54	1.51	12.35	11.10	1.70	79559.63
發生時間	17	17	23	17	9	2		13
零點偏移(率)	0.00 %	0.00 %	-0.03 %	-0.00 %		0.02	0.00	0.00 %
全幅偏移(率)	1.64 %	0.00 %	-0.15 %	0.14 %		0.37	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								