

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月05日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.01	11.31	53.99	1.82	18.95	10.90	1.21	82964.66
1	10.43	11.33	49.02	3.77	18.74	10.50	1.22	85872.41
2	9.98	11.48	45.47	3.45	18.91	10.85	1.21	82980.79
3	4.41	11.60	60.25	2.27	18.78	11.16	1.22	80969.90
4	7.96	11.09	61.96	2.50	19.46	10.64	1.23	84633.67
5	3.94	13.85	55.16	2.08	18.67	11.06	1.20	82728.58
6	8.88	13.70	60.91	1.93	19.02	10.84	1.20	83058.16
7	9.39	13.93	50.67	1.85	17.34	11.21	1.19	81909.87
8	9.30	13.65	56.06	1.86	18.10	10.92	1.19	83925.73
9	7.69	13.68	55.61	1.63	17.93	10.97	1.18	83362.23
10	8.85	14.14	60.23	1.46	18.05	11.29	1.20	80683.64
11	5.10	14.01	50.68	1.55	17.20	11.30	1.21	81287.23
12	9.42	13.47	60.56	2.22	16.18	11.90	1.20	76919.63
13	8.77	11.43	55.29	1.53	18.16	11.10	1.23	81504.95
14	10.58	11.71	52.16	2.21	16.45	11.54	1.21	80033.80
15	9.15	11.62	49.11	2.54	15.65	11.48	1.20	81101.89
16	14.72	11.97	57.64	2.57	17.01	11.45	1.21	80138.47
17	13.49	13.19	54.96	1.89	14.47	12.00	1.23	77667.03
18	6.60	11.84	63.94	1.55	15.05	11.85	1.20	78782.43
19	9.14	11.59	58.50	2.06	17.05	11.44	1.19	80336.08
20	9.09	11.48	52.94	2.47	16.43	11.41	1.19	81670.86
21	14.96	11.55	56.96	2.89	16.66	11.49	1.20	80925.82
22	7.34	11.51	55.18	1.91	16.74	11.48	1.19	80680.66
23	9.60	11.43	64.11	2.23	18.10	11.17	1.20	81987.39
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.95	12.36	55.89	2.18	17.46	11.25	1.20	81505.24
最大值	14.96	14.14	64.11	3.77	19.46	12.00	1.25	85872.41
發生時間	21	10	23	1	4	17		1
最小值	3.94	11.09	45.47	1.46	14.47	10.50	1.18	76919.63
發生時間	5	4	2	10	17	1		12
零點偏移(率)	-0.09 %	0.00 %	-0.33 %	0.00 %		-0.02	-0.01	0.10 %
全幅偏移(率)	-1.38 %	-1.66 %	0.06 %	-0.33 %		-0.05	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月05日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.16	12.07	45.05	0.83	18.94	10.57	0.99	81281.27
1	0.13	12.30	64.58	2.28	18.42	10.66	1.00	83494.91
2	0.13	12.20	57.91	2.03	17.80	10.83	1.02	82738.72
3	0.21	12.40	44.31	1.29	17.70	11.08	1.02	81152.66
4	0.34	12.11	61.45	0.89	19.35	10.57	1.02	83993.52
5	0.60	12.35	54.86	0.63	19.68	10.73	1.01	81667.62
6	0.79	13.20	44.01	0.70	20.59	10.34	0.98	89546.21
7	0.59	13.16	48.55	0.80	20.12	10.26	0.97	84841.30
8	0.65	13.13	59.10	1.66	18.88	10.51	0.97	84169.40
9	0.33	13.19	56.05	1.75	17.81	10.69	0.98	83891.21
10	0.61	13.36	70.58	1.10	18.41	10.77	0.99	82767.22
11	1.19	14.58	60.82	1.81	16.49	11.33	0.99	79776.95
12	1.34	12.83	57.23	1.40	17.61	11.00	0.98	78700.94
13	0.31	12.87	46.65	2.07	17.70	10.61	0.97	79164.36
14	0.26	12.74	50.57	2.53	17.03	10.81	0.97	81933.96
15	0.26	12.43	60.27	2.29	16.86	11.06	0.97	81784.54
16	7.61	12.31	60.27	2.07	17.36	10.76	0.98	83544.84
17	10.82	12.58	63.54	1.82	17.79	11.04	1.00	80701.42
18	4.36	12.25	47.73	1.43	18.72	10.63	0.98	80883.23
19	0.96	11.97	47.95	1.63	18.07	10.58	0.97	80844.07
20	1.04	11.87	46.37	1.87	18.08	10.46	0.97	81449.28
21	2.28	11.74	48.97	0.98	19.61	10.09	0.97	84862.18
22	2.55	12.03	52.75	0.64	19.65	10.34	0.98	82408.63
23	2.13	12.16	49.87	1.04	19.51	10.30	0.98	82914.53
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	1.65	12.58	54.14	1.48	18.42	10.67	0.99	82438.04
最大值	10.82	14.58	70.58	2.53	20.59	11.33	1.03	89546.21
發生時間	17	11	10	14	6	11		6
最小值	0.13	11.74	44.01	0.63	16.49	10.09	0.95	78700.94
發生時間	1	21	6	5	11	21		12
零點偏移(率)	-0.14 %	-0.00 %	-0.07 %	-0.01 %		0.00	-0.01	-0.10 %
全幅偏移(率)	2.22 %	-2.74 %	0.28 %	-1.42 %		0.15	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月05日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.22	12.21	45.74	3.07	21.09	8.82	1.37	77384.06
1	2.48	10.82	40.77	4.40	18.92	9.39	1.36	78642.33
2	2.65	10.67	61.42	2.75	18.86	9.39	1.38	77685.40
3	4.86	10.77	52.29	2.52	17.49	9.70	1.37	76120.21
4	3.99	10.76	53.00	2.78	20.20	9.31	1.36	75089.99
5	4.63	10.93	55.39	2.63	21.07	9.11	1.36	76300.89
6	3.54	11.69	43.49	2.51	20.75	8.87	1.37	77917.63
7	5.77	11.81	49.09	2.82	19.77	9.21	1.42	82282.21
8	5.68	11.01	56.65	2.85	18.67	9.59	1.43	77983.42
9	4.34	11.00	61.39	2.67	18.65	9.67	1.43	76915.72
10	5.65	10.72	50.23	2.66	18.36	9.36	1.43	77272.00
11	5.87	12.37	53.95	2.77	20.09	9.17	1.42	77437.90
12	6.17	12.03	42.74	2.00	20.18	8.65	1.39	75098.89
13	4.22	11.88	38.32	1.56	20.35	8.30	1.40	74035.89
14	7.26	11.78	45.59	1.75	18.98	9.03	1.43	77478.97
15	4.46	11.72	52.68	1.68	18.12	9.36	1.40	75960.60
16	7.64	11.65	55.56	1.83	17.52	9.34	1.36	75360.69
17	10.03	12.12	50.14	2.24	20.57	8.66	1.38	76188.93
18	7.98	11.82	48.24	1.87	18.43	9.17	1.42	76073.43
19	7.57	12.41	52.41	1.83	19.73	9.22	1.43	75960.10
20	8.02	11.83	45.19	2.22	20.18	8.96	1.43	78474.24
21	7.53	11.25	59.68	0.92	18.41	9.91	1.43	76992.84
22	7.91	10.81	58.42	1.49	19.52	9.34	1.43	75829.78
23	3.78	11.18	49.00	2.62	20.04	8.93	1.41	76585.66
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.64	11.47	50.89	2.35	19.41	9.19	1.40	76877.99
最大值	10.03	12.41	61.42	4.40	21.09	9.91	1.43	82282.21
發生時間	17	19	2	1	0	21		7
最小值	2.48	10.67	38.32	0.92	17.49	8.30	1.35	74035.89
發生時間	1	2	13	21	3	13		13
零點偏移(率)	0.00 %	-0.04 %	-0.04 %	-0.00 %		-0.04	-0.01	-0.10 %
全幅偏移(率)	1.99 %	-0.03 %	1.73 %	0.28 %		0.30	0.04	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								