

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年01月30日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.90	12.61	52.48	1.46	15.92	12.00	0.81	76901.07
1	10.16	12.49	52.69	1.32	17.71	11.67	0.81	78597.45
2	9.99	12.54	42.16	2.72	16.10	11.39	0.81	82620.30
3	9.76	12.59	33.80	2.56	15.84	11.45	0.81	81983.79
4	8.86	12.68	55.05	2.23	15.31	12.17	0.79	75981.52
5	9.02	11.88	40.21	2.50	14.74	11.69	0.90	77663.02
6	10.25	12.16	43.75	2.35	15.33	11.90	0.93	78534.58
7	9.86	12.01	47.18	2.44	15.24	11.75	0.92	80280.52
8	9.43	12.35	49.13	2.80	15.08	11.92	0.92	78706.72
9	10.98	13.45	44.99	2.75	15.14	11.41	0.92	82815.68
10	10.53	12.37	40.02	2.95	14.35	11.86	0.95	79641.44
11	9.76	12.68	53.68	2.06	15.29	12.25	0.97	75551.10
12	9.84	12.06	52.98	2.57	14.65	11.66	0.96	80832.72
13	11.03	14.26	42.41	3.22	14.09	11.84	0.93	79544.27
14	9.18	13.08	58.44	2.53	15.04	12.36	0.93	74159.86
15	9.81	12.95	55.49	1.56	16.60	11.59	0.94	79455.83
16	10.04	13.06	56.09	2.83	15.12	11.37	0.96	82360.05
17	10.55	11.92	58.05	2.59	14.98	11.45	0.93	82439.37
18	9.36	11.89	50.99	3.58	13.28	11.87	0.92	80108.92
19	9.29	12.74	46.47	3.17	13.67	12.27	0.92	75914.10
20	11.43	13.40	57.28	1.94	15.26	12.00	0.92	77860.37
21	12.63	12.23	61.40	5.29	15.57	10.99	0.92	85981.34
22	9.32	12.31	58.85	5.36	14.57	11.80	0.92	79868.15
23	11.44	13.86	50.65	2.92	15.46	11.53	0.93	81325.65
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.14	12.65	50.18	2.74	15.18	11.76	0.91	79546.99
最大值	12.63	14.26	61.40	5.36	17.71	12.36	0.98	85981.34
發生時間	21	13	21	22	1	14		21
最小值	8.86	11.88	33.80	1.32	13.28	10.99	0.79	74159.86
發生時間	4	5	3	1	18	21		14
零點偏移(率)	-0.19 %	-0.01 %	-0.01 %	-0.01 %		-0.11	-0.01	0.30 %
全幅偏移(率)	1.56 %	0.89 %	-0.32 %	0.03 %		0.10	-0.06	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年01月30日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.05	12.63	41.21	1.94	16.67	10.52	0.99	77657.04
1	11.37	12.27	45.88	2.17	17.85	10.58	0.99	75552.87
2	12.29	11.85	46.39	2.87	17.46	10.11	0.98	77837.11
3	9.64	11.62	38.08	2.80	16.34	10.34	0.98	75136.24
4	10.99	12.09	45.57	3.06	16.15	10.80	0.97	76450.34
5	9.11	12.32	51.94	2.71	15.77	11.09	0.97	77010.98
6	9.03	12.09	52.86	2.55	15.93	10.85	0.99	73251.91
7	11.57	12.29	53.95	2.71	15.34	11.13	0.99	75031.66
8	10.45	12.02	59.85	2.70	15.62	10.82	0.98	77456.91
9	9.69	11.92	45.76	3.16	15.86	10.63	0.98	74452.27
10	6.83	11.76	35.41	4.38	16.83	10.10	1.01	75086.65
11	12.16	12.26	66.30	4.15	17.42	9.93	1.02	77621.69
12	9.14	12.13	64.76	2.99	15.59	10.94	1.00	75503.01
13	12.26	15.31	60.95	3.66	15.90	10.52	0.98	78927.37
14	10.40	12.42	64.79	1.63	15.81	11.41	1.02	77458.44
15	11.72	12.08	54.50	2.98	16.82	10.97	0.98	77896.97
16	11.43	11.48	57.75	1.85	16.09	10.57	1.00	76701.93
17	10.67	11.56	44.62	1.51	15.92	10.64	1.00	75672.53
18	10.65	11.79	47.21	1.82	14.82	10.86	0.98	75378.18
19	11.49	11.70	47.36	2.09	15.38	10.78	0.97	75178.28
20	10.57	11.70	44.95	2.04	15.28	10.74	0.97	74836.69
21	10.79	12.15	48.73	2.60	15.81	10.92	0.97	76843.60
22	12.15	11.69	44.88	1.97	15.65	10.72	0.97	76786.00
23	9.54	11.41	44.52	1.76	16.49	10.37	0.97	75967.32
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.58	12.11	50.34	2.59	16.12	10.68	0.99	76237.33
最大值	12.29	15.31	66.30	4.38	17.85	11.41	1.02	78927.37
發生時間	2	13	11	10	1	14		13
最小值	6.83	11.41	35.41	1.51	14.82	9.93	0.96	73251.91
發生時間	10	23	10	17	18	11		6
零點偏移(率)	-0.10 %	0.01 %	-0.05 %	-0.01 %		-0.07	-0.01	0.00 %
全幅偏移(率)	-1.50 %	-0.03 %	-0.03 %	-0.39 %		-0.01	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年01月30日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.40	11.38	57.30	1.81	17.75	10.05	1.48	73950.00
1	9.00	11.63	50.38	1.87	18.42	9.93	1.48	75032.68
2	9.29	11.67	47.19	2.03	15.61	10.25	1.48	71485.78
3	8.85	11.78	46.94	2.06	16.54	9.90	1.48	71294.53
4	8.94	11.14	46.52	1.89	16.34	9.97	1.48	70450.70
5	8.37	11.05	48.86	2.11	15.74	9.97	1.48	70450.80
6	8.65	10.96	47.90	2.05	16.03	9.82	1.48	71434.61
7	8.71	10.86	45.89	2.09	16.22	9.72	1.46	68390.06
8	8.79	11.62	45.87	2.44	15.69	9.97	1.45	70485.69
9	9.49	11.46	40.80	2.19	16.92	9.32	1.43	70033.67
10	8.82	11.06	38.61	2.02	17.36	9.28	1.43	71193.26
11	8.64	11.63	37.30	2.12	16.02	9.35	1.44	71005.38
12	9.24	11.21	41.28	2.03	16.58	9.18	1.43	71251.43
13	8.18	13.42	42.79	3.27	14.36	10.18	1.43	66044.16
14	6.43	14.16	53.50	3.77	13.77	11.26	1.43	62978.33
15	7.21	12.37	44.13	3.06	14.73	10.29	1.42	70275.96
16	9.47	11.40	38.17	2.53	15.78	9.46	1.43	73697.78
17	9.70	11.21	33.89	1.94	16.43	9.02	1.43	72358.22
18	8.38	12.05	28.90	3.25	15.51	8.79	1.43	71141.99
19	11.89	11.56	36.67	3.17	16.58	9.05	1.43	69864.15
20	13.04	11.20	36.11	2.65	16.81	9.20	1.43	72455.21
21	9.60	10.96	41.27	2.24	15.28	9.87	1.43	70926.47
22	9.69	11.40	39.52	1.90	16.33	9.59	1.43	72347.10
23	9.81	13.03	37.86	1.25	16.13	9.49	1.43	70160.07
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.11	11.68	42.82	2.32	16.12	9.70	1.45	70779.50
最大值	13.04	14.16	57.30	3.77	18.42	11.26	1.48	75032.68
發生時間	20	14	0	14	1	14		1
最小值	6.43	10.86	28.90	1.25	13.77	8.79	1.40	62978.33
發生時間	14	7	18	23	14	18		14
零點偏移(率)	-0.08 %	0.01 %	-0.04 %	-0.01 %		-0.08	-0.01	0.00 %
全幅偏移(率)	0.04 %	0.53 %	-0.03 %	-0.08 %		0.17	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								