

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月14日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.82	0.95	47.42	0.45	21.49	10.57	1.38	81816.94
1	8.78	1.07	63.29	0.32	21.50	11.45	1.36	75503.77
2	2.12	5.50	66.20	1.21	18.68	13.22	1.60	63768.58
3	1.41	1.07	43.00	0.83	20.14	12.06	1.46	71742.19
4	6.41	2.45	48.26	0.41	21.07	11.01	1.38	79440.34
5	6.50	4.54	52.62	0.36	21.93	10.43	1.34	83090.12
6	10.04	4.54	56.31	0.34	21.58	10.77	1.33	80056.03
7	9.48	3.93	57.29	0.45	20.87	11.79	1.33	73137.32
8	3.95	3.43	60.70	0.96	19.33	12.46	1.39	69333.85
9	8.36	1.93	51.72	0.28	21.42	10.88	1.35	79932.96
10	9.83	13.86	45.76	0.20	22.05	10.51	1.34	81906.15
11	9.64	1.89	53.71	0.32	21.73	10.86	1.34	79634.40
12	9.47	8.28	53.64	0.89	20.01	11.93	1.35	72266.04
13	12.29	6.57	45.25	0.19	22.69	10.51	1.36	80981.13
14	9.80	11.37	49.34	1.28	18.24	11.63	1.38	76285.86
15	11.34	2.39	60.85	1.81	18.06	11.83	1.38	74120.13
16	9.84	1.57	49.72	0.86	20.06	11.33	1.38	77439.73
17	19.04	11.78	51.29	1.15	20.19	11.21	1.40	78397.27
18	10.92	3.12	46.48	2.31	19.37	11.20	1.38	78797.37
19	11.29	6.08	50.50	0.94	20.37	11.16	1.37	76747.33
20	10.11	6.80	51.97	1.19	19.55	11.99	1.38	72360.78
21	10.83	5.04	60.58	0.71	20.49	11.89	1.38	72212.97
22	3.10	10.92	69.27	1.14	18.59	13.42	1.49	61664.18
23	0.43	9.56	68.13	1.09	19.42	13.83	1.81	57712.02
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.57	5.36	54.30	0.82	20.37	11.58	1.40	74931.14
最大值	19.04	13.86	69.27	2.31	22.69	13.83	2.10	83090.12
發生時間	17	10	22	18	13	23		5
最小值	0.43	0.95	43.00	0.19	18.06	10.43	1.33	57712.02
發生時間	23	0	3	13	15	5		23
零點偏移(率)	-0.02 %	-0.02 %	-0.00 %	-0.00 %		0.03	0.00	0.00 %
全幅偏移(率)	-0.48 %	-0.42 %	-0.22 %	0.06 %		0.37	-0.03	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月14日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.08	4.73	55.98	1.53	18.89	10.09	1.49	69069.42
1	9.12	0.94	46.18	1.39	19.58	10.92	1.50	63748.08
2	10.20	1.34	61.52	1.46	20.67	10.27	1.50	66900.68
3	10.10	1.81	50.90	1.38	20.24	9.88	1.50	69577.59
4	8.89	0.65	66.08	0.96	20.90	10.36	1.49	66306.62
5	7.89	3.82	66.68	0.85	20.72	10.80	1.50	63837.70
6	9.70	1.57	63.99	0.62	22.61	9.63	1.49	61672.88
7	10.94	3.70	47.74	1.33	22.10	9.20	1.47	72078.98
8	10.42	3.08	47.45	1.61	20.00	9.73	1.46	70379.18
9	10.40	2.39	52.46	1.48	19.98	9.93	1.47	69773.54
10	11.07	10.83	54.33	4.03	17.92	10.81	1.49	65324.61
11	10.35	0.53	54.20	2.14	17.82	10.98	1.49	63902.64
12	10.50	1.30	49.07	1.63	19.77	9.84	1.49	70079.89
13	10.99	2.63	45.38	1.76	19.25	9.80	1.49	69022.02
14	13.75	3.36	57.72	2.47	17.83	10.41	1.49	67311.13
15	10.64	2.78	59.53	2.25	17.13	10.85	1.48	66164.49
16	11.52	2.68	62.12	2.50	16.72	11.23	1.49	64053.16
17	14.68	3.38	56.28	2.37	17.58	10.61	1.46	67336.30
18	12.48	5.13	56.72	2.58	17.26	10.98	1.49	64990.16
19	11.09	1.65	55.78	2.06	18.52	10.31	1.49	67731.15
20	10.06	6.89	58.55	1.77	18.50	10.84	1.49	64838.54
21	10.41	6.17	62.80	1.84	18.00	10.59	1.49	67181.58
22	9.96	6.06	56.53	1.74	18.65	10.60	1.49	65938.85
23	10.03	6.17	58.57	2.03	17.21	10.91	1.50	65127.43
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.64	3.48	56.11	1.82	19.08	10.40	1.49	66764.44
最大值	14.68	10.83	66.68	4.03	22.61	11.23	1.54	72078.98
發生時間	17	10	5	10	6	16		7
最小值	7.89	0.53	45.38	0.62	16.72	9.20	1.46	61672.88
發生時間	5	11	13	6	16	7		6
零點偏移(率)	-0.01 %	-0.02 %	-0.01 %	0.00 %		-0.04	0.00	0.00 %
全幅偏移(率)	1.66 %	-0.25 %	0.04 %	0.25 %		0.11	-0.06	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月14日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.24	1.61	58.00	1.77	16.17	10.88	1.34	85757.38
1	6.94	2.06	58.53	1.44	17.66	10.88	1.33	85051.86
2	4.38	1.48	61.97	1.45	18.31	10.67	1.33	88317.92
3	7.06	1.41	56.96	1.45	17.86	10.69	1.31	88819.10
4	5.68	6.95	58.81	1.63	16.47	10.83	1.30	89737.27
5	8.04	1.74	62.52	1.65	17.46	10.89	1.31	87228.95
6	2.95	3.18	68.37	1.73	16.87	12.21	1.31	75840.73
7	8.29	6.83	53.57	1.70	18.51	10.05	1.32	81498.77
8	9.88	7.39	48.66	1.99	16.24	10.51	1.33	85864.38
9	7.92	2.47	53.35	2.33	15.55	10.82	1.33	81795.88
10	10.28	1.66	48.28	1.91	16.47	10.66	1.34	85195.10
11	11.41	3.49	50.28	2.38	15.85	10.64	1.36	87425.66
12	9.39	2.26	52.01	1.83	16.26	10.85	1.36	86092.18
13	9.74	1.94	58.21	1.86	15.78	11.50	1.38	82257.69
14	7.56	2.67	53.16	2.10	15.81	11.37	1.38	82596.45
15	10.38	2.24	54.76	2.44	14.98	11.15	1.38	84413.45
16	8.53	1.32	54.44	2.24	14.96	11.30	1.38	81592.71
17	10.83	3.10	52.39	2.01	15.80	10.86	1.37	83934.08
18	11.18	3.94	54.19	1.97	16.71	10.82	1.38	84756.16
19	10.32	3.39	54.00	1.62	17.41	10.67	1.39	84744.17
20	12.89	5.12	56.03	1.90	15.88	10.98	1.39	85356.10
21	3.82	4.79	62.64	1.67	15.93	11.11	1.38	82674.78
22	3.98	4.72	57.16	1.37	16.84	10.81	1.38	82597.48
23	9.02	5.12	53.32	1.59	16.32	10.71	1.38	86468.37
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.36	3.37	55.90	1.83	16.50	10.91	1.35	84584.03
最大值	12.89	7.39	68.37	2.44	18.51	12.21	1.42	89737.27
發生時間	20	8	6	15	7	6		4
最小值	2.95	1.32	48.28	1.37	14.96	10.05	1.30	75840.73
發生時間	6	16	10	22	16	7		6
零點偏移(率)	0.00 %	-0.03 %	-0.09 %	-0.00 %		0.01	0.00	0.00 %
全幅偏移(率)	0.06 %	-0.35 %	-0.25 %	0.00 %		0.43	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								