

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月29日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.48	2.10	57.01	3.48	17.90	11.64	1.46	75027.18
1	14.09	9.34	54.32	3.55	18.70	11.69	1.46	74054.72
2	11.26	2.93	55.66	3.61	18.29	11.42	1.46	76966.20
3	7.20	3.00	59.31	3.50	17.43	11.81	1.46	75079.06
4	9.82	7.37	49.99	3.50	17.27	11.63	1.46	76365.73
5	7.12	5.17	60.20	3.53	17.81	12.01	1.43	74006.05
6	10.63	2.76	66.74	3.40	18.88	11.60	1.43	75482.91
7	9.18	4.09	63.90	3.20	19.32	11.29	1.44	76951.94
8	7.36	3.33	43.98	2.56	20.67	10.51	1.41	82148.72
9	0.86	2.45	59.82	3.12	18.57	11.37	1.40	76510.33
10	0.14	2.48	65.28	3.15	19.64	11.47	1.40	75276.58
11	3.52	2.11	43.43	3.09	19.34	11.16	1.38	78300.68
12	10.35	2.53	50.99	3.38	19.05	11.33	1.39	76385.96
13	8.43	1.86	56.87	3.22	19.56	11.34	1.39	75927.39
14	6.10	2.09	52.56	3.34	19.41	11.69	1.39	74212.33
15	6.72	1.53	55.71	3.10	19.22	11.11	1.40	78595.21
16	8.29	3.04	50.17	3.40	18.05	11.51	1.39	75850.72
17	9.79	1.66	66.96	3.31	19.67	11.33	1.38	77033.00
18	8.85	2.26	54.56	3.44	18.91	11.70	1.38	74253.47
19	6.85	2.28	59.22	3.17	19.67	11.45	1.39	75765.52
20	7.50	2.26	66.38	3.42	19.25	11.94	1.39	71572.04
21	13.39	1.23	53.33	2.82	20.78	10.41	1.38	81963.91
22	10.16	5.46	62.24	3.72	17.72	12.19	1.38	70139.95
23	11.05	4.26	62.24	3.55	19.45	11.74	1.39	72481.50
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.34	3.23	57.12	3.31	18.94	11.47	1.41	75847.96
最大值	14.09	9.34	66.96	3.72	20.78	12.19	1.48	82148.72
發生時間	1	1	17	22	21	22		8
最小值	0.14	1.23	43.43	2.56	17.27	10.41	1.37	70139.95
發生時間	10	21	11	8	4	21		22
零點偏移(率)	0.00 %	0.00 %	-0.01 %	-0.00 %		0.05	0.00	0.00 %
全幅偏移(率)	0.02 %	-0.15 %	-0.21 %	-0.00 %		0.33	-0.03	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月29日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	13.61	2.27	53.98	2.50	15.26	10.36	1.42	63017.29
1	9.71	5.58	45.68	2.14	16.14	10.29	1.41	62092.51
2	9.89	6.65	49.37	2.45	15.23	9.92	1.40	62127.52
3	10.80	5.10	55.40	2.41	15.37	9.81	1.38	64621.12
4	10.67	4.15	48.71	2.58	14.96	10.50	1.38	62042.63
5	9.60	2.73	59.96	2.32	16.19	10.87	1.39	63284.85
6	11.57	2.83	57.70	1.88	17.98	10.32	1.34	66822.08
7	6.74	4.75	58.62	2.09	15.43	10.82	1.34	61332.20
8	5.60	1.83	61.90	2.07	14.68	11.27	1.37	60474.51
9	6.45	1.39	57.66	1.85	16.05	10.67	1.38	66678.33
10	10.76	2.85	62.09	2.06	16.27	10.75	1.38	66676.56
11	8.88	4.73	54.49	2.24	15.37	11.05	1.38	63876.89
12	7.16	1.44	68.05	1.82	16.15	10.94	1.38	64355.75
13	8.32	2.04	63.18	1.70	17.03	10.77	1.38	65091.97
14	7.00	1.81	54.41	1.46	17.89	10.36	1.38	66608.44
15	9.85	5.96	65.67	1.94	16.39	10.88	1.38	64573.86
16	9.36	1.94	62.59	2.05	15.90	11.10	1.38	63470.32
17	9.31	1.67	61.99	1.54	18.06	10.41	1.37	65862.28
18	11.16	2.09	55.39	2.05	16.45	10.83	1.36	64761.87
19	7.48	2.01	68.43	1.92	16.75	11.13	1.38	63158.72
20	11.95	3.61	60.07	2.13	16.97	10.75	1.38	66226.23
21	9.92	1.96	63.57	2.06	16.76	10.83	1.38	65502.62
22	10.51	1.35	63.97	1.66	18.13	10.59	1.39	66356.52
23	10.11	3.21	60.72	1.60	18.09	10.52	1.40	66577.74
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.43	3.08	58.90	2.02	16.40	10.66	1.38	64399.70
最大值	13.61	6.65	68.43	2.58	18.13	11.27	1.43	66822.08
發生時間	0	2	19	4	22	8		6
最小值	5.60	1.35	45.68	1.46	14.68	9.81	1.33	60474.51
發生時間	8	22	1	14	8	3		8
零點偏移(率)	-0.11 %	-0.00 %	-0.00 %	-0.00 %		-0.04	0.00	0.00 %
全幅偏移(率)	0.91 %	-0.06 %	0.24 %	0.07 %		0.27	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月29日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.91	4.98	51.58	3.27	13.10	10.89	1.84	78533.61
1	9.75	2.38	61.66	2.79	13.88	10.91	1.83	78073.96
2	13.02	4.77	55.38	3.64	13.51	10.73	1.84	80540.08
3	7.19	4.20	57.54	2.73	13.91	10.73	1.85	82863.13
4	9.17	3.42	60.64	2.42	15.44	10.59	1.84	82390.89
5	8.94	3.37	61.08	2.03	16.66	9.99	1.84	86202.01
6	5.08	5.32	48.97	1.75	17.11	9.91	1.84	85335.78
7	5.77	6.61	62.01	2.31	14.63	10.14	1.83	83887.78
8	6.14	2.45	46.85	2.17	14.34	10.32	1.84	80730.50
9	7.04	0.86	58.78	2.30	14.42	10.42	1.85	80651.35
10	8.46	1.42	58.09	2.25	15.35	10.56	1.87	82654.60
11	9.37	0.96	65.10	2.41	14.88	10.82	1.90	82282.39
12	8.03	0.68	56.96	1.89	15.87	10.42	1.88	81045.95
13	6.70	0.82	65.16	2.05	15.65	10.65	1.89	82773.35
14	5.52	0.96	56.70	1.95	15.29	10.90	1.89	85295.35
15	9.73	2.73	66.62	2.63	14.37	10.87	1.89	84869.48
16	9.08	0.99	62.80	2.07	15.81	10.86	1.89	84293.37
17	4.04	0.98	63.22	2.08	15.06	11.24	1.86	81198.24
18	8.73	5.56	65.13	2.04	16.36	10.72	1.86	87777.28
19	1.79	8.03	66.20	2.15	15.50	11.96	1.88	77356.25
20	5.37	1.82	49.32	1.98	15.81	10.86	1.89	87976.61
21	8.23	1.73	65.52	2.32	15.24	11.18	1.88	83958.75
22	10.37	1.66	64.15	2.24	15.45	11.13	1.89	85751.89
23	10.75	5.02	63.60	2.15	15.66	11.09	1.87	85028.18
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.88	2.99	59.71	2.32	15.14	10.75	1.86	82977.95
最大值	13.02	8.03	66.62	3.64	17.11	11.96	1.90	87976.61
發生時間	2	19	15	2	6	19		20
最小值	1.79	0.68	46.85	1.75	13.10	9.91	1.82	77356.25
發生時間	19	12	8	6	0	6		19
零點偏移(率)	-0.01 %	0.00 %	-0.02 %	-0.00 %		0.01	0.00	0.00 %
全幅偏移(率)	1.07 %	-0.33 %	-0.17 %	-0.07 %		0.45	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								