

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月18日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.71	4.08	47.92	2.54	14.96	11.74	1.03	81611.76
1	5.63	2.09	53.95	3.33	14.18	12.57	1.06	72831.36
2	3.75	2.84	55.44	1.48	16.57	12.64	1.06	73247.38
3	8.44	2.45	55.28	1.14	17.57	11.52	1.06	82373.51
4	9.02	4.18	46.69	2.77	14.71	12.02	1.04	80682.49
5	9.76	6.17	65.06	2.94	14.30	12.20	1.02	76293.48
6	10.78	5.06	52.48	2.22	16.48	11.65	1.02	82491.39
7	10.02	4.92	52.24	1.83	16.03	11.76	1.02	81856.98
8	7.23	4.81	55.94	1.40	16.32	11.94	1.02	80580.45
9	7.86	4.29	47.23	2.11	15.07	11.78	1.02	80878.16
10	7.76	4.61	56.00	1.67	15.60	12.07	1.03	76581.44
11	9.23	5.42	40.64	2.57	14.72	11.83	1.05	79348.00
12	9.30	6.21	47.62	2.11	15.16	11.96	1.06	77301.88
13	10.54	8.30	46.68	3.02	13.56	11.98	1.04	78219.86
14	8.88	3.84	47.48	1.74	14.82	11.99	1.02	75818.55
15	5.93	5.46	53.00	1.79	14.56	11.79	1.02	77732.41
16	6.04	6.06	53.44	1.74	14.90	11.72	1.04	78913.69
17	7.74	6.44	48.90	1.81	15.23	11.62	1.06	82002.34
18	4.07	6.24	64.22	1.50	15.11	12.29	1.06	76799.93
19	4.88	7.04	50.65	1.29	16.28	11.56	1.06	82883.35
20	10.27	6.09	46.81	1.98	15.21	11.47	1.06	82509.29
21	7.99	4.36	62.99	1.90	15.83	11.62	1.05	78815.57
22	4.80	4.65	66.30	1.18	15.75	12.08	1.06	76949.06
23	5.60	4.84	51.69	1.48	15.77	11.69	1.06	81238.95
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.72	5.02	52.86	1.98	15.36	11.90	1.04	79081.72
最 大 值	10.78	8.30	66.30	3.33	17.57	12.64	1.08	82883.35
發生時間	6	13	22	1	3	2		19
最 小 值	3.75	2.09	40.64	1.14	13.56	11.47	1.01	72831.36
發生時間	2	1	11	3	13	20		1
零點偏移(率)	-0.06 %	-0.00 %	-0.01 %	-0.01 %		0.00		0.10 %
全幅偏移(率)	0.00 %	0.00 %	-0.00 %	0.00 %		0.08		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月18日

[illegible]

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月18日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO ₂ _C	#3-H ₂ O	#3-O ₂ _C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.98	3.36	51.41	2.32	13.61	11.42	1.07	74808.97
1	6.21	3.20	47.94	1.70	15.22	10.80	1.05	77969.41
2	8.40	1.14	46.30	1.63	17.06	10.32	1.07	80571.42
3	8.16	3.15	52.98	1.42	16.90	10.63	1.07	79391.99
4	9.05	4.37	53.94	1.31	19.08	10.10	1.06	83150.27
5	8.40	5.64	38.40	1.10	18.09	10.00	1.05	84884.41
6	9.22	5.84	49.44	1.07	17.90	10.18	1.05	83707.62
7	1.64	8.82	52.75	0.65	16.18	10.49	1.05	83736.55
8	2.96	4.09	50.92	0.99	16.79	10.53	1.06	81025.21
9	6.16	4.19	49.85	1.32	16.63	10.63	1.06	80610.70
10	4.61	4.30	48.32	1.33	15.32	11.00	1.08	77033.40
11	5.98	4.78	49.88	1.51	15.13	11.02	1.09	78028.69
12	2.47	4.27	50.40	1.08	15.87	10.84	1.09	78161.42
13	1.58	3.87	48.71	1.27	16.34	10.50	1.10	78914.65
14	2.24	3.43	44.63	1.28	15.51	10.71	1.09	76221.62
15	3.06	4.26	52.95	1.42	14.93	10.74	1.09	75848.77
16	4.28	3.70	50.86	1.15	16.03	10.46	1.09	78804.82
17	1.41	3.88	50.80	0.79	16.20	10.31	1.08	80307.00
18	2.39	3.75	55.44	0.56	17.54	10.20	1.07	82001.06
19	3.71	4.04	47.09	0.92	16.24	10.12	1.07	83293.90
20	4.36	3.77	50.36	1.03	16.16	10.17	1.06	80343.67
21	5.61	2.57	54.39	0.82	16.96	10.40	1.07	78225.03
22	2.78	3.92	63.92	0.47	17.89	10.75	1.08	76770.06
23	1.95	4.99	59.81	0.72	17.18	11.29	1.09	72443.00
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.69	4.14	50.90	1.16	16.45	10.57	1.07	79427.24
最 大 值	9.22	8.82	63.92	2.32	19.08	11.42	1.10	84884.41
發生時間	6	7	22	0	4	0		5
最 小 值	1.41	1.14	38.40	0.47	13.61	10.00	1.04	72443.00
發生時間	17	2	5	22	0	5		23
零點偏移(率)	-0.05 %	-0.01 %	-0.01 %	0.00 %		-0.02		0.00 %
全幅偏移(率)	0.02 %	-0.74 %	-0.36 %	0.03 %		0.02		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								